


Appendix C2.2 - SCI Field Photos 2019.05.10.pdf 1 5/8/2020 2:40:17 PM




Appendix C2.2 - SCI Field Photos 2019.05.10.pdf 2 5/8/2020 2:40:26 PM













Appendix D

Southern California Edison, Pump Performance Test Records from 1984, 1988, and 1990.

SOUTHERN CALIFORNIA EDISON

Confidential/Proprietary Information

February 25, 2020

JOSHUA MEMORIAL PARK 808 EAST LANCASTER BLVD. LANCASTER, CA 93535

HYDRAULIC TEST RESULTS:

Location: 808 E LANCASTER BLVD

Cust #: Serv. Acct. #:

Meter: 732-3114 Pump Ref.#: 2871

In accordance with your request, an energy efficiency test was performed on your turbine well pump pump on January 26, 1984. If you have any questions regarding the results which follow, please contact UNKNOWN USER at .

Equipment

HP: 40

 Pump:
 PEERL
 No:
 86849

 Motor:
 WH
 No:
 1010V906

Results	Test 1	Test 2
Discharge Pressure, PSI	58.5	76.9
Standing Water Level, Feet	206.5	206.5
Drawdown, Feet	29.4	26.9
Discharge Head, Feet	135.1	177.6
Pumping Water Level, Feet	235.9	233.4
Total Head, Feet	371	411
Capacity, GPM	216	182
GPM per Foot Drawdown	7.3	6.8
Acre Feet Pumped in 24 Hours	.955	.804
kW Input to Motor	31.5	30.8
HP Input to Motor	42.2	41.3
Motor Load (%)	94	91.9
kWh per Acre Foot	792	919
Overall Plant Efficiency (%)	47.9	45.7

SOUTHERN CALIFORNIA EDISON AU EDISON INTERNATIONAL COmpany

Confidential/Proprietary Information

February 25, 2020

JOSHUA MEMORIAL PARK 808 EAST LANCASTER BLVD. LANCASTER, CA 93535

PUMPING COST ANALYSIS:

Location: 808 E LANCASTER BLVD

 CSS Cust #:
 CRM Cust #:
 Pump Ref.#: 2871

 CSS Serv. Acct.:
 CRM Serv. Acct.:
 Meter: 732-3114

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on January 26, 1984, billing history for the past 12 months, and your current rate of GS-2.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 47.9% to .0%.
- 2. This can save you up to 0 kWh and \$0.00 annually.

		Plant Efficiency	
	<u>Existing</u>	<u>Improved</u>	<u>Savings</u>
Total kWh	85,632	85,632	
kW Input	31.50	31.50	.00
kWh per Acre Foot	792	792	
Acre Feet per Year	108.1		
Average Cost per kWh	\$0.00		
Average Cost per Acre Foot	\$0.00	\$0.00	\$0.00
Overall Plant Efficiency (%)	47.9		
Total Annual Cost	\$0.00	\$0.00	\$0.00

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact UNKNOWN USER at .

SOUTHERN CALIFORNIA EDISON AU EDISON INTERNATIONAL COmpany

Confidential/Proprietary Information

February 25, 2020

JOSHUA MEMORIAL PARK 808 EAST LANCASTER BLVD. LANCASTER, CA 93535

HYDRAULIC TEST RESULTS:

Location: 808 E LANCASTER BLVD

Cust #: Serv. Acct. #:

Meter: 732-3114 Pump Ref.#: 2871

In accordance with your request, an energy efficiency test was performed on your turbine well pump pump on April 14, 1988. If you have any questions regarding the results which follow, please contact UNKNOWN USER at .

Equipment

HP: 40

 Pump:
 PEERL
 No:
 86849

 Motor:
 WH
 No:
 1010V906

Results	Test 1	Test 2
Discharge Pressure, PSI	32.3	52.2
Standing Water Level, Feet	211.7	211.7
Drawdown, Feet	39.5	38
Discharge Head, Feet	74.6	120.6
Pumping Water Level, Feet	251.2	249.7
Total Head, Feet	325.8	370.3
Capacity, GPM	293	249
GPM per Foot Drawdown	7.4	6.6
Acre Feet Pumped in 24 Hours	1.295	1.101
kW Input to Motor	35.4	36
HP Input to Motor	47.5	48.3
Motor Load (%)	105.6	107.4
kWh per Acre Foot	656	785
Overall Plant Efficiency (%)	50.8	48.2

SOUTHERN CALIFORNIA EDISON

Confidential/Proprietary Information

February 25, 2020

JOSHUA MEMORIAL PARK 808 EAST LANCASTER BLVD. LANCASTER, CA 93535

PUMPING COST ANALYSIS:

Location: 808 E LANCASTER BLVD

 CSS Cust #:
 CRM Cust #:
 Pump Ref.#: 2871

 CSS Serv. Acct.:
 CRM Serv. Acct.:
 Meter: 732-3114

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on April 14, 1988, billing history for the past 12 months, and your current rate of GS-2.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 50.8% to .0%.
- 2. This can save you up to 0 kWh and \$0.00 annually.

		Plant Efficiency	
	<u>Existing</u>	<u>Improved</u>	<u>Savings</u>
Total kWh	109,884	109,884	
kW Input	35.40	35.40	.00
kWh per Acre Foot	656	656	
Acre Feet per Year	167.5		
Average Cost per kWh	\$0.00		
Average Cost per Acre Foot	\$0.00	\$0.00	\$0.00
Overall Plant Efficiency (%)	50.8		
Total Annual Cost	\$0.00	\$0.00	\$0.00

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact UNKNOWN USER at .

SOUTHERN CALIFORNIA EDISON AN EDISON INTERNATIONAL COMPANY

Confidential/Proprietary Information

February 25, 2020

JOSHUA MEMORIAL PARK 808 EAST LANCASTER BLVD. LANCASTER, CA 93535

HYDRAULIC TEST RESULTS:

Location: 808 E LANCASTER BLVD

Cust #: Serv. Acct. #:

Meter: 732-3114 Pump Ref.#: 2871

In accordance with your request, an energy efficiency test was performed on your turbine well pump pump on October 17, 1990. If you have any questions regarding the results which follow, please contact GARY PARDUE at .

Equipment

HP: 40

 Pump:
 PEERL
 No:
 86849

 Motor:
 WH
 No:
 1010V906

Results	Test 1	Test 2	Test 3
Discharge Pressure, PSI	54.5	66.7	82.9
Standing Water Level, Feet	219	219	219
Drawdown, Feet	39.4	38.6	36.4
Discharge Head, Feet	125.9	154.1	191.5
Pumping Water Level, Feet	258.4	257.6	255.4
Total Head, Feet	384.3	411.7	446.9
Capacity, GPM	234	210	187
GPM per Foot Drawdown	5.9	5.4	5.1
Acre Feet Pumped in 24 Hours	1.033	.930	.826
kW Input to Motor	34.6	34.6	34.4
HP Input to Motor	46.4	46.4	46.1
Motor Load (%)	103.2	103.2	102.6
kWh per Acre Foot	804	893	999
Overall Plant Efficiency (%)	48.9	47.1	45.7

The above test results indicate various operating conditions of this pump.

SOUTHERN CALIFORNIA EDISON

Confidential/Proprietary Information

February 25, 2020

JOSHUA MEMORIAL PARK 808 EAST LANCASTER BLVD. LANCASTER, CA 93535

PUMPING COST ANALYSIS:

Location: 808 E LANCASTER BLVD

 CSS Cust #:
 CRM Cust #:
 Pump Ref.#: 2871

 CSS Serv. Acct.:
 CRM Serv. Acct.:
 Meter: 732-3114

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 17, 1990, billing history for the past 12 months, and your current rate of GS-2.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 48.9% to 60.0%.
- 2. This can save you up to 17,164 kWh and \$1,920.10 annually.
- 3. These kWh savings translate to a 7.5-ton decrease in CO2 emissions.

		Plant Efficiency	
	<u>Existing</u>	<u>Improved</u>	<u>Savings</u>
Total kWh	92,616	75,452	17,164
kW Input	34.60	28.19	6.41
kWh per Acre Foot	804	655	149
Acre Feet per Year	115.2		
Average Cost per kWh	\$0.11		
Average Cost per Acre Foot	\$89.95	\$73.28	\$16.67
Overall Plant Efficiency (%)	48.9	60	
Total Annual Cost	\$10,360.95	\$8,440.86	\$1,920.10


It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at .

Appendix E


SCI Irrigated Area Analysis Google Earth Historical Satellite Imagery

Date	Acres	Notes
1994, May 27	18.72	Mortuary building does not exist.
2003, July 3	18.61	Mortuary building exists (built in 1997).
2003, August 13	21.40	Area south of mortuary building is irrigated.
2003, September 12	21.40	Area south of mortuary building is irrigated.
2005, November 15	18.27	
2004, December 31	18.32	
2006, January 8	18.32	
2006, March 15	18.32	
2008, January 8	18.32	
2009, May 24	18.32	
2011, July 15	18.32	
2011, December 3	18.32	
2012, August 25	18.32	
2013, May 24	18.32	
2015, April 10	18.69	
2015, September 4	18.69	Small, irrigated area south of mortuary building.
2016, October 4	18.69	Small, irrigated area south of mortuary building.
2017, April 28	18.69	Small, irrigated area south of mortuary building.
Mean	18.78	
Standard Deviation	0.94	
Minimum	18.27	
Maximum	21.40	


1994, May 27




2003, June 3




2003, August 13




2003, September 12




2005, November 15




2004, December 31




2006, January 8




2006, March 15




2008, January 8




2009, May 24




2011, July 15




2011, July 16




2011, December 3




2012, August 25




2013, May 24




2015, April 10




2015, September 4



2016, October 4



2017, April 28



Appendix F

DRC Pump Systems Invoice Records 1988, 1993, and 2018

INVOICE

DEL R. COMBS, INC.



PEERLESS PUMP SALES & SERVICE P.O. BOX 1029 LANCASTER, CALIFORNIA 93534 (805) 942-1173

DATE 2/25/88

Joshua Memorial Park 808 E. Lancaster Blvd. Lancaster, Ca. 93535

	942-812	5
DESCRIPTION		TOTAL
RE: Our w/o #00619 & additional work.		
ITEM #1 Labor pull complete pump 250' of 6" x 2 x 1-3/16 x 10' lengths of column tube & shaft. Plus 12-stage 10" bowls w/ ft. valve. 72hrs. @ 70.00	\$ 525.00	
ITEM #2 OUTSIDE LABOR BY WELENCO - T.V. well	\$ 710.00	
ITEM #3 EXTRA ITEM Checked depth of well 358', water level @ 150' also loaded motor & hauled to Bowen Electric, Inc. for clean up & retreat. 12hrs. @ 70.00	\$ 105.00	
ITEM #4 EXTRA ITEM Installed 5' linner in well @ 138'.	\$1640.00	
ITEM #5 Shop Labor disassy. 250' of inner col., reface tubes, check bearing, steam clean tubes, & clean & check shaft's & reassemble.	\$1050.00	
on 40hp motor clean up & bearing exchange	\$ 220.00	
ITEM #7 Labor to reinstall pump 250' plus 20' of extension, plus rebuilt 13- stage of bowls. 3men 7hrs. @ 80.00	\$ 560.00	
ITEM #8 EXTRA LABOR Received call- pump was pumpin up 90 psi into pressure tank but no water in field. Service labor found screen in sand trap plugged with sand. Removed & cleaned.	G 105 00	
2 men 1½hrs. @ 70.00 ITEM #8 EXTRA LABOR Returned & found check valve not holding water filled w/ sand, gasket bad, also removed man hole cover & had sand cleaned out of pressure tank. Made new rubber flapper gasket & reassy.check valve	\$ 105.00	
& started pump. 1man 5½hrs. @ 40.00	\$ 220.00	
con'L.		



PEERLESS PUMP SALES & SERVICE P.O. BOX 1029 LANCASTER, CALIFORNIA 93534 (805) 942-1173

DATE 2/25/88


Joshua Memorial Park


DESCRIPTION			TOTAL
con't. ITEM #10 EXTRA LABOR Received 3rd call- Check valve still wasn't checked out complete system & found OK. Als & started. Was running 4 lines @ 70#psi.		\$ 80.00 \$4285.00 \$ 930.00	
MATERIAL 40' 8 2" x 5' oil tubes @ 14.40 ea. 2- 2 x 1-3/16" line shaft bearings @ 14.00 e 13- Stage 9" LA Peerless bowls 1- 6" surge valve (Lakewood) 1- 6" nipple TOE w/ 6" galv cone strainer & 1- 7313 thrust motor bearing 1- 6212 guide motor bearing 1- used 6" std. x 10' suction 20' of new extension 6 x 2 x 1-3/16		\$ 115.20 \$ 28.00 \$2500.00 \$ 280.00 \$ 132.80 \$ 38.30 \$ 75.00 \$ 400.00 \$3569.30 \$ 80.00 \$ 237.20	
	GRAND TOTAL LESS DOWN PMT BALANCE DUE	\$910 50 \$2500.00- \$6601.50	
Thank Youll			
MATERIAL REMAINS THE PROPERTY OF DRC PU	MP SYSTEMS. INC. UNTIL PAID	N FULL	

Fick R-AL-GERY JOB RECORD

1 1	111	DAI	2-2	22-	88
Name Job	is Mam	orial to	RK		
Location 10 Th	Lancaste	RBL E	ast		
Pump Make Reel	less		No.		
I. D. Well /2 //	(270	+ BONLS)	Total De	opth 3	581
6"Lgth. Column20-10"	5×6"	3-20 \$ 10°	heaste Tub	ing 2'	X13
Size Shaft / 3	_	0' Lgths.	3-20'5	10 h	ad
No. Threads	Column	Tubing	R	()	L () Shaft
Size Bowls /0 "	Stages 13	Suction	D	isc.	
Motor HP 40	Make	RPM	Horiz.	vнs	V88
MISC. QUTI SUL	ee Volve	aT Botto	m of R	rulo	
EMDELLER!	FTA	4391			
		•			

Additional Information on Back





SALES & SERVICE

STATE CONT. LIC. NO. 329759

3604 EAST AVENUE I

LANCASTER, CALIFORNIA 93535

FAX (805) 946-1559 (805) 946-9444

8/26/93

JOSHUA MEMORIAL PARK 808 E. LANCASTER BLVD. LANCASTER, CA. 93534

	DESCRIPTION			TOTAL
	Our WORK ORDER #00812 3-men & rig, drove to well site & set up 270' of 6" pump, plus 13-stg 10" bowls.			
	wore out. 60' of tube & shaft was also Checked water level @ 135' Depth of we	wore out. 11 @345'		
	Load pump on truck & return to shop & un SHOP: Assemble new submersible pump & n tighten collars on 4" pipe. Load mater	3-men 7 hrs. make cable splice. ials on truck. Make	\$ 875.00	
8/24	8" shroud for pump. 2-men & rig, drove to well site. Bail to depth of 352'. Install new 30 HP Gr with 273' of 4" pipe and #8 sub. cable. run pump until water clear. Hookup dissystem in operation. An electrician wi	undfos submersible pump Made all hookups and charge to tank. Put	\$ 400.00	\$2100.0
	MATERIALS: 30 HP Grundfos 460V, 30, submersible pur 270' of 4" pipe 270' of #8 sub. cable wire 1- well plate seal 1- 8" x 10" shroud 1- 4" x 3" bell reducer & 2-4" tee's	list \$5778.00 TOTAL MATERIALS SALES TAX	\$5200.00 \$1620.00 \$ 540.00 \$ 150.00 \$ 85.00 \$ 140.00	\$7735.0
3/5/9	THIS PUMP HAS A 1 YEAR WARRANTY. 3 RECEIVED DOWN PAYMENT CK. #22995	FREIGHT GRAND TOTAL		\$ 137.0 \$10610.1 .\$ 5305.0
		BALANCE		\$5305.14

DRC Pump Systems, Inc. 44434 90th St. East

Lancaster Ca 93535-2413 Phone: 661-946-9444

Invoice

Date	Invoice #
5/7/2018	3694

Bill To	
Joshua Memorial Cemetary SCI CA Funeral Services, Inc. 808 E Lancaster, CA 93535	

Desc	ription	Amount
Labor to pull 273' of 4' galvanized, 30 HP pump and re		3,600.00
1 - 230S300-9 30 HP pump and motor 40' of 4" galvanized pipe 40' of # 8 submersible cable Sales Tax		8,390.00T 532.14T 124.32T 859.41
Thank you for choosing DRC Pumps		Total \$13,505.87

PROOF OF SERVICE STATE OF CALIFORNIA, COUNTY OF SAN BERNARDINO

Re: ANTELOPE VALLEY GROUNDWATER CASES

Los Angeles County Superior Court Judicial Council Coordinated

Proceedings No. 4408; Santa Clara County Superior Court Case No. 1-05-CV-049053

I am employed in the County of San Bernardino, State of California. I am over the age of 18 years and not a party to the within action; my business address is: 550 East Hospitality Lane, Suite 300, San Bernardino, CA 92408-4205.

On May 14, 2020, I served the foregoing document(s) described SCI CALIFORNIA FUNERAL SERVICES, INC., A CALIFORNIA CORPORATION DBA JOSHUA MEMORIAL PARK'S VERIFIED DISCOVERY REPSONSE REGARDING GROUNDWATER PRODUCTION RIGHT CLAIM on the interested parties in this action in the following manner:

(X) **BY ELECTRONIC SERVICE** – I caused such document(s) listed above to be electronically served, via One Legal, to all parties appearing on the Santa Clara County Superior Court website, http://www.scefiling.org, in the action of the Antelope Valley Groundwater Cases; proof of electronic-filing through One Legal is then printed and maintained with the original documents in our office. Electronic service is complete at the time of transmission. My electronic notification email address is dina.snider@greshamsavage.com,

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct.

Executed on May 14, 2020 at San Bernardino, California.

DINA M. SNIDER

GRESHAM SAVAGE

ATTORNEYS AT LAW
550 EAST HOSPITALITY LANE
THIRD FLOOR
SAN BERNARDINO, CA
92408
(909) 890-4499