


# **Exhibit E**



# PUMP CHECK

Pumping Systems Analysts  
Hydraulic Test Report

Since 1958

(951) 684-9801 • Lic. 799498 • Fax (951) 684-2988

## CERTIFICATE OF ACCURACY

Customer: Phelan Pinon Hills CSD  
Location: 13150 263rd Street  
Identification: Well #14

Test Date: 10/09/2012

Meter Size: 12" Make: Siemens Mag Flo  
Meter No: 7ME652948102N297 Register: MG x .0001

### General Data

Meter read before test: 1156.0646 Meter read after test: 1156.0778

Pipe ID: 12 (Inch) Pipe area: 113.1 (sq.in.) Pressure: 151.0 (Lbs/sq.in.)

### Test Data

#### Test Before Inspection

Test Equipment			Totalizer		Volume			Metered GPM	Percent of Flow
Test No.	Mano Read	Actual GPM	Second Read	First Read	Diff.	Convert to Gallons	Time in Seconds		
1	6.40	724	1156.0708	1156.0680	28	2,800	232.05	724	100.0%
2	6.35	718	1156.0743	1156.0711	32	3,200	267.67	717	99.9%
3	6.35	718	1156.0775	1156.0745	30	3,000	251.48	716	99.7%
Avg.		720.1					Avg.	719.0	99.9%


### Remarks

34.29.290n117.39.656w  
PC 3235/SCE 32127

Approved \_\_\_\_\_

P.O. Box 5646, Riverside, California 92517

"Pump Testing, The Service That Pays For Itself"



# PUMP CHECK

Pumping Systems Analysts  
Hydraulic Test Report

(951) 684-9801 • Lic. 799498 • Fax (951) 684-2988

## CERTIFICATE OF ACCURACY

Customer: Phelan Pinon Hills CSD  
Location: 13150 263rd Street  
Identification: Well #14

Test Date: 09/27/2010

Meter Size: 12" Make: Siemens  
Meter No: 7ME652948102N297 Register: Gal x 1 million

### General Data

Meter read before test: 462.084 Meter read after test: 462.1106

Pipe ID: 12 (Inch) Pipe area: 113.1 (sq.in.) Pressure: 145.0 (Lbs/sq.in.)

### Test Data

#### Test Before Inspection

Test Equipment	Mano Read	Actual GPM	Totalizer			Volume			
			Second Read	First Read	Diff.	Convert to Gallons	Time in Seconds	Metered GPM	Percent of Flow
1	6.95	786	462.0936	462.09	0.004	4,000	306.66	783	99.6%
2	6.90	780	462.098	462.094	0.0041	4,100	316.22	778	99.7%
3	6.95	786	462.1023	462.098	0.004	4,000	305.93	784	99.8%
Avg.		784.2					Avg.	781.7	99.7%

### Remarks

34.29.290n117.39.656w  
PC 3235/SCE 32127

Approved \_\_\_\_\_

P.O. Box 5646, Riverside, California 92517