

Phelan Pinon Hills Community Service District

Well Log

Hour read: 1419.11

549.5816

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	13216	10:45	550.7696	.8874	14755.75	19.64	753	39711	✓	154	
2	13	11:00	551.7749	1.0109	14811.15	22.4	752	39765	Filled	150	
3	13	8:30	552.1913 mg	.7119	14827.09	15.94	744	40600	Filled	144	
4	13	8:10	553.3467 mg	.8549	14846.17	19.08	747	40051	Filled	155	
5	13	9:45	554.4811 mg	1.1344	14871.78	25.41	738	40113	Filled	145	
6	13	11:00	555.6237 mg	1.1426	14896.93	25.45	757	40175	Filled	170	
7	LEA	8:45	556.5142 mg	.8905	14916.82	19.89	746	40222	Filled	157	
8	EPA	8:09	557.4372 mg	.9223	14937.46	26.64	745	40272	Filled	160	
9	EPA	9:10	558.3107 mg	.8735	14957.28	19.82	755	40320	Filled	165	
10	13	9:00	559.2998 mg	.9211	14979.23	26.95	751	40374	Filled	150	
11	13	9:40	560.2200 mg	.9207	14999.57	20.84	754	40423	Filled	150	
12	13	9:00	561.1813 mg	.9615	15020.95	21.38	749	40475	Filled	150	
13	EPA	7:57	562.0787 mg	.8974	15040.93	19.98	749	40524	Filled	160	
14	13	10:00	563.0620 mg	.9333	15062.87	21.94	747	40577	Filled	165	
15	13	11:45	563.9478 mg	.9858	15082.65	13.78	746	40625	Filled	154	
16	13	9:30	564.6941 mg	.7463	15099.50	16.75	742	40666	Filled	170	
17	13	9:45	565.5474 mg	.8533	15118.52	16.02	743	40773	Filled	170	
18	LEA	7:30	566.3612 mg	.8138	15136.73	18.23	744	40757	Filled	160	
19	JS	8:00	567.3039 mg	.9427	15157.69	20.96	750	40708	Filled	155	
20	LEA	8:05	568.1777 mg	.8138	15177.17	19.48	748	40855	Filled	163	
21	JS	8:45	569.0521 mg	.8744	15196.62	19.45	749	40908	Filled	160	
22	EPA	9:11	569.9340 mg	.8819	15216.32	19.70	746	40950	Filled	150	
23	LEA	7:45	570.7619 mg	.8279	15234.96	18.64	740	40995	Filled	155	
24	JS	8:30	571.7214 mg	.9600	15254.52	21.36	749	41047	Filled	160	
25	JS	8:10	572.662 mg	.9393	15277.24	20.92	748	41094	Filled	160	
26	13	9:00	573.6476 mg	1.0044	15299.47	22.23	755	41152	Filled	155	
27	13	8:35	574.6032 mg	.8354	15318.35	18.68	738	41198	Filled	156	
28	13	8:52	575.0034 mg	.8002	15324.76	11.41	730	41226	Filled	146	
29	TC	11:00	576.0465 mg	1.0491	15332.77	23.01	755	41282	Filled	150	
30	13	9:02	576.8293 mg	.7828	15370.40	17.63	740	41324	Filled	160	
31	13	8:35	577.6173 mg	.8680	15385.13	19.33	746	41371	Filled	160	

Comments:

Phelan Pinon Hills Community Service District

MONTH: FEBRUARY  
 YEAR: 2011  
 SITE: W-14

Well Log

Hour read: 15389.73

Flow Meter Read: 571.4973

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	LEA	7:25	578.5704 mg	.8731	15409.20	19.42	749	41419	Filled	162	
2	RS	7:55	579.4481 mg	.8777	15428.83	19.63	745	41446	Filled	146	
3	RS	9:00	580.4557 mg	1.0876	15451.18	22.38	751	41520	Filled	158	
4	LEA	8:10	581.2720 mg	.8163	15469.36	18.18	748	41565	Filled	158	
5	JS	9:30	582.2630 mg	.991	15491.30	21.94	752	41618	Filled	160	
6	TC	9:25	583.2135 mg	.9505	15512.57	21.27	744	41670	Filled	151	
7	RS	8:45	584.066 mg	.8532	15531.87	19.13	737	41716	Filled	152	
8	RS	8:15	585.0285 mg	.5618	15553.18	21.31	752	41761	Filled	155	
9	RS	10:45	585.9987 mg	.9702	15574.72	21.54	751	41820	Filled	135	Adj out stop
10	RS	8:10	586.7661 mg	.7674	15591.88	17.16	745	41862	Filled	150	
11	RS	9:00	587.6913 mg	.9252	15612.52	20.64	747	41912	Filled	150	
12	RS	1:10	588.7555 mg	1.0642	15636.21	23.59	749	41970	Filled	171	
13	RS	11:50	589.6500 mg	.8745	15656.52	20.11	741	42019	Filled	166	
14	RS	5:30	590.4278 mg	.7772	15675.56	17.54	739	42061	Filled	150	
15	RS	1:15	591.5513 mg	1.1241	15699.04	25.18	744	42122	Filled	162	
16	RS	10:00	592.3044 mg	.7531	15715.03	16.89	743	42143	Filled	190	
17	JS	8:45	593.2051 mg	.9107	15735.77	19.94	752	42211	Filled	160	
18	JS	9:45	594.2441 mg	1.041	15755.98	33.03	753	42267	Filled	180	
19	LEA	9:50	595.0993 mg	.8532	15777.75	18.85	754	42313	Filled	160	
20	EPA	10:44	596.0197 mg	.9204	15798.19	20.44	750	42363	Filled	148	
21	EPA	8:53	596.8258 mg	.8061	15815.80	17.61	743	42406	Filled	151	
22	RS	9:00	597.7441 mg	.9183	15835.92	20.12	741	42455	Filled	150	
23	RS	9:00	598.4627 mg	.7184	15852.21	16.29	735	42493	Filled	156	
24	RS	7:15	599.3534 mg	.8907	15871.79	19.58	758	42541	Filled	151	
25	RS	10:00	600.2822 mg	.9288	15892.19	20.40	759	42591	Filled	150	
26	CC	11:59	601.3016 mg	1.0194	15914.68	22.49	755	42646	"	158	
27	CC	8:55	602.0092 mg	.7076	15930.05	15.67	753	42684	"	155	
28	RS	9:00	602.9438 mg	.9846	15957.31	21.96	747	42739	Filled	190	
29											
30											
31											

Comr rts:

MONTH: MARCH  
 YEAR: 2011  
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Hour read: 15952.31

Flow Meter Read 602.9938 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	BS	8:00	503.9566 mg	9628	15973.66	21.35	752	42789	Filled	163	
2	DS	9:00	604.8962 mg	9396	15974.47	20.81	753	42861	Filled	150	
3	DS	9:15	605.8904 mg	9942	16006.22	21.75	762	42893	Filled	155	
4	EPA	8:00	606.7768 mg	8864	16035.72	19.15	758	42940	Filled	149	
5	TS	11:00	607.7376 mg	9608	16057.33	21.61	741	42992	Filled	160	
6	TC	9:40	608.5533 mg	8157	16075.54	18.21	746	43036	Filled	155	
7	DS	7:00	609.4395	8866	16095.18	19.64	752	43084	Filled	150	
8	DS	8:45	610.3610	9217	16115.65	20.47	750	43133	Filled	150	Adj. drop
9	DS	8:50	611.2270 mg	8660	16134.98	19.33	747	43180	Filled	156	
10	DS	8:45	612.1406 mg	9136	16155.42	20.44	745	43230	Filled	151	
11	DS	9:20	613.1644 mg	10238	16178.57	22.95	744	43286	Filled	155	
12	DS	2:25	614.2682 mg	11038	16202.72	24.55	749	43345	Filled	176	
13	TK	11:15	615.0530	7496	16220.18	17.26	754	43388	Filled	175	
14	DS	10:00	615.8631	8101	16238.67	18.49	730	43432	Filled	150	
15	DS	10:30	616.7813	9182	16257.34	20.67	740	43483	Filled	155	
16	DS	9:20	617.7000	9187	16277.73	20.39	751	43532	Filled	150	
17	TC	7:40	618.4812	7812	16297.60	17.87	728	43575	Filled	148	
18	DS	8:15	619.4513 mg	9701	16319.39	21.79	742	43628	Filled	155	
19	LEA	10:15	620.4630 mg	10117	16341.97	22.58	747	43682	Filled	160	
20	EPA	10:44	621.4982 mg	10352	16364.86	22.89	754	43738	Filled	149	
21	ALH	8:25	621.9715 mg	4733	16375.75	16.89	724	43761	Filled	150	
22	DS	8:20	622.8145 mg	8430	16394.82	19.07	737	43811	Filled	152	Adj. oil drop
23	DS	9:30	623.4560 mg	10115	16409.85	15.63	711	43846	Filled	171	
24	DS	8:45	624.2180 mg	7626	16426.79	16.94	750	43887	Filled	150	
25	DS	9:30	625.0374 mg	8194	16445.69	18.2	744	43932	Filled	163	
26	CC	8:33	625.8966 mg	8592	16463.46	18.87	759	43978	Filled	160	
27	TC	11:21	626.7790 mg	8824	16483.83	19.87	740	44027	Filled	158	
28	DS	7:00	627.5527 mg	7731	16501.06	17.23	748	44047	Filled	155	
29	DS	9:00	628.3846 mg	8319	16519.42	18.56	747	44114	Filled	157	
30	DS	9:00	629.3315 mg	7529	16540.59	20.07	757	44165	Filled	146	
31	DS	9:15	630.1858 mg	8483	16559.44	19.07	741	44211	Filled	148	

Comments:

MONTH: APRIL  
 YEAR: 2011  
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Last months Flow read: 630.1858 mg

Hour read: 16557.46

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	SS	9:25	631.1179 mg	9371	16580.63	20.17	741	44762	✓	160	
2	FL	6:35	631.8898 mg	7719	16598.48	17.85	720	44304	Filled	150	
3	TC	10:34	632.9736 mg	1,0338	16621.76	23.28	740	44361	Filled	150	
4	RS	9:00	633.8252 mg	1,9016	16642.05	20.29	741	44416	Filled	150	
5	RS	8:30	634.6872 mg	8570	16661.37	19.32	737	44456	Filled	150	
6	RS	8:40	635.5583 mg	8761.00	16681.71	20.34	718	44505	Filled	147	
7	RS	8:30	636.5120 mg	9537.00	16702.94	21.28	747	44558	Filled	186	
8	RS	9:15	637.4986 mg	9846.00	16724.98	21.99	748	44610	Filled	150	
9	RS	12:16	638.5191 mg	1,0725	16747.65	22.67	750	44665	Filled	173	
10	RS	10:59	639.3958 mg	8647	16767.08	19.13	741	44712	Filled	170	
11	RS	8:10	640.1971 mg	8133	16785.86	18.58	730	44757	Filled	149	
12	LEA	8:13	641.2105 mg	1,0134	16808.35	22.69	744	44812	Filled	162	
13	RS	9:06	642.2410 mg	1,0305	16831.44	23.09	744	44867	Filled	185	
14	RS	9:20	643.2194 mg	1,1784	16853.42	21.98	742	44920	Filled	168	
15	RS	9:30	644.0792 mg	8588	16873.01	19.02	730	44968	Filled	145	
16	EPA	9:55	644.9959 mg	9162	16893.92	20.88	731	45018	Filled	170	
17	LEA	8:55	645.9424 mg	9470	16915.61	21.59	731	45070	Filled	160	
18	RS	9:10	646.9196 mg	9772	16937.70	22.19	734	45123	Filled	150	
19	RS	7:40	647.8683 mg	9487.00	16957.26	21.5	735	45175	Filled	158	
20	RS	7:45	648.8739 mg	1,0056	16982.09	22.89	732	45230	Filled	150	
21	RS	10:50	650.0748 mg	1,2029	17007.46	27.37	732	45295	Filled	160	
22	RS	9:00	650.1716 mg	9280	17029.57	20.11	748	45344	Filled	149	
23	CC	10:30	652.0378 mg	1,8582	17053.73	24.16		45402	Filled	160	
24	SMILE	10:55	653.0210 mg	1,9832	17076.11	22.38	732	45456	Filled	160	
25	RS	3:00	651.2048 mg	1,1858	17102.91	26.8	737	45520	Filled	190	
26	RS	2:00	655.2745 mg	1,0675	17126.82	23.91	744	45578	Filled	155	
27	RS	9:00	655.9715 mg	1,7172	17143.20	16.38	730	45611	Filled	175	
28	RS	8:30	656.9889 mg	9974	17164.27	23.02	722	45673	Filled	149	
29	EPA	8:12	658.0004 mg	1,0115	17189.46	23.24	725	45727	Filled	156	
30	TS	9:30	659.0480 mg	1,0470	17213.55	23.89	731	45785	Filled	145	
31											

Comments:

Phelan Pinon Hills Community Service District

MONTH: MAY  
YEAR: 2011  
SITE: W-14

Well Log

Last months Flow read: 659.0480 mg

Hour read: 17213 35

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	BS	9:30	660.1285 mg	1.0805	17238.10	24.75	727	45864	ok	175	
2	BS	10:30	661.2744 mg	1.1457	17264.54	26.44	722	45708	Filled	166	
3	BS	10:50	662.1783 mg	1.039	17255.54	21.02	717	45958	Filled	166	
4	BS	8:15	663.1274 mg	1.0491	17267.68	22.12	715	46012	Filled	167	
5	BS	8:15	664.1477 mg	1.0205	17281.64	23.96	710	46068	Filled	165	
6	BS	8:45	665.2217 mg	1.0768	17293.71	25.07	714	46128	Filled	167	
7	BS	11:00	666.3254 mg	1.1057	17302.44	25.75	712	46189	Filled	166	46 gal drop
8	BS	10:45	667.3324	1.007	17406.04	23.58	722	46245	Filled	159	
9	BS	8:30	668.2838 mg	1.1546	17427.75	21.91	724	46298	Filled	190	
10	BS	9:00	669.3231 mg	1.0393	17452.35	24.4	710	46363	Filled	190	
11	BS	8:10	670.3273 mg	1.1920	17475.67	23.32	714	46411	Filled	157	
12	BS	8:40	671.3661 mg	1.0438	17500.15	24.48	711	46470	Filled	165	
13	BS	9:00	672.4306 mg	1.0646	17524.82	24.67	719	46529	Filled	165	
14	EPA	9:15	673.4541 mg	1.0235	17548.73	23.91	713	46586	Filled	158	
15	LEA	9:40	674.5032 mg	1.0491	17573.03	24.3	720	46644	Filled	190	
16	BS	9:00	675.6762 mg	1.1730	17595.65	22.42	717	46693	Filled	170	
17	LEA	8:10	676.3995 mg	1.0233	17617.29	21.64	711	46749	Filled	168	
18	BS	9:10	677.3956 mg	1.1961	17640.53	23.24	714	46805	Filled	160	
19	BS	9:15	678.3769 mg	1.0215	17663.98	23.45	712	46860	Filled	150	
20	BS	10:15	679.4666 mg	1.0696	17688.85	24.11	714	46920	Filled	169	
21	BS	12:10	680.5377 mg	1.0712	17714.28	25.39	703	46980	Filled	196	
22	BS	9:19	681.3770 mg	1.039	17734.20	19.92	702	47027	Filled	160	
23	BS	9:20	682.3415 mg	1.1643	17757.20	23.06	698	47081	Filled	172	
24	BS	8:45	683.2594 mg	1.1810	17778.65	21.45	713	47133	Filled	172	
25	BS	8:40	684.2328 mg	1.1734	17801.96	23.31	696	47188	Filled	160	
26	BS	9:20	685.2689 mg	1.0341	17826.91	24.55	703	47246	Filled	180	
27	BS	10:10	686.3122 mg	1.0433	17851.50	24.49	700	47305	Filled	190	
28	BS	10:21	687.2951 mg	1.0829	17875.04	23.54	696	47361	Filled	170	
29	BS	9:30	688.2435 mg	1.084	17897.84	22.85	692	47415	Filled	175	
30	BS	8:04	689.1504 mg	1.0629	17919.52	21.63	698	47466	Filled	150	
31	BS	9:10	690.1486 mg	1.074	17944.24	24.77	685	47525	Filled	165	

Comments:

MONTH: JUNE  
 YEAR: 2011  
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Hour read: 17:00:00

Flow Meter Read: 492.1456 mg

Last months Flow read: 492.1456 mg

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	8:45	LEA	691.1489 mg	.9809	17967.77	23.48	696	47580	Filled	177	
2	8:25	LEA	692.1456 mg	.9967	17991.48	23.71	701	47636	Filled	175	
3	8:45	RS	693.1652 mg	1.0196	18015.82	24.34	698	47694	Filled	162	
4	RS	10:15	694.2350 mg	1.0698	18041.24	25.44	701	47754	Filled	174	
5	RS	12:00	695.3885 mg	1.1535	18067.26	25.94	741	47816	Filled	146	
6	LEA	8:45	696.2926 mg	.9041	18087.77	20.57	733	47865	Filled	210	
7	LEA	9:00	697.3107 mg	1.0181	18112.07	24.3	698	47922	Filled	190	
8	LEA	8:35	698.3039 mg	.9932	18135.64	23.57	702	47978	Filled	205	
9	LEA	8:10	699.1476 mg	.8437	18155.97	20.33	691	48026	Filled	162	
10	LEA	8:30	700.0203 mg	.8727	18176.14	20.17	700	48075	Filled	165	
11	LEA	10:10	701.1076 mg	1.0873	18202.38	25.164	707	48136	Filled	160	
12	LEA	9:03	702.0807 mg	.9731	18225.38	2.3	705	48190	Filled	174	
13	LEA	8:10	703.0541 mg	.9724	18248.18	22.8	712	48245	Filled	175	
14	LEA	8:10	704.0668 mg	1.0127	18272.16	23.98	704	48301	Filled	170	Fashed Bo DIE
15	LEA	8:25	705.0856 mg	1.0188	18296.14	23.98	708	48358	Filled	162	in wash
16	LEA	7:50	706.0742 mg	.9886	18319.48	23.34	706	48414	Filled	170	
17	RS	8:15	707.1023 mg	1.0281	18343.92	24.44	701	48472	Filled	171	
18	CC	9:16	708.1641 mg	1.0618	18368.97	25.05	706	48531	Filled	155	
19	CC	9:51	709.2113 mg	1.0472	18393.54	24.57	710	48589	Filled	155	
20	LEA	10:08	710.1840 mg	.9127	18416.38	22.84	710	48644	Filled	175	
21	LEA	8:00	711.1077 mg	.9237	18438.28	21.9	703	48695	Filled	160	
22	LEA	8:10	712.1151 mg	1.0074	18462.39	24.11	696	48752	Filled	165	
23	LEA	8:40	713.1441 mg	1.029	18486.91	24.52	699	48810	Filled	172	
24	LEA	8:40	714.1591 mg	1.015	18510.91	24.0	705	48867	Filled	177	
25	RS	8:30	715.1607 mg	1.0011	18534.58	23.97	697	48924	Filled	175	
26	LEA	8:37	716.1576 mg	.9974	18558.86	23.98	693	48980	Filled	179	
27	LEA	8:10	717.1386 mg	.9810	18582.39	23.53	695	49035	Filled	194	
28	LEA	7:47	718.1277 mg	.9891	18606.02	23.63	698	49091	Filled	180	
29	LEA	8:45	719.1676 mg	1.0399	18630.00	23.98	723	49150	Filled	173	
30	LEA	8:40	720.1628 mg	.9952	18654.91	24.91	666	49207	Filled	175	
31											

Comments:

MONTH: July  
 YEAR: 2011  
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Hour read: 18654.91

Flow Meter Read: 720.1628 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Edison	Oil	PSI	Comments
1	RS	9:30	721.2028	1.04100	18779.73	24.84	698	49265	Filled	162	
2	RS	11:00	722.2685	1.064700	18785.04	25.29	699	49329	Filled	160	
3	HA	9:25	723.2041	.9354	18727.55	22.41	695	49399	Filled	160	
4	HA	9:17	724.2246	1.0205	18757.00	24.45	695	49436	Filled	163	FLUSHED @ 02 WASH
5	LEA	8:30	725.1764 mg	.9518	18774.72	22.72	698	49490	Filled	184	
6	LEA	8:25	726.1713 mg	.9949	18798.64	23.92	693	49547	Filled	766	
7	LEA	8:35	727.1917 mg	1.0204	18822.81	24.17	704	49604	Filled	184	
8	LEA	8:20	728.1726 mg	.9809	18846.58	23.97	688	49660	Filled	168	
9	LEA	9:10	729.2050 mg	1.0824	18871.43	24.85	692	49719	Filled	182	
10	EPA	7:49	730.1442 mg	.9392	18894.06	22.62	692	49772	Filled	164	Adj Dipper
11	LEA	8:50	731.1949 mg	1.0527	18919.09	25.03	700	49831	Filled	162	
12	LEA	7:57	732.1612 mg	.9663	18942.20	23.11	697	49886	Filled	164	
13	EPA	7:57	733.1680 mg	1.0068	18966.25	24.05	698	49943	Filled	176	
14	LEA	8:00	734.1370 mg	.969	18989.48	23.23	695	49998	Filled	160	
15	RS	8:40	735.1520 mg	1.0150	19013.75	24.27	697	50055	Filled	179	
16	LE	9:12	736.1703 mg	1.0185	19038.25	24.5	693	50113	Filled	190	
17	LE	9:02	737.1818 mg	1.0118	19062.15	23.9	705	50170	Filled	179	
18	LEA	9:20	738.2157 mg	1.0339	19086.35	24.2	712	50228	Filled	157	
19	LEA	8:10	739.1833 mg	.9676	19109.25	22.9	704	50282	Filled	178	FLUSHED Blow off
20	LEA	8:33	740.1822 mg	.9989	19132.75	23.5	700	50338	Filled	155	at 42ASH
21	LEA	9:32	741.2398 mg	1.0576	19157.73	24.98	706	50397	Filled	173	
22	LEA	8:42	742.2165 mg	.9767	19180.89	23.16	703	50452	Filled	155	
23	RS	10:10	743.2466 mg	1.0001	19204.50	23.67	704	50508	Filled	145	
24	LE	12:14	744.3404 mg	1.1238	19231.03	26.47	707	50571	Filled	175	
25	LEA	8:10	745.1263 mg	.7859	19250.06	19.03	688	50616	Filled	169	
26	LEA	8:10	746.1345 mg	1.0082	19274.06	24.00	700	50673	Filled	157	FLUSHED Blow off
27	LEA	8:30	747.1502 mg	1.0157	19298.38	24.32	696	50730	Filled	175	AT 02ASH
28	RS	11:30	748.2013 mg	1.1110	19325.73	24.95	687	50794	Filled	146	
29	RS	8:50	749.1469 mg	.8560	19346.67	21.34	692	50844	Filled	145	
30		12:30	750.2904 dy	1.143200	19374.30	27.63	690	50909	Filled	175	
31			751.1689	.8785	19395.80	21.56	679	50959	Filled	145	

Comr ts:

Phelan Pinon Hills Community Service District

MONTH: August  
YEAR: 2011  
SITE: W-14

Well Log

Last months Flow read: 751.1689 mg

Hour read: 19395.86

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	LEA	8:38	752.0547 mg	8858	19417.03	21.17	697	51010	Filled	160	
2	LEA	8:20	752.9787 mg	8240	19439.26	22.23	693	51062	Filled	187	
3	LEA	10:15	754.0553 mg	1.0766	19465.19	25.93	692	51123	Filled	187	
4	LEA	8:08	754.9640 mg	.9087	19487.07	21.88	692	51175	Filled	198	
5	LEA	8:40	755.9814 mg	1.0174	19511.58	24.51	690	51223	Filled	165	
6	EPA	7:57	756.9470 mg	.9656	19534.99	23.41	687	51288	Filled	162	
7	LEA	9:55	758.0166 mg	1.0696	19560.86	25.87	689	51349	Filled	187	FLASHER BOE WASH 16 min
8	LEA	8:13	758.9431 mg	.9265	19583.15	22.29	693	51402	Filled	162	
9	LEA	8:18	759.9435 mg	1.0004	19607.22	24.07	693	51459	Filled	167	
10	IS	8:30	760.9528 mg	1.0093	19631.77	24.55	685	51517	Filled	180	
11	LEA	8:25	761.9324 mg	.9796	19655.35	23.58	690	51572	Filled	188	
12	IS	12:45	763.0849 mg	1.1525	19683.36	26.13	682	51639	Filled	167	
13	EC	9:14	763.9413 mg	.8564	19704.15	20.67	691	51697	Filled	210	
14	EPA	8:33	764.9068 mg	.9655	19727.52	23.37	689	51742	Filled	180	
15	LEA	8:50	765.9132 mg	1.0064	19751.79	24.27	691	51800	Filled	172	
16	LEA	8:25	766.8913 mg	.9781	19775.10	23.31	699	51855	Filled	175	
17	LEA	8:05	767.8702 mg	.9789	19798.75	23.65	690	51911	Filled	182	
18	LEA	9:20	768.9100 mg	1.0398	19823.99	25.24	687	51970	Filled	188	
19	LEA	8:32	769.8689 mg	.9589	19847.20	23.21	689	52025	Filled	162	
20	IS	10:45	770.9443 mg	1.0754	19873.04	25.96	693	52086	Filled	200	
21	TC	11:12	771.9678 mg	1.0235	19897.81	24.75	689	52145	Filled	181	
22	EPA	8:55	772.8703 mg	.9025 mg	19919.60	21.79	690	52196	Filled	164	Adj. Dr. pper
23	EPA	8:51	773.8614 mg	.9911 mg	19943.55	23.95	689	52252	Filled	181	
24	EPA	8:08	774.8243 mg	.9029 mg	19966.91	23.36	687	52307	Filled	179	
25	EPA	8:40	775.8455 mg	1.0212 mg	19991.52	24.61	692	52365	Filled	162	
26	IS	9:00	776.8565 mg	1.0110 mg	20015.97	24.45	689	52423	Filled	160	
27	IS	10:20	777.8945 mg	1.6380	20041.14	25.17	687	52483	Filled	161	
28	ADL	8:40	778.7436 mg	.8491	20066.95	20.81	680	52532	Filled	162	
29	LEA	10:40	779.8202 mg	1.0766	20087.98	26.03	689	52593	Filled	188	
30	LEA	8:25	780.7262 mg	.9060	20109.75	21.77	694	52644	Filled	182	3 seconds per Day
31	LEA	7:54	781.6877 mg	.9615	20133.22	23.47	683	52700	Filled	163	

Comr ts:



Phelan Pinon Hills Community Service District

MONTH: September  
 YEAR: 2011  
 SITE: W-14

Well Log

Hour read: 20133.22

Flow Meter Read: 781.6877 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	LEA	8:35	782.7074 mg	1.0197	2057.91	24.69	688	52758	Filled	155	
2	LEA	8:35	783.6953 mg	.9879	20181.89	28.98	687	52814	Filled	180	
3	EPA	10:00	784.6447 mg	.9494	20204.57	22.98	689	52869	Filled	158	
4	LEA	10:30	785.6552 mg	1.0105	20229.36	24.49	688	52926	Filled	162	1 Drip saw 3 seconds
5	EPA	11:04	786.4464 mg	.7902	20248.70	19.54	674	52972	Filled	168	Flushed B/C at WASH
6	LEA	8:15	787.3111 mg	.8657	20269.98	21.08	684	53022	Filled	198	
7	LEA	7:18	788.2497 mg	.9386	20293.05	23.07	678	53076	Filled	188	
8	LEA	9:02	789.3021 mg	1.0624	20318.77	25.72	682	53137	Filled	185	
9	US	8:50	790.2335 mg	.9314	20341.56	22.74	681	53190	Filled	162	
10	CC	8:50	791.2287 mg	.9146	20365.51	23.95	692	53247	Filled	198	
11	BMO	9:27	792.2329 mg	1.0048	20390.21	24.7	692	53305	Filled	170	
12	LEA	8:33	793.1723 mg	.9444	20413.24	23.03	683	53359	Filled	183	
13	CC	7:54	794.1026 mg	.9253	20435.73	22.49	686	53412	Filled	198	
14	CC	7:51	794.9829 mg	.8803	20456.93	21.2	692	53462	Filled	195	
15	LEA	9:18	796.0357 mg	1.0528	20482.35	25.42	690	53522	Filled	190	
16	LEA	8:53	797.0096 mg	.9739	20505.92	23.57	689	53578	Filled	174	
17	TS	10:00	797.9887 mg	.9791	20529.42	23.50	694	53634	Filled	185	
18	TC	11:38	799.0493 mg	1.0606	20557.08	25.66	688	53694	Filled	163	
19	LEA	8:43	799.8490 mg	.7997	20574.25	19.17	695	53740	Filled	163	Flushed B/C at WASH
20	LEA	8:54	800.8537 mg	1.0047	20598.45	24.2	692	53797	Filled	176	
21	CC	8:26	801.8367 mg	.983	20622.03	23.58	695	00041	Filled	157	? Ed. 17000 added
22	CC	8:20	802.7893 mg	.9526	20644.94	22.91	693	00095	Filled	160	Minimum 878
23	PA	10:10	803.8596 mg	1.0703	20670.82	25.88	689	00156	Filled	161	Run - 113
24	TS	10:00	804.8753 mg	1.0157	20694.70	23.88	709	00213	Filled	180	Run - 105
25	AK	9:20	805.9372 mg	.9619	20717.93	25.23	690	00268	Filled	180	
26	LEA	9:00	806.7787 mg	.9415	20740.64	22.71	691	00321	Filled	190	Run - 83
27	LEA	8:05	807.7378 mg	.9591	20763.71	23.07	693	00376	Filled	183	Run - 88
28	LEA	9:10	808.7842 mg	1.0464	20788.78	25.07	696	00435	Filled	167	Run - 93 B/C WASH
29	LEA	8:05	809.7385 mg	.9543	20811.72	22.94	693	00489	Filled	180	Run - 89
30	LEA	9:17	810.7976 mg	1.0591	20836.90	25.18	701	00549	Filled	180	Run - 93
31											

Com' ts:

Phelan Pinon Hills Community Service District  
 Well Log

Phelan Pinon Hills Community Service District  
 Well Log

Year: 2011  
 SITE: W-14

Last months Flow read: 810,797.6 mg      Hour read: 20836.90

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	12:17	811,943.1 mg	1,145.5	20863.89	26.99	707	80°	00613	Filled	160	1 pipe per 3 sec.
2	EPA	10:27	812,070.1 mg	927	20866.10	22.21	696	ON 70°	00665	Filled	173	Air Driller
3	LEA	8:05	813,773.4 mg	903.3	20907.71	21.61	697	83°	00716	Filled	170	
4	LEA	8:15	814,782.2 mg	1,008.8	20931.88	24.17	696	83°	00773	Filled	166	
5	LEA	8:25	815,736.6 mg	954.4	20954.65	22.77	699	73°	00827	Filled	162	
6	LEA	8:30	816,750.5 mg	1,013.9	20978.71	24.06	702	64°	00885	Filled	185	
7	RS	9:20	817,813.8 mg	1,063.3	21003.71	25.00	708	63°	00944	Filled	161	
8	CC	9:33	818,767.2 mg	953.4	21026.11	22.4	709	73°	00998	Filled	161	
9	CC	9:47	819,753.1 mg	988.9	21049.55	23.44	701	74°	1053	Filled	167	Blow out required
10	LEA	9:17	820,630.2 mg	877.1	21070.63	21.08	693	85°	01103	Filled	160	Air Compressor
11	LEA	8:47	821,534.3 mg	904.1	21092.09	21.46	702	82°	01154	Filled	169	
12	LEA	8:28	822,525.8 mg	991.5	21115.77	23.68	698	85°	01210	Filled	165	
13	LEA	8:25	823,523.1 mg	997.3	21139.72	23.95	694	86°	01267	Filled	173	
14	LEA	10:07	824,593.9 mg	1,070.8	21165.43	25.71	694	103°	01328	Filled	200	
15	TC	12:37	825,638.8 mg	1,044.9	21190.29	27.45	634	84°	1387	Filled	187	
16	JS	9:30	826,488.6 mg	849.8	21210.74	20.35	695	81°	1435	Filled	175	
17	LEA	9:32	827,460.2 mg	971.6	21233.99	23.25	694	82°	01490	Filled	173	
18	LEA	10:30	828,482.5 mg	1,022.3	21258.57	24.58	693	100°	01548	Filled	185	
19	LEA	8:13	829,394.3 mg	911.8	21280.29	21.72	700	84°	01599	Filled	166	
20	LEA	8:15	830,297.2 mg	902.9	21301.55	21.66	695	84°	01650	Filled	180	DRAINED WATER FROM AIR COMPRESSOR
21	CC	8:32	831,317.3 mg	1,015.1	21326.20	24.25	698	78°	1708	Filled	160	
22	CC	9:38	832,305.7 mg	993.4	21349.90	23.7	699	81°	1764	"	160	
23	AS	10:20	833,419.4 mg	1,115.7	21376.67	26.77	693	98°	1827	Fill	180	
24	LEA	8:35	834,273.9 mg	854.5	21396.88	20.21	705	84°	01875	Filled	166	
25	LEA	9:25	835,313.9 mg	1,040.0	21421.72	24.84	698	83°	01934	Filled	190	
26	LEA	9:50	836,294.3 mg	980.4	21445.13	23.41	698	84°	01989	Filled	153	
27	LEA	8:50	837,298.5 mg	1,004.2	21469.16	24.03	696	80°	02046	Filled	168	
28	LEA	9:05	838,317.5 mg	1,019.0	21493.35	24.19	702	81°	02103	Filled	158	
29	EPA	1:30	839,302.0 mg	984.5	21516.95	23.5	688	83°	02159	Filled	169	
30	LEA	7:55	839,999.3 mg	697.3	21533.42	16.57	701	84°	02198	Filled	168	
31	LEA	8:50	840,969.3 mg	970.0	21556.50	23.08	700	89°	02253	Filled	195	

Comments: 10/29 Pans EPA 4/EA

MC TH: November  
 YEAR: 2011  
 SITE: W-14

Phelan Pinon Hills Community Service District  
 Well Log

Hour read: 21556.50

840.9693 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:45	841.9305 mg	.9612	21579.28	22.78	703	84°	02307	Filled	160	Flushed Blow off at wash
2	LEA	9:35	842.9058 mg	.9753	21602.43	23.15	702	84°	02362	Filled	170	
3	LEA	9:10	843.8082 mg	.9924	21623.94	21.51	699	82°	02413	Filled	184	
4	LEA	9:20	844.7177 mg	.9198	21645.61	21.27	707	-	24611	Filled	198	
5	LEA	9:35	845.8219 mg	1.0947	21671.27	23.44	711	80°	2525	Filled	154	
6	LEA	10:35	846.6494 mg	.8275	21700.54	19.29	715	82°	2571	Filled	155	
7	LEA	9:25	847.3980 mg	.7486	21708.17	17.61	708	80°	02613	Filled	162	
8	LEA	8:00	848.1797 mg	.7817	21726.48	18.31	712	80°	02657	Filled	199	
9	LEA	9:00	849.0896 mg	.9099	21747.73	21.25	714	80°	02707	Filled	189	Flushed Blow off at wash
10	LEA	10:00	850.0198 mg	.9302	21769.31	21.58	718	80°	02759	Filled	170	
11	LEA	10:00	850.8056 mg	.7853	21787.73	18.42	711	80°	2803	Filled	170	
12	LEA	7:45	851.5443 mg	.7607	21805.31	17.58	721	80°	2845	Filled	145	
13	LEA	10:32	852.5019 mg	.9350	21827.22	21.91	711	-	2897	Filled	168	
14	LEA	10:10	853.3791 mg	.8772	21847.64	20.42	716	80°	02946	Filled	150	
15	LEA	7:40	854.1972 mg	.8181	21866.11	18.47	738	80°	02991	Filled	150	Flushed Blow off at wash
16	LEA	9:18	855.2246 mg	1.0374	21889.80	23.69	730	85°	03047	Filled	168	
17	LEA	9:05	856.1219 mg	.8873	21910.57	20.77	712	84°	03097	Filled	186	
18	LEA	3:00	857.3058 mg	1.0839	21936.01	25.44	710	83°	3459	Filled	156	
19	LEA	9:26	857.3543 mg	.6485	21951.12	15.71	715	85°	3194	Filled	163	
20	LEA	9:10	858.6457 mg	.7914	21969.78	16.64	706	82°	3239	Filled	149	
21	LEA	8:45	859.4718 mg	.8261	21989.05	19.27	714	80°	03284	Filled	150	Flushed Blow off at wash
22	LEA	8:20	860.3649 mg	.8931	22009.84	20.79	716	80°	03334	Filled	150	
23	LEA	7:50	861.2246 mg	.8597	22029.65	19.81	723	80°	03381	Filled	150	
24	LEA	9:50	862.1161 mg	.8915	22050.50	20.85	713	80°	03431	Filled	156	
25	LEA	10:25	863.9268 mg	.8107	22069.40	18.90	715	80°	03477	Filled	195	
26	EPA	9:31	863.8297 mg	.9029	22090.17	20.77	724	80°	03526	Filled	155	
27	EPA	9:27	864.7239 mg	.8942	22109.47	20.77	718	80°	03576	Filled	169	
28	LEA	8:30	865.6260 mg	.9021	22131.72	20.78	724	80°	03626	Filled	178	
29	LEA	9:10	866.5225 mg	.8965	22152.77	21.05	710	80°	03676	Filled	165	
30	LEA	9:25	867.4117 mg	.8892	22173.50	20.81	712	80°	03725	Filled	170	
31												

Comments: Required water leak in Chlorinator Re. 11/2

M<sup>TH</sup>: December  
 YEAR: 2011  
 SITE: W-14

Phelan Pinon Hills Community Service District  
 Well Log

Last months Flow read: 867.4117 mg  
 Hour read: 22.173.58

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:45	868.3424 000	.9307	22194.97	21.39	725	60°	03776	Filled	156	
2	CC	8:23	869.6740 mg	.7576	22212.13	17.46	717	71°	3818	"	160	
3	RS	8:45	870.0366	.5428	22230.14	21.76	722	70°	3870	Filled	150	
4	RS	9:45	870.9299 mg	.8931	22259.92	20.13	711	71°	3920	Filled	160	
5	RS	10:00	871.7317 mg	.8618	22275.32	20.40	704	60°	3968	Filled	154	
6	LEA	9:00	872.6522 mg	.8605	22295.45	20.13	712	60°	04016	Filled	163	
7	RS	8:30	873.5133 mg	.8611	22315.02	20.13	713	67°	4064	Filled	156	
8	LEA	8:50	874.3497 mg	.8364	22334.86	19.28	723	65°	04110	Filled	163	
9	LEA	8:40	875.2112 mg	.8615	22354.70	19.84	724	72°	04158	Filled	167	
10	JS	9:30	875.9240 mg	.7198	22371.17	16.47	721	62°	4198	Filled	155	
11	TC	11:30	876.8188 mg	.7848	22392.07	20.90	713	-	4248	Filled	156	
12	RS	10:00	877.6084 mg	.7876	22410.13	18.04	729	-	4291	Filled	155	Flushed B.O.
13	LEA	9:30	878.2667 mg	.6583	22425.49	15.36	714	53°	04328	Filled	153	well not running
14	RS	9:30	879.0937 mg	.8270	22444.57	19.05	722	-	4374	Filled	145	ALARM TESTED
15	LEA	9:25	879.8498 mg	.7561	22462.33	17.76	710	65°	04416	Filled	167	
16	RS	10:00	880.6386 mg	.7885	22480.57	18.24	721	64°	4440	Filled	150	
17	RS	9:15	881.3058 mg	.7270	22497.20	16.45	729	65°	4500	Filled	145	
18	RS	9:30	882.1488 mg	.7430	22515.10	17.9	725	61°	4543	Filled	150	
19	RS	9:30	883.0709 mg	.9221	22536.62	21.12	728	68°	4594	Filled	150	
20	LEA	8:45	883.7952 mg	.7243	22553.20	16.98	711	64°	04634	Filled	195	
21	RS	10:00	884.7397 mg	.9445	22574.61	21.61	728	150°	4684	Filled	150	
22	LEA	8:15	885.4378 mg	.6981	22591.10	16.29	714	50°	04725	Filled	170	
23	EPA	11:00	886.4251 mg	.9873	22613.65	22.55	730	68°	04779	Filled	156	
24	LEA	9:30	887.1977 mg	.7726	22631.53	17.88	720	60°	04822	Filled	182	
25	LEA	9:40	888.1095 mg	.9118	22652.69	21.16	718	60°	04873	Filled	158	
26	EPA	10:10	888.8576 mg	.7481	22670.68	17.39	717	64.3°	04915	Filled	174	
27	LEA	8:40	889.6865 mg	.7689	22687.93	17.85	718	64°	04959	Filled	163	
28	LEA	9:15	890.5013 mg	.8748	22708.13	20.2	722	60°	05007	Filled	150	
29	LEA	9:45	891.4721 mg	.9708	22730.46	22.33	725	63°	05060	Filled	150	
30	RS	9:30	892.1957 mg	.7131	22747.35	16.59	714	12.9°	5101	Filled	170	
31	Dimb	8:45	893.0481 mg	.6529	22766.85	19.5	725	-	5148	Filled	160	

Comments: