


# **Exhibit E**



# PUMP CHECK

Pumping Systems Analysts  
Hydraulic Test Report

Since 1958

(951) 684-9801 • Lic. 799498 • Fax (951) 684-2988

## CERTIFICATE OF ACCURACY

Customer: Phelan Pinon Hills CSD  
Location: 13150 263rd Street  
Identification: Well #14

Test Date: 10/09/2012

Meter Size: 12" Make: Siemens Mag Flo  
Meter No: 7ME652948102N297 Register: MG x .0001

### General Data

Meter read before test: 1156.0646 Meter read after test: 1156.0778

Pipe ID: 12 (Inch) Pipe area: 113.1 (sq.in.) Pressure: 151.0 (Lbs/sq.in.)

### Test Data

#### Test Before Inspection

| Test Equipment |           |            | Totalizer   |            | Volume |                    |                 | Metered GPM | Percent of Flow |
|----------------|-----------|------------|-------------|------------|--------|--------------------|-----------------|-------------|-----------------|
| Test No.       | Mano Read | Actual GPM | Second Read | First Read | Diff.  | Convert to Gallons | Time in Seconds |             |                 |
| 1              | 6.40      | 724        | 1156.0708   | 1156.0680  | 28     | 2,800              | 232.05          | 724         | 100.0%          |
| 2              | 6.35      | 718        | 1156.0743   | 1156.0711  | 32     | 3,200              | 267.67          | 717         | 99.9%           |
| 3              | 6.35      | 718        | 1156.0775   | 1156.0745  | 30     | 3,000              | 251.48          | 716         | 99.7%           |
| Avg.           |           | 720.1      |             |            |        |                    | Avg.            | 719.0       | 99.9%           |

### Remarks


34.29.290n117.39.656w  
PC 3235/SCE 32127

Approved \_\_\_\_\_

P.O. Box 5646, Riverside, California 92517

"Pump Testing, The Service That Pays For Itself"

001318



# PUMP CHECK

Pumping Systems Analysts  
Hydraulic Test Report

(951) 684-9801 • Lic. 799498 • Fax (951) 684-2988

## CERTIFICATE OF ACCURACY

Customer: Phelan Pinon Hills CSD  
Location: 13150 263rd Street  
Identification: Well #14

Test Date: 09/27/2010

Meter Size: 12" Make: Siemens  
Meter No: 7ME652948102N297 Register: Gal x 1 million

### General Data

Meter read before test: 462.084 Meter read after test: 462.1106

Pipe ID: 12 (Inch) Pipe area: 113.1 (sq.in.) Pressure: 145.0 (Lbs/sq.in.)

### Test Data

#### Test Before Inspection

| Test Equipment | Mano Read | Actual GPM | Totalizer   |            |        | Volume             |                 |             |                 |
|----------------|-----------|------------|-------------|------------|--------|--------------------|-----------------|-------------|-----------------|
|                |           |            | Second Read | First Read | Diff.  | Convert to Gallons | Time in Seconds | Metered GPM | Percent of Flow |
| 1              | 6.95      | 786        | 462.0936    | 462.09     | 0.004  | 4,000              | 306.66          | 783         | 99.6%           |
| 2              | 6.90      | 780        | 462.098     | 462.094    | 0.0041 | 4,100              | 316.22          | 778         | 99.7%           |
| 3              | 6.95      | 786        | 462.1023    | 462.098    | 0.004  | 4,000              | 305.93          | 784         | 99.8%           |
| Avg.           |           | 784.2      |             |            |        |                    | Avg.            | 781.7       | 99.7%           |

### Remarks

34.29.290n117.39.656w  
PC 3235/SCE 32127

Approved \_\_\_\_\_

P.O. Box 5646, Riverside, California 92517