

EXHIBIT A

EXHIBIT A

Phelan Pinon Hills Community Service District
 Well Log

Last months Flow read: 549.3816

Hour read: 10/19/11

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	12/16	10:45	520.7690	.8874	17755.75	19.64	753	37711	✓	154	
2	15	11:00	551.7749	1.0107	14811.15	32.4	752	39965	Filled	150	
3	15	8:30	552.1415 mg	.7119	14822.09	10.94	744	40000	Filled	144	
4	15	8:10	553.3467 mg	.8549	14846.17	19.08	747	40051	Filled	155	
5	15	9:45	554.4811 mg	1.1344	14871.72	25.41	738	40113	Filled	145	
6	15	11:00	555.6232 mg	1.1426	14896.93	25.15	757	40175	Filled	170	
7	LEA	8:45	556.5142 mg	.8905	14916.82	19.89	746	40222	Filled	157	
8	EPA	8:09	557.4372 mg	.923	14937.46	26.64	745	40272	Filled	160	
9	EPA	9:10	558.3107 mg	.8735	14957.28	19.82	755	40320	Filled	165	
10	15	9:00	559.2995	.9211	14979.25	21.95	751	40374	Filled	150	
11	15	9:40	560.2200 mg	.9202	14999.57	26.34	754	40423	Filled	150	
12	15	9:00	561.1813 mg	.9615	15020.95	21.38	749	40475	Filled	150	
13	EPA	7:57	562.0787 mg	.8974	15040.93	19.98	749	40524	Filled	166	
14	15	10:00	563.0620 mg	.9833	15062.87	21.91	747	40577	Filled	165	
15	15	11:45	563.9478 mg	.8854	15082.65	19.76	746	40625	Filled	154	
16	15	9:30	564.6441	.7463	15099.90	16.75	742	40666	Filled	170	
17	15	9:45	565.5474	.8533	15118.52	16.02	743	40773	Empty	170	
18	LEA	7:30	566.3612 mg	.8138	15136.73	18.23	744	40757	Filled	160	
19	15	8:00	567.3039 mg	.9427	15157.69	20.96	730	40808	Filled	155	
20	LEA	8:05	568.1777 mg	.8138	15177.17	19.48	748	40855	Filled	163	
21	15	8:45	569.0521 mg	.8744	15196.62	19.45	749	40903	Filled	160	
22	EPA	9:11	569.9340 mg	.8819	15216.32	19.70	746	40950	Filled	150	
23	LEA	7:45	570.7619 mg	.8279	15234.96	18.64	740	40995	Filled	155	
24	15	8:30	571.7219 mg	.9600	15254.52	21.36	749	41047	Filled	160	
25	15	8:10	572.662 mg	.9393	15277.24	20.92	748	41094	Filled	160	
26	15	9:00	573.5616 mg	1.004	15299.47	22.23	755	41152	Filled	155	
27	15	8:25	574.5032 mg	.8356	15316.35	18.68	738	41198	Filled	156	
28	15	5:52	575.0034 mg	.8602	15329.76	11.91	730	41226	Empty	149	
29	15	11:00	576.0465 mg	1.0421	15352.77	23.01	755	41282	Filled	150	
30	15	9:02	576.8293 mg	.7828	15370.40	17.63	740	41324	Filled	160	
31	15	8:35	577.6173 mg	.8686	15387.15	19.25	746	41371	Filled	160	

Comments:

Phelan Pinon Hills Community Service District

MONTH: FEBRUARY
YEAR: 2011
SITE: W-14

Well Log

Last months Flow read: 577.1473

Hour read: 15389.78

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	CEA	7:25	578.5704 mg	8731	15409.20	19.42	749	41419	Filled	162	
2	RS	7:55	579.4481 mg	8777	15428.83	19.63	745	41446	Filled	146	
3	RS	9:00	580.4857 mg	10676	15451.18	22.33	751	41520	Filled	158	
4	CEA	8:10	581.2720 mg	8163	15469.86	18.18	748	41565	Filled	158	
5	TS	9:30	582.2250 mg	991	15491.30	21.94	752	41618	Filled	160	
6	TC	9:25	583.2135 mg	9505	15512.57	21.27	744	41670	Filled	151	
7	RS	8:45	584.0667 mg	8532	15531.87	19.3	737	41716	Filled	152	
8	RS	8:15	585.0285 mg	5618	15553.18	21.31	752	41769	Filled	155	
9	RS	10:45	585.9487 mg	9702	15574.72	24.54	751	41820	Filled	155	Adj. out skip
10	RS	8:10	586.7661 mg	7674	15591.88	17.16	745	41862	Filled	150	
11	RS	9:00	587.6913 mg	7252	15612.52	20.64	747	41912	Filled	150	
12	RS	1:10	588.7553 mg	10642	15634.21	23.69	749	41970	Filled	171	
13	RS	11:50	589.6500 mg	8745	15654.52	22.11	741	42019	Filled	166	
14	RS	5:30	590.4272 mg	7772	15673.86	17.54	739	42061	Filled	150	
15	RS	1:15	591.5513 mg	11241	15699.04	25.18	744	42122	Filled	162	
16	RS	10:00	592.3614 mg	7531	15715.03	16.89	743	42167	Filled	190	
17	RS	8:45	593.2091 mg	9807	15735.97	19.94	752	42211	Filled	160	
18	RS	9:45	594.2491 mg	1091	15756.98	15.03	753	42267	Filled	180	
19	LEA	9:50	595.0993 mg	8532	15777.75	18.85	754	42313	Filled	160	
20	EPA	10:44	596.0197 mg	9204	15798.19	20.44	750	42363	Filled	148	
21	EPA	8:53	596.8258 mg	8061	15815.80	17.61	743	42406	Filled	151	
22	RS	9:00	597.7241 mg	9183	15835.32	20.32	761	42455	Filled	150	
23	RS	9:00	598.4627 mg	7184	15852.21	16.29	735	42493	Filled	156	
24	RS	7:15	599.3534 mg	8907	15871.79	19.58	758	42541	Filled	151	
25	RS	10:00	600.2822 mg	9288	15892.19	20.40	759	42591	Filled	150	
26	CC	11:59	601.3016 mg	1094	15914.68	22.49	755	42646	"	158	
27	CC	8:55	602.0792 mg	7676	15930.25	15.67	753	42684	"	155	
28	RS	9:00	602.9038 mg	9846	15952.31	21.96	747	42737	Filled	140	
29											
30											
31											

Comments:

MONTH: MARCH
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Last months Flow read: 602.9938 mg

Hour read: 15452.31

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	RS	8:00	603.9566 mg	9628	15973.66	21.35	752	42789	Filled	153	
2	RS	9:00	604.8962 mg	9376	15774.47	20.81	753	42861	Filled	150	
3	RS	9:15	605.8904 mg	9942	16086.22	21.75	762	42893	Filled	155	
4	EPA	8:00	606.7768 mg	8864	16035.72	19.5	758	42940	Filled	149	
5	TS	11:00	607.7376 mg	9688	16057.33	21.61	741	42942	Filled	160	
6	TC	9:40	608.5533 mg	8157	16075.54	18.21	746	43036	Filled	155	
7	RS	9:00	609.4393	8860	16095.19	19.64	752	43084	Filled	150	
8	RS	8:45	610.3610	9217	16115.65	20.47	750	43133	Filled	150	Adj. 1 drop
9	RS	8:50	611.2270 mg	8660	16134.98	19.83	747	43180	Filled	156	
10	RS	8:45	612.1406 mg	9134	16155.42	20.44	745	43230	Filled	151	
11	RS	9:30	613.1144 mg	10238	16178.37	22.95	744	43286	Filled	155	
12	RS	2:25	614.7682 mg	11038	16202.72	20.55	749	43345	Filled	174	
13	AL	11:15	615.0530	7646	16220.18	17.26	754	43388	Filled	175	
14	RS	10:00	615.8631	8101	16238.67	18.49	730	43432	Filled	150	
15	RS	10:30	616.7813	9182	16251.34	20.67	746	43483	Filled	155	
16	RS	9:30	617.7000	9187	16279.73	20.39	751	43532	Filled	150	
17	TC	7:40	618.4812	7812	16297.60	17.87	728	43575	Filled	148	
18	TS	8:15	619.4513 mg	9701	16319.39	21.79	742	43628	Filled	155	
19	LEA	10:15	620.4630 mg	10117	16341.97	22.58	747	43682	Filled	160	
20	EPA	10:44	621.4982 mg	16352	16369.86	22.89	754	43738	Filled	149	
21	AL	2:25	621.9715 mg	4733	16375.75	10.99	724	43764	Filled	150	
22	RS	8:20	622.8145 mg	6430	16394.82	19.07	737	43811	Filled	152	Adj. oil drop
23	RS	9:30	623.4560 mg	6415	16407.85	10.03	711	43846	Filled	171	
24	RS	8:45	624.2180 mg	7620	16424.79	16.94	750	43887	Filled	150	
25	RS	9:30	625.0374 mg	8194	16445.09	18.2	744	43937	Filled	163	
26	CL	8:33	625.8966 mg	8592	16463.96	18.87	759	43978	Filled	160	
27	TC	11:21	626.7790 mg	8824	16483.83	19.87	740	44027	Filled	158	
28	RS	7:00	627.5527 mg	7737	16501.06	17.23	748	44067	Filled	155	
29	RS	9:00	628.3844 mg	8319	16517.42	18.32	747	44114	Filled	157	
30	RS	9:00	629.3375 mg	9529	16540.59	20.17	757	44165	Filled	146	
31	RS	9:15	630.1858 mg	8483	16559.45	19.07	741	44211	Filled	148	

Comments:

Phelan Pinon Hills Community Service District

MONTH: APRIL
 YEAR: 2011
 SITE: W-14

Well Log

Last months Flow read: 630.1858 mg

Hour read: 16557.66

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	TS	8:05	631.1179 mg	9371	16500.63	20.17	741	44262	✓	160	
2	TS	6:35	631.8898 mg	7719	16598.98	17.85	720	64304	Filled	150	
3	TS	10:34	632.9736 mg	1,0338	16621.76	23.28	740	44361	Filled	150	
4	TS	9:00	633.8252 mg	19016	16442.05	20.29	741	44410	Filled	150	
5	TS	8:30	634.6822 mg	8570	16461.37	19.32	739	44456	Filled	150	
6	TS	8:40	635.5583 mg	18761	16481.71	20.34	718	44505	Filled	147	
7	TS	8:30	636.5120 mg	9537	16762.92	21.28	747	44558	Filled	186	
8	TS	9:15	637.4986 mg	9866	16724.98	21.33	748	44610	Filled	150	
9	TS	12:16	638.5191 mg	1,0205	16747.45	22.57	750	44665	Filled	173	
10	TS	10:34	639.5858 mg	5647	16767.08	19.13	741	44712	Filled	170	
11	TS	8:10	640.1471 mg	8133	16785.86	13.58	730	44757	Filled	149	
12	LEA	8:13	641.2105 MG	1,0134	16808.35	22.69	744	44812	Filled	162	
13	TS	7:06	642.2402 mg	1,0305	16831.44	23.09	744	44867	Filled	185	
14	TS	9:30	643.2194 mg	1,0584	16853.42	21.98	742	44920	Filled	163	
15	TS	9:00	644.2792 mg	7537	16873.11	19.62	730	44968	Filled	145	
16	EPA	9:55	644.9754 mg	9162	16893.92	20.88	731	45018	Filled	170	
17	LEA	8:55	645.9424 mg	9470	16915.51	21.59	731	45070	Filled	160	
18	TS	9:10	646.9196 mg	9772	16937.76	22.19	734	45122	Filled	150	
19	TS	11:40	647.8683 mg	9487	16957.26	21.5	735	45175	Filled	158	
20	TS	7:45	648.8757 mg	1,0054	16982.09	22.37	732	45230	Filled	150	
21	TS	12:50	650.0748 mg	1,2017	17007.45	27.27	732	45295	Filled	160	
22	TS	9:00	650.1716 mg	9028	17024.87	26.11	748	45374	Filled	149	
23	TS	10:30	652.0370 mg	1,8582	17053.73	24.16		45402	Filled	160	
24	TS	10:55	653.0210 mg	19832	17076.11	22.38	732	45456	Filled	160	
25	TS	3:00	654.2048 mg	1,1858	17102.91	26.8	732	45520	Filled	190	
26	TS	8:00	655.2740 mg	1,0675	17124.82	23.91	744	45573	Filled	155	
27	TS	9:00	655.9915 mg	1,7172	17143.20	14.28	730	45611	Filled	175	
28	TS	8:30	656.9887 mg	9974	17166.72	23.02	722	45673	Filled	149	
29	EPA	8:12	658.0004 MG	1,0115	17189.46	23.24	725	45727	Filled	156	
30	TS	9:30	659.0480 mg	1,0470	17213.55	23.89	731	45785	Filled	145	
31											

Comments:

Phelan Pinon Hills Community Service District

MONTH: MAY
YEAR: 2011
SITE: W-14

Well Log

Last months Flow read: 659.0480 mg

Hour read: 17213.35

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	J3	9:30	600.1285 mg	1.0805	17238.10	24.75	727	45844	Oil	175	
2	PS	10:30	661.2744 mg	1.1457	17264.54	26.44	722	45708	Oil	166	
3	PS	10:50	662.1783 mg	1.0391	17235.54	21.07	717	45552	Filled	166	
4	PS	8:15	663.1274 mg	1.9491	17300.42	23.12	715	46010	Filled	167	
5	PS	8:15	664.1477 mg	1.0207	17331.14	23.96	710	46062	Filled	165	
6	PS	8:45	665.2247 mg	1.0762	17340.71	25.07	714	46122	Filled	167	
7	PS	11:00	666.3254 mg	1.1607	17382.03	25.75	712	46187	Filled	166	
8	PS	10:45	667.3324 mg	1.007	17466.04	23.58	712	46245	Filled	159	Agouti dog
9	PS	8:30	668.2838 mg	1.9546	17467.35	21.91	724	46292	Filled	190	
10	PS	9:00	669.3231 mg	1.0553	17482.35	21.4	710	46363	Filled	190	
11	PS	8:30	670.3222 mg	1.1412	17475.67	23.32	714	46411	Filled	151	
12	PS	8:30	671.3661 mg	1.0432	17500.15	24.46	711	46472	Filled	165	
13	J3	9:00	672.4306 mg	1.0646	17524.82	24.67	719	46529	Filled	165	
14	EPA	9:15	673.4541 mg	1.0235	17548.73	23.91	713	46586	Filled	158	
15	LEA	9:40	674.5032 mg	1.0491	17573.03	24.3	720	46644	Filled	190	
16	PS	9:00	675.6767 mg	1.9730	17541.65	22.52	719	46692	Filled	170	
17	LEA	8:10	676.3995 mg	1.9283	17617.29	21.64	711	46749	Filled	168	
18	PS	9:10	677.3956 mg	1.9941	17640.83	23.24	714	46805	Filled	160	
19	PS	9:15	678.3229 mg	1.0056	17663.96	23.47	712	46860	Filled	157	
20	PS	10:15	679.4665 mg	1.0696	17683.31	24.91	714	46920	Filled	169	
21	PS	12:10	680.5377 mg	1.0712	17714.28	25.37	713	46980	Filled	196	
22	CR	9:19	681.3770 mg	1.8393	17734.26	19.92	702	47027	Filled	160	
23	PS	9:20	682.3412 mg	1.0643	17757.30	23.00	698	47031	Filled	172	
24	PS	8:25	683.2594 mg	1.9190	17786.65	21.45	713	47132	Filled	172	
25	PS	8:40	684.2328 mg	1.9734	17801.96	23.31	696	47188	Filled	160	
26	PS	9:20	685.2689 mg	1.0340	17826.91	24.53	703	47246	Filled	180	
27	J3	10:10	686.3122 mg	1.0453	17851.50	24.99	700	47305	Filled	170	
28	J3	10:20	687.2951 mg	1.9829	17875.04	23.54	696	47361	Filled	170	
29	J3	9:30	688.2435 mg	1.9484	17897.89	22.85	692	47415	Filled	175	
30	J3	8:04	689.1504 mg	1.9069	17919.52	21.63	693	47466	Filled	150	
31	PS	9:00	690.1686 mg	1.0714	17944.29	24.77	685	47525	Filled	162	

Comments:

Phelan Pinon Hills Community Service District

MONTH: JUNE
YEAR: 2011
SITE: W-14

Well Log

Last months Flow read:

Hour read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	8:45	LEA	691.1489 mg	.9809	17967.77	23.48	696	47580	Filled	177	
2	8:25	LEA	692.1456 mg	.9967	17991.48	23.71	701	47636	Filled	175	
3	8:45	RS	693.1652 mg	1.0191 ⁰⁰	18015.82	24.34	698	47694	Filled	162	
4	RS	10:15	694.2350 mg	1.0488 ⁰⁰	18041.24	25.44	701	47754	Filled	174	
5	RS	12:00	695.3885 mg	1.1535 ⁰⁰	18067.76	25.94	741	47816	Filled	141	
6	LEA	8:45	696.2926 mg	.9041	18087.77	20.57	733	47865	Filled	210	
7	LEA	9:00	697.3107 mg	1.0181	18112.07	24.3	698	47922	Filled	190	
8	LEA	8:35	698.3039 mg	.9932	18135.64	23.57	702	47978	Filled	205	
9	LEA	8:10	699.1476 mg	.9237	18155.97	20.33	691	48026	Filled	162	
10	LEA	8:30	700.0208 mg	.8727	18176.74	20.77	700	48075	Filled	165	
11	LEA	10:10	701.1076 mg	1.0873	18202.38	25.64	707	48136	Filled	160	
12	FPA	9:03	702.0807 mg	.9721	18225.38	23	705	48190	Filled	174	
13	LEA	8:10	703.0541 mg	.9724	18248.18	22.8	712	48245	Filled	175	
14	LEA	8:10	704.0668 mg	1.0127	18272.16	23.98	704	48301	Filled	170	
15	LEA	8:25	705.0856 mg	1.0128	18296.14	23.98	708	48358	Filled	162	Flush'd 30 PIE 702 Wash
16	LEA	7:50	706.0742 mg	.9886	18319.48	23.34	706	48414	Filled	170	
17	RS	8:15	707.1023 mg	1.0281	18343.92	24.44	701	48472	Filled	171	
18	CC	9:16	708.1641 mg	1.0618	18368.97	25.06	706	48531	Filled	155	
19	CC	9:51	709.2119 mg	1.0472	18393.57	24.57	710	48589	Filled	155	
20	LEA	10:08	710.1840 mg	.9727	18416.38	22.24	710	48644	Filled	175	
21	LEA	8:00	711.1077 mg	.9237	18438.28	21.9	703	48695	Filled	160	
22	LEA	8:10	712.1151 mg	1.0074	18462.39	24.11	696	48752	Filled	165	
23	LEA	8:40	713.1441 mg	1.029	18486.91	24.52	699	48810	Filled	172	
24	LEA	8:40	714.1591 mg	1.015	18510.91	24.0	705	48867	Filled	177	
25	RS	8:30	715.1667 mg	1.0011	18534.95	23.97	697	48924	Filled	175	
26	LEA	8:37	716.1576 mg	.9974	18558.86	23.98	693	48980	Filled	179	
27	LEA	8:10	717.1386 mg	.9810	18582.39	23.53	695	49035	Filled	194	
28	LEA	7:47	718.1277 mg	.9891	18606.02	23.63	698	49091	Filled	180	
29	LEA	8:45	719.1676 mg	1.0399	18630.00	23.98	723	49150	Filled	173	
30	LEA	8:40	720.1628 mg	.9952	18654.91	24.91	666	49207	Filled	175	
31											

Comments:

MONTH: July
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Hour read: 18654.91

Flow Meter Read 720.1628 MG

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	RS	9:30	721.2028	1.041	18774.72	24.84	693	49265	Filled	162	
2	RS	10:00	722.2028	1.0847	18798.64	25.21	694	49326	Filled	160	
3	LEA	9:25	723.2041	.9354	18774.55	24.41	695	49379	Filled	160	
4	LEA	9:57	724.2046	1.0205	18757.00	24.45	695	49436	Filled	163	FLUSHED @ 0.2 WASH
5	LEA	8:30	725.1764 MG	.9518	18774.72	22.72	698	49490	Filled	184	
6	LEA	8:25	726.1713 MG	.9949	18798.64	23.93	693	49547	Filled	166	
7	LEA	8:35	727.1917 MG	1.0204	18822.81	24.17	704	49604	Filled	184	
8	LEA	8:20	728.1726 MG	.9809	18846.58	23.77	688	49660	Filled	168	
9	LEA	9:10	729.2050 MG	1.0824	18871.43	24.85	693	49719	Filled	182	
10	EPA	7:49	730.1412 MG	.9392	18899.06	22.63	692	49772	Filled	164	Adj Dipper
11	LEA	8:50	731.1949 MG	1.0507	18919.09	25.03	700	49831	Filled	162	
12	LEA	7:57	732.1613 MG	.9663	18948.20	23.11	697	49886	Filled	164	
13	EPA	7:57	733.1680 MG	1.0068	18966.25	24.05	698	49943	Filled	176	
14	LEA	8:00	734.1370 MG	.969	18989.48	23.23	695	49998	Filled	160	
15	RS	8:40	735.1570 MG	1.0150	19013.75	23.77	697	50055	Filled	179	
16	RS	9:12	736.1703 MG	1.0133	19038.25	24.15	693	50113	Filled	190	
17	CC	9:07	737.1818 MG	1.0115	19062.15	23.9	705	50170	Filled	179	
18	LEA	9:20	738.2157 MG	1.0339	19086.85	24.2	712	50228	Filled	157	
19	LEA	8:10	739.1833 MG	.9676	19109.25	22.9	704	50282	Filled	178	Flushed Blow off
20	LEA	8:33	740.1822 MG	.9989	19132.75	23.5	700	50338	Filled	155	ext wash
21	LEA	9:32	741.2398 MG	1.0576	19157.73	24.98	706	50397	Filled	173	
22	LEA	8:42	742.2165 MG	.9767	19180.89	23.16	703	50452	Filled	155	
23	RS	10:10	743.2406 MG	1.0001	19204.50	23.67	704	50508	Filled	145	
24	CC	12:14	744.3484 MG	1.1238	19231.03	26.17	707	50571	Filled	175	
25	LEA	8:10	745.1263 MG	.7859	19250.06	19.03	688	50616	Filled	169	
26	LEA	8:10	746.1345 MG	1.0082	19274.06	24.00	700	50673	Filled	157	Flushed Blow off
27	LEA	8:30	747.1502 MG	1.0157	19298.38	24.32	696	50730	Filled	175	AT WASH
28	RS	11:30	748.2213 MG	1.1110	19325.30	25.15	687	50794	Filled	196	
29	RS	8:50	749.1469 MG	.8556	19346.87	21.34	692	50844	Filled	145	
30		12:30	750.2704 MG	1.1430	19374.30	27.13	690	50909	Filled	175	
31			751.1689	.8785	19395.80	21.56	679	50954	Filled	145	

Comr ts:

MONTH: August
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Hour read: 19395.86

Flow read: 751.689 mg

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Edison	Oil	PSI	Comments
1	LEA	8:38	752.0547 mg	8858	19417.03	21.17	697	51010	Filled	160	
2	LEA	8:20	752.9787 mg	8240	19489.26	22.23	693	51062	Filled	187	
3	LEA	10:15	754.0553 mg	1.0766	19465.19	25.98	692	51123	Filled	187	
4	LEA	8:08	754.9640 mg	9087	19487.07	21.88	692	51175	Filled	198	
5	LEA	8:40	755.9814 mg	1.0174	19511.58	21.51	690	51223	Filled	165	
6	EPA	7:57	756.9470 mg	9626	19534.99	23.41	687	51288	Filled	162	
7	LEA	9:55	758.0166 mg	1.0696	19560.86	25.87	689	51349	Filled	187	Flashed 80 @ WWSH 10 min
8	LEA	8:13	758.9431 mg	9265	19583.15	22.29	693	51402	Filled	162	
9	LEA	8:18	759.9435 mg	1.0004	19607.22	24.07	693	51459	Filled	167	
10	IS	8:30	760.9528 mg	1.0193	19631.77	24.55	685	51517	Filled	180	
11	LEA	8:25	761.9324 mg	9796	19655.35	23.58	692	51572	Filled	188	
12	OS	12:45	763.0849 mg	1.1825	19683.10	24.13	692	51637	Filled	167	
13	OC	9:14	763.9413 mg	8584	19704.15	24.67	691	51687	Filled	210	
14	EPA	8:33	764.9068 mg	9655	19727.52	23.37	689	51742	Filled	180	
15	LEA	8:50	765.9132 mg	1.0064	19751.79	24.27	691	51800	Filled	172	
16	LEA	8:25	766.8913 mg	9781	19775.10	23.31	699	51855	Filled	175	
17	LEA	8:05	767.8702 mg	9789	19798.75	23.65	690	51911	Filled	182	
18	LEA	9:20	768.9100 mg	1.0398	19823.99	25.24	687	51970	Filled	188	
19	LEA	8:32	769.8689 mg	9589	19847.20	23.31	689	52025	Filled	162	
20	JS	10:45	770.9443 mg	1.0754	19873.04	25.86	693	52086	Filled	200	
21	TC	11:12	771.9678 mg	1.0235	19897.81	24.75	689	52145	Filled	181	
22	EPA	8:55	772.8703 mg	9025 mg	19919.60	21.79	690	52196	Filled	169	Adj. Dripper
23	EPA	8:51	773.8664 mg	9911 mg	19943.55	23.95	689	52252	Filled	181	
24	EPA	8:08	774.8243 mg	9462 mg	19966.91	23.36	687	52307	Filled	179	
25	EPA	8:40	775.8455 mg	1.0212 mg	19991.52	24.61	692	52365	Filled	162	
26	OS	9:00	776.8545 mg	1.0110 mg	20015.97	24.45	689	52423	Filled	160	
27	OS	10:20	777.8945 mg	1.6380	20041.14	23.17	687	52483	Filled	161	
28	AL	8:40	778.7436 mg	6491	20066.195	26.91	690	52532	Filled	162	
29	LEA	10:40	779.8202 mg	1.0766	20087.98	26.03	689	52593	Filled	188	
30	LEA	8:25	780.7262 mg	9060	20109.75	21.77	694	52644	Filled	182	3 seconds per drip
31	LEA	7:54	781.6877 mg	9615	20133.22	23.47	683	52700	Filled	163	

Comr ts:

MONTH: September
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Hour read: 20133.22

Flow Meter Read: 781.6877 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	LEA	8:35	782.7074 mg	1.0197	20157.91	24.69	688	52758	Filled	155	
2	LEA	8:35	783.6953 mg	.9879	20181.89	23.98	687	52814	Filled	180	
3	EPA	10:00	784.6447 mg	.9494	20204.87	22.98	689	52869	Filled	158	
4	LEA	10:30	785.6552 mg	1.0105	20229.36	24.49	688	52926	Filled	162	1 Drop ev. 3 seconds
5	EPA	11:04	786.4454 mg	.7902	20248.90	19.54	674	52972	Filled	168	Flushed 3/002 WASH
6	LEA	8:15	787.3111 mg	.8657	20269.98	21.08	684	53022	Filled	198	
7	LEA	7:18	788.2497 mg	.9386	20293.05	23.07	678	53076	Filled	188	
8	LEA	9:02	789.2021 mg	1.0624	20318.77	25.72	682	53137	Filled	185	
9	LEA	8:50	790.2325 mg	.9314	20341.50	22.77	681	53190	Filled	162	
10	CC	8:50	791.2287 mg	.9446	20365.51	23.95	672	53247	Filled	198	
11	BAMU	9:27	792.2329 mg	1.0048	20390.21	24.7	672	53305	Filled	170	
12	LEA	8:33	793.1723 mg	.9444	20413.24	23.03	683	53359	Filled	183	
13	CC	7:54	794.1026 mg	.9253	20435.73	22.49	686	53412	Filled	198	
14	CC	7:51	794.9829 mg	.8803	20456.83	21.2	692	53462	Filled	195	
15	LEA	9:18	796.0357 mg	1.0528	20482.35	25.42	680	53522	Filled	190	
16	LEA	8:53	797.0096 mg	.9739	20505.92	23.57	689	53578	Filled	174	
17	CS	9:00	797.9887 mg	.9791	20529.42	23.50	694	53634	Filled	185	
18	TC	11:38	799.0493 mg	1.0606	20555.08	25.66	688	53694	Filled	163	
19	LEA	8:43	799.8490 mg	.7997	20574.25	19.17	695	53740	Filled	163	Flushed B/D at WASH
20	LEA	8:54	800.8537 mg	1.0047	20598.45	24.2	692	53797	Filled	176	
21	CC	8:26	801.8367 mg	.9483	20622.85	23.58	695	00041	Filled	157	7 Edison meters
22	CC	8:20	802.7893 mg	.9526	20644.94	22.91	693	00095	Filled	166	Edison mtr 87.8'
23	RS	10:10	803.8596 mg	1.0703	20670.82	25.88	689	00156	Filled	161	Run - 113'
24	RS	10:00	804.8753 mg	1.0157	20694.70	23.88	709	00213	Filled	180	Run - 105'
25	CC	9:20	805.8372 mg	.9619	20717.93	25.23	690	00268	Filled	180	
26	LEA	9:00	806.7787 mg	.9415	20740.64	22.71	691	00321	Filled	190	Run - 83°
27	LEA	8:05	807.7378 mg	.9591	20763.71	23.07	693	00376	Filled	183	Run - 88°
28	LEA	9:10	808.7842 mg	1.0464	20789.78	25.07	696	00435	Filled	167	Run - 93° Flushed B/D WASH
29	LEA	8:05	809.7385 mg	.9543	20811.72	22.94	693	00489	Filled	180	Run - 89°
30	LEA	9:17	810.7976 mg	1.0591	20836.90	25.18	701	00549	Filled	180	Run - 93°
31											

Com' 115:

WTH: October
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Last months Flow read: 810,797.6 mg Hour read: 20836.90

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	12:17	811,943.1 mg	1,145.5	20863.89	26.99	707	100° ON	00613	Filled	160	1 drop per 3 sec. 22. Disappe
2	EPA	10:27	812,870.1 mg	927	20886.10	27.21	696	100° ON	00665	Filled	173	
3	LEA	8:05	813,773.4 mg	903.3	20910.71	27.61	697	83° ON	00716	Filled	170	
4	LEA	8:15	814,782.2 mg	1,008.8	20931.88	27.17	696	83° ON	00773	Filled	166	
5	LEA	8:25	815,736.6 mg	954.4	20954.65	27.77	699	73° ON	00827	Filled	162	
6	LEA	8:30	816,750.5 mg	1,013.9	20978.71	27.06	702	67° ON	00885	Filled	185	
7	LEA	9:20	817,813.8 mg	1,067.3	21003.71	25.00	708	63° ON	00944	Filled	161	
8	LEA	9:33	818,767.2 mg	953.4	21026.11	27.4	709	73° ON	00998	Filled	161	
9	LEA	9:47	819,753.1 mg	988.9	21049.55	27.44	701	73° ON	01053	Filled	167	detained to report #12 compressor
10	LEA	9:17	820,630.2 mg	877.1	21070.63	27.08	693	85° ON	01103	Filled	160	
11	LEA	8:47	821,534.3 mg	904.1	21092.09	27.46	702	82° ON	01154	Filled	169	
12	LEA	8:28	822,525.8 mg	991.5	21115.77	27.68	698	85° ON	01210	Filled	165	
13	LEA	8:25	823,523.1 mg	997.3	21139.72	27.95	694	86° ON	01267	Filled	173	Flush blow off @ WASH
14	LEA	10:07	824,583.9 mg	1,070.8	21165.43	25.71	694	103° ON	01328	Filled	200	
15	LEA	12:37	825,638.8 mg	1,044.9	21190.29	27.45	697	87° ON	01387	Filled	187	
16	LEA	9:30	826,488.6 mg	849.8	21210.74	27.35	695	87° ON	01435	Filled	175	
17	LEA	9:32	827,460.2 mg	971.6	21233.99	25.25	694	95° ON	01490	Filled	173	
18	LEA	10:30	828,482.5 mg	1,022.3	21258.57	24.58	693	103° ON	01548	Filled	185	
19	LEA	8:13	829,394.3 mg	911.8	21280.29	27.12	700	87° ON	01599	Filled	166	
20	LEA	8:15	830,297.2 mg	902.9	21301.95	27.66	695	79° ON	01650	Filled	180	detained maintenance from #12 compressor
21	LEA	8:37	831,312.3 mg	1,015.1	21326.20	27.25	698	78° ON	01708	Filled	160	
22	LEA	9:38	832,305.7 mg	993.4	21349.90	27.7	699	78° ON	01764	Filled	160	
23	LEA	10:18	833,419.4 mg	1,115.7	21376.67	27.77	693	90° ON	01827	Filled	180	
24	LEA	8:35	834,273.9 mg	854.5	21396.88	27.01	705	94° ON	01875	Filled	166	
25	LEA	9:25	835,313.9 mg	1,040.0	21421.72	27.84	698	83° ON	01934	Filled	190	
26	LEA	9:50	836,294.3 mg	980.4	21445.13	27.41	698	87° ON	01989	Filled	153	
27	LEA	8:50	837,278.5 mg	1,004.2	21469.16	27.03	696	76° ON	02046	Filled	168	
28	LEA	9:05	838,317.5 mg	1,019.0	21493.35	27.19	702	81° ON	02103	Filled	158	
29	EPA	1:30	839,303.0 mg	984.5	21516.75	27.5	698	84° ON	02159	Filled	169	
30	LEA	7:55	839,999.3 mg	697.3	21533.42	16.57	701	72° ON	02198	Filled	168	
31	LEA	8:50	840,969.3 mg	970.0	21556.50	27.08	700	87° ON	02253	Filled	195	

Comments: 10/29 Pms EPA+LEA

MONTH: November
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Hour read: 21556.50

Last months Flow read: 840,969.3 mg

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:45	841,930.5 mg	.9612	21579.28	22.78	703	87°	02307	Filled	160	Flushed Blow off at Wash
2	LEA	9:35	842,905.8 mg	.9753	21602.43	23.15	702	87°	02362	Filled	170	
3	LEA	9:10	843,808.2 mg	.9024	21623.94	21.51	699	86°	02413	Filled	184	
4	ES	9:20	844,777 mg	.9190	21645.41	21.47	707	-	24444	Filled	199	
5	ES	9:35	845,821.9 mg	1.0947	21671.27	23.44	711	80°	7525	Filled	157	
6	ES	9:55	846,649.4 mg	.8275	21690.54	19.29	715	82°	2571	Filled	155	
7	LEA	9:25	847,398.0 mg	.7486	21708.17	17.61	708	80°	02613	Filled	162	
8	LEA	8:00	848,179.7 mg	.7817	21726.48	18.31	712	80°	02657	Filled	199	Flushed Blow off at Wash
9	LEA	9:00	849,089.6 mg	.9089	21747.73	21.25	714	80°	02707	Filled	189	
10	LEA	10:00	850,019.8 mg	.9302	21769.31	21.58	718	74°	02759	Filled	170	
11	ES	10:00	850,005.6 mg	.7853	21787.73	18.42	711	80°	2803	Filled	170	
12	ES	7:45	851,504.3 mg	.7607	21805.31	17.58	721	84°	2845	Filled	145	
13	ES	10:32	852,501.9 mg	.9356	21827.22	21.91	711	-	2897	Filled	168	
14	LEA	10:10	853,379.1 mg	.8772	21847.64	20.42	716	80°	02946	Filled	150	
15	LEA	7:40	854,197.2 mg	.8181	21866.11	18.47	738	80°	02991	Filled	150	Flushed Blow off at Wash
16	LEA	9:18	855,224.6 mg	1.0374	21889.80	23.69	730	85°	03047	Filled	168	
17	LEA	9:05	856,121.9 mg	.8873	21910.57	20.17	712	90°	03097	Filled	186	
18	ES	3:00	857,205.8 mg	1.0839	21936.01	25.44	710	83°	454	Filled	156	
19	ES	9:26	857,354.3 mg	.6435	21951.12	15.11	715	85°	3194	Filled	163	
20	ES	9:10	858,645.7 mg	.7914	21969.78	16.64	706	82°	3239	Filled	163	
21	LEA	8:45	859,478 mg	.8261	21989.05	19.27	714	80°	03284	Filled	150	Flushed Blow off at Wash
22	LEA	8:20	860,364.9 mg	.8931	22009.84	20.79	716	80°	03334	Filled	150	
23	LEA	7:50	861,224.6 mg	.8597	22029.65	19.81	723	80°	03381	Filled	150	
24	LEA	9:50	862,116.1 mg	.8915	22050.50	20.85	713	80°	03431	Filled	156	
25	LEA	10:25	863,926.8 mg	.8107	22069.40	18.90	715	85°	03477	Filled	195	
26	CPA	9:31	863,829.7 mg	.9029	22090.17	20.17	724	82°	03526	Filled	155	
27	CPA	9:27	864,723.9 mg	.8947	22109.94	20.77	718	80°	03576	Filled	169	
28	LEA	8:30	865,626.0 mg	.9021	22131.72	20.78	724	87°	03626	Filled	178	
29	LEA	9:10	866,522.5 mg	.8965	22152.77	21.05	710	72°	03676	Filled	165	
30	LEA	9:25	867,417 mg	.8892	22173.58	20.81	712	80°	03725	Filled	170	
31												

Comments: Repaired water leak in Chlorinator Bui 1/2

M TH: December
 YEAR: 2011
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Last months Flow read: 867.4117 mg

Hour read: 22:17:3.58

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:45	868.3424 mg	.9307	22194.97	21.39	725	60°	03776	Filled	156	
2	CC	8:23	869.0740 mg	.7516	22212.43	17.46	717	71°	3818	"	160	
3	CS	8:45	870.0326 mg	.9428	22230.19	21.76	722	70°	3870	Filled	150	
4	CS	9:45	870.7297 mg	.8731	22259.13	16.13	711	71°	3930	Filled	150	
5	CS	10:00	871.7917 mg	.8618	22275.37	16.47	704	60°	3988	Filled	154	
6	LEA	9:00	872.6522 mg	.8605	22295.45	20.13	712	64°	04016	Filled	163	
7	CS	8:38	873.5133 mg	.8611	22315.07	20.13	713	60°	4064	Filled	156	
8	LEA	8:50	874.3497 mg	.8964	22334.86	19.28	723	65°	04110	Filled	163	
9	LEA	8:40	875.2112 mg	.8615	22354.70	19.84	724	72°	04158	Filled	167	
10	CS	9:30	875.9240 mg	.7138	22371.17	16.47	721	61°	4198	Filled	155	
11	TC	11:30	876.8188 mg	.8148	22392.07	20.90	713	-	4298	Filled	156	
12	CS	10:00	877.6084 mg	.7876	22410.13	19.02	729	-	4271	Filled	155	Flushed B.O.
13	LEA	9:30	878.2667 mg	.6583	22425.49	15.36	714	53°	04328	Filled	153	well not running
14	CS	9:30	879.0737 mg	.8270	22444.57	19.02	722	-	4314	Filled	145	ALARM TESTED
15	LEA	9:25	879.8498 mg	.7561	22462.33	17.76	710	65°	04416	Filled	167	
16	CS	10:00	880.6386 mg	.7888	22480.57	18.24	721	64°	4460	Filled	150	
17	CS	9:15	881.3458 mg	.7210	22497.20	16.65	729	50°	4500	Filled	165	
18	CS	9:31	882.1488 mg	.7530	22515.70	17.9	729	61°	4543	Filled	180	
19	CS	9:30	883.0709 mg	.9221	22536.22	21.12	728	68°	4594	Filled	150	
20	LEA	8:45	883.7952 mg	.7243	22553.20	16.88	711	64°	04634	Filled	195	
21	CS	10:00	884.7397 mg	.9445	22574.31	21.61	728	150°	4488	Filled	150	
22	LEA	8:15	885.4378 mg	.6981	22591.10	16.29	714	50°	04725	Filled	170	
23	EPA	11:06	886.4251 mg	.9873	22613.65	22.55	730	68°	04779	Filled	150	
24	LEA	9:30	887.1977 mg	.7726	22631.53	17.88	720	60°	04822	Filled	182	
25	LEA	9:40	888.1095 mg	.9118	22652.69	21.16	718	78°	04873	Filled	158	
26	EPA	10:10	888.8576 mg	.7481	22670.68	17.39	717	64.3°	04915	Filled	174	
27	LEA	8:40	889.6865 mg	.7689	22687.93	17.85	718	64°	04958	Filled	163	
28	LEA	9:15	890.5013 mg	.8748	22708.13	20.2	722	65°	05007	Filled	150	
29	LEA	9:45	891.4721 mg	.9708	22730.46	22.33	725	68°	05060	Filled	150	
30	CS	9:30	892.1957 mg	.7231	22747.35	16.57	714	12.1°	5101	Filled	170	
31	CS	8:45	893.0481 mg	.8529	22766.85	19.6	728	-	5148	Filled	160	

Comments:

NTH: January
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Hour read: 22166.55

Flow Meter Read 893.0481

Last months Flow read: 893.0481

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	CC	9:08	893.9562 mg	.9081	22788.91	21.36	709	71.6	5199	Colled	150	
2	CC	8:49	894.7153 mg	.7591	22865.55	17.52	722	63.1	5241	Colled	169	
3	CS	9:10	895.5587 mg	.9434	22855.22	11.53	720	-	5283	Colled	165	
4	CS	10:00	896.5207 mg	.9620	22845.42	12.32	722	127	5340	Colled	181	
5	LEA	8:05	897.2557 mg	.7350	22864.61	17.13	715	80	05283	Filled	176	
6	LEA	8:50	898.1209 mg	.8652	22884.67	26.86	719	73	05431	Filled	169	
7	CS	9:40	898.9864 mg	.8655	22904.59	19.92	704	82	5479	Filled	185	
8	CC	12:24	899.7919 mg	.8055	22923.45	16.86	746	-	5524	Filled	158	
9	CS	10:00	900.5335 mg	.7416	22940.66	17.23	717	84	5566	Colled	186	
10	LEA	8:25	901.2148 mg	.6813	22956.48	15.8	719	89	05604	Filled	170	
11	CS	8:40	901.9570 mg	.7422	22973.82	17.34	713	127	5646	Filled	170	
12	LEA	8:30	902.8050 mg	.8480	22993.47	19.65	719	87	05693	Filled	150	
13	CS	10:30	903.6487 mg	.5437	23013.16	19.15	714	-	5740	Colled	160	
14	CS	10:30	904.4864 mg	.8277	23031.77	18.54	725	-	5787	Colled	168	
15	LEA	11:00	905.3314 mg	.8783	23050.86	26.45	705	87	5834	Filled	140	
16	LEA	9:20	905.5428 mg	.6084	23066.59	14.52	705	70	5848	Colled	170	
17	CS	9:00	906.7878 mg	.3450	23086.53	19.65	717	116	5916	Filled	90	
18	CS	11:00	907.5106 mg	.7228	23105.10	16.89	710	-	5956	Colled	190	Flushed Blow off at 10:55
19	LEA	10:30	908.1433 mg	.6327	23117.83	14.71	717	80	05992	Filled	158	
20	LEA	8:45	908.9076 mg	.7643	23135.79	17.96	709	89	06035	Filled	188	
21	LEA	8:56	909.8604 mg	.9528	23157.53	21.74	730	84	06087	Filled	150	
22	LEA	9:20	910.6093 mg	.7489	23175.12	17.59	710	85	06130	Filled	176	
23	CS	9:00	911.2994 mg	.6461	23191.82	13.8	697	113	6169	Colled	140	
24	LEA	8:05	912.1615 mg	.8621	23211.53	19.91	722	80	06217	Filled	150	
25	CS	10:00	912.0639 mg	.9024	23232.21	20.68	727	112	6247	Filled	157	
26	LEA	8:30	913.8854 mg	.8215	23250.66	18.45	742	80	06311	Filled	157	
27	LEA	9:00	914.6114 mg	.7260	23267.37	16.91	715	80	6352	Colled	197	
28	CC	8:54	915.4019 mg	.7905	23285.85	18.26	722	71.2	6396	Filled	151	
29	CC	10:24	916.2269 mg	.8240	23305.21	19.38	709	-	6443	Filled	160	Alarm is popping system 1/2 hr. then
30	CS	1:45	917.0884 mg	.8415	23325.32	26.11	714	140	6491	Filled	157	
31	LEA	8:55	917.8512 mg	.7628	23343.15	17.83	713	80	06534	Filled	183	

Comments:

VTH: February
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Hour read: 23343.15

Flow Meter Read 917.8512 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	BS	10:00	918.7418 mg	.8996 mg	23343.99	23.84	712	-	1584	Filled	179	
2	LEA	8:10	919.4518 mg	.7100 mg	23380.58	16.59	713	52°	06624	Filled	189	
3	LEA	8:40	920.3715 mg	.9197 mg	23401.94	21.36	718	63°	06675	Filled	163	
4	BS	11:30	921.1817 mg	.8107 mg	23421.04	19.1	707	50°	07121	Filled	170	
5	TC	11:12	922.0285 mg	1.8468 mg	23490.69	19.65	718	-	6769	Filled	165	
6	LEA	8:30	922.7023 mg	.6738 mg	23456.74	16.05	700	50°	06807	Filled	156	
7	LEA	8:10	923.3867 mg	.6844 mg	23473.12	16.38	696	58°	06846	Filled	195	
8	BS	9:30	924.2723 mg	.8836 mg	23494.97	21.3	715	127°	6877	Filled	190	
9	CC	8:14	925.1350 mg	.8547 mg	23513.83	18.91	716	68°	6944	Filled	167	
10	CC	8:20	926.0197 mg	.8847 mg	23534.34	20.51	719	71°	6994	Filled	195	
11	BS	11:20	926.7205 mg	.7005 mg	23555.47	21.09	712	110°	7004	Filled	169	
12	BS	11:00	927.6473 mg	.7468 mg	23572.03	17.5	711	50°	7026	Empty	190	
13	LEA	8:10	928.3723 mg	.7050 mg	23589.58	16.65	706	61°	07126	Filled	158	
14	LEA	8:45	929.1036 mg	.7313 mg	23607.29	17.71	688	48°	07169	Filled	180	Flushed Blowoff/wash
15	LEA	8:25	929.9460 mg	.8424 mg	23626.31	19.02	738	52°	07215	Filled	180	
16	BS	11:00	930.5633 mg	.7173 mg	23643.87	17.00	700	-	7254	Filled	160	
17	LEA	9:10	931.3963 mg	.7330 mg	23660.11	16.72	731	72°	07296	Filled	162	
18	LEA	8:50	932.2956 mg	.8993 mg	23680.25	20.14	744	70°	07345	Filled	152	
19	LEA	9:00	933.0363 mg	.7407 mg	23697.33	17.08	723	off	07387	Filled	145	
20	EPA	11:02	933.9786 mg	.9423 mg	23719.72	21.29	734	94°	07438	Filled	162	
21	LEA	8:30	934.7620 mg	.7834 mg	23726.59	17.87	731	60°	07481	Filled	190	
22	BS	1:00	935.8826 mg	1.1200 mg	23761.99	25.4	735	74°	7542	Filled	200	
23	BS	10:30	936.6842 mg	.8016 mg	23780.29	18.3	730	63°	7587	Filled	195	
24	BS	10:50	937.4703 mg	.9411 mg	23802.20	21.91	720	138°	7439	Filled	175	
25	CC	9:32	938.4975 mg	.8677 mg	23820.34	20.14	718	41	7687	Filled	183	
26	CC	9:16	939.4530 mg	.9555 mg	23844.49	22.15	696	60	7741	Filled	151	
27	LEA	9:40	940.5074 mg	1.0644 mg	23868.94	24.45	719	60	07799	Filled	150	
28	CC	8:30	941.3766 mg	.8692 mg	23888.87	19.93	727	54°	7847	Filled	190	
29	LEA	8:27	942.1091 mg	.7325 mg	23905.99	17.12	713	53°	07888	Filled	150	
30												
31												

Comments:

MONTH: Mar. 2012
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Hour read: 23905.99

Flow Meter Read 942.1091 mg

Last months Flow read: 942.1091 mg

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:08	943.0555	9464	23927.54	21.55	732	55.9	7940	Filled	155	
2	LEA	9:00	944.0224 mg	9669	23949.71	22.17	710	57°	7993	Filled	188	
3	LEA	10:30	945.0410 mg	9986	23972.64	22.93	726	62°	8048	Filled	177	
4	LEA	11:06	946.0339 mg	1,0149	23996.02	23.38	723	—	8104	Filled	190	
5	LEA	8:30	946.8420 mg	8,8061	24014.86	18.84	713	78°	8149	Filled	200	
6	LEA	8:45	947.7535 mg	9,9115	24035.98	21.12	696	74.3°	8199	Filled	160	
7	LEA	9:12	948.7287 mg	9,752	24058.37	22.39	726	57.3°	8253	Filled	156	
8	LEA	10:01	949.6326 mg	9,537	24080.61	22.34	715	63.5°	8306	Filled	187	
9	LEA	8:53	950.5557 mg	8,731	24100.96	20.35	715	76.4°	8354	Filled	158	
10	LEA	12:00	951.4372 mg	1,0755	24116.06	25.1	714	—	8411	Filled	140	
11	LEA	14:31	952.9407 mg	8,295	24145.53	19.41	710	73°	8466	Filled	160	
12	LEA	10:19	953.3596 mg	8,984	24166.41	20.88	718	74°	8510	Filled	200	
13	LEA	8:01	954.1730 mg	8,154	24185.52	19.11	709	64.1°	8556	Filled	150	
14	LEA	9:10	955.1367 mg	9,637	24207.76	22.24	722	68.8°	8609	Filled	159	
15	LEA	9:00	956.0332 mg	8,985	24228.16	20.84	717	72.6°	8658	Filled	154	
16	LEA	9:00	956.9242 mg	9,01	24244.45	20.35	720	72.2°	8703	Filled	150	
17	LEA	10:08	957.9864 mg	1,0522	24273.02	24.21	724	77°	8762	Filled	110	
18	LEA	10:25	958.8236 mg	8,372	24292.72	19.66	732	78°	8811	Filled	161	
19	LEA	8:30	959.1354 mg	8,118	24311.29	18.12	727	78°	8862	Filled	160	
20	LEA	8:50	960.6000 mg	9,646	24333.39	21.95	732	68°	8909	Filled	164	
21	LEA	8:30	961.4649 mg	8,649	24353.10	19.71	731	67°	8956	Filled	155	
22	LEA	8:30	962.3817 mg	9,168	24374.32	21.22	720	67°	8907	Filled	165	
23	LEA	8:45	963.2746 mg	8,929	24394.49	20	744	71°	8956	Filled	168	
24	LEA	10:50	964.2259 mg	8,552	24417.09	22.1	720	—	9009	Filled	145	
25	LEA	12:30	965.2086 mg	8,880	24431.71	22.62	720	—	9063	Filled	149	
26	LEA	9:00	965.9543 mg	9,477	24456.88	17.17	726	68°	9104	Filled	154	Flushed Bleed off/flush
27	LEA	9:20	966.7592 mg	8,049	24475.39	18.51	725	70°	9149	Filled	150	
28	LEA	8:35	967.5539 mg	7,947	24492.45	18.06	733	72°	9192	Filled	172	
29	LEA	8:25	968.4375 mg	8,836	24513.76	20.31	725	68°	9241	Filled	156	
30	LEA	8:50	969.3964 mg	9,589	24535.84	22.08	724	67°	9293	Filled	166	
31	LEA	10:15	970.2755 mg	8,791	24556.46	20.56	712	67°	9342	Filled	170	

Comments:

MONTH: April
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Flow read: 970.2755 mg Hour read: 24556.40

Rate	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	JS	10:30	971.1058 mg	970.7 mg	24575.55	19.15	722	64	09483	Filled	185	
2	LEA	8:40	971.9796 mg	8138 mg	24595.87	20.32	717	62	09537	Filled	152	
3	LEA	8:30	972.9201 mg	9405 mg	24617.63	21.76	720	72	09589	Filled	153	SWEEPPOINT Chlorinator On
4	LEA	8:10	973.8402 mg	9201 mg	24639.25	21.62	709	60	09640	Filled	155	
5	LEA	8:05	974.8285 mg	9883 mg	24662.22	22.97	717	57	09695	Filled	152	
6	LEA	8:17	975.7696 mg	9141 mg	24684.23	22.01	713	52.1	9747	Filled	149	
7	LEA	8:09	976.6795 mg	9107 mg	24705.38	21.15	717	68	9747	Filled	156	
8	LEA	10:00	977.6411 mg	9689 mg	24727.83	22.45	714	75	9851	Filled	176	
9	LEA	9:30	978.6580 mg	10169 mg	24751.51	23.68	716	80	09908	Filled	158	Flushed Blow off
10	LEA	8:30	979.6291 mg	9711 mg	24774.07	22.56	717	74	09961	Filled	156	
11	LEA	8:25	980.6629 mg	10338 mg	24797.98	23.91	721	60	10018	Filled	163	
12	LEA	8:25	981.5896 mg	9267 mg	24819.30	21.32	724	60	10069	Filled	150	
13	LEA	8:30	982.5240 mg	9344 mg	24840.91	21.61	721	65	10120	Filled	155	WEEPPOINT
14	LEA	10:55	983.5031 mg	9791 mg	24863.69	22.78	716	60	10175	Filled	163	
15	LEA	10:58	984.4619 mg	9589 mg	24885.56	21.87	731	64	10227	Filled	167	
16	LEA	8:55	985.2624 mg	8005 mg	24904.15	18.59	718	72	10271	Filled	175	
17	LEA	9:55	986.2151 mg	9527 mg	24926.35	22.20	715	82	10324	Filled	162	
18	LEA	9:05	987.1380 mg	9179 mg	24947.66	21.31	718	60	10375	Filled	181	
19	LEA	8:05	987.9854 mg	8524 mg	24967.98	20.32	699	82.4	10423	Filled	158	
20	LEA	9:27	988.9443 mg	10089 mg	24991.53	23.55	714	84	10479	Filled	160	
21	LEA	9:25	990.0211 mg	10263 mg	25015.62	24.09	710	92	10536	Filled	160	
22	LEA	8:31	990.9967 mg	9756 mg	25038.73	23.11	703	—	10591	Filled	150	703 GPM
23	AM	9:30	992.0444 mg	10477 mg	25063.70	24.97	699	88	10650	Filled	185	
24	AM	8:10	993.0173 mg	9724 mg	25086.50	22.8	711	82	10704	Filled	155	
25	AM	8:50	994.0667 mg	10434 mg	25111.10	24.6	707	84	10762	Filled	162	
26	AM	8:28	994.9580 mg	8913 mg	25132.80	21.7	689	71.6	10812	Filled	151	
27	AM	8:54	996.0086 mg	10500 mg	25157.19	24.39	719	60	10870	Filled	150	
28	AM	10:00	997.0604 mg	10518 mg	25181.96	24.77	707	60	10929	Filled	172	
29	AM	9:20	998.0191 mg	9587 mg	25204.23	22.77	707	—	10983	Filled	150	
30	AM	8:43	998.9944 mg	9753 mg	25227.90	23.17	702	89.9	11037	Filled	182	
31												

Comments:

MONTH: May
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Hour read: 2527.790

Last months Flow read: 998.9944 mg

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	NEA	8:24	999.9978 mg	1.0034	2525.53	23.63	708	83.9	11073	Filled	155	OUT TO WEEDS
2	LEA	8:17	1000.9006 mg	1.0038 mg	2532.84	21.3	706	76.0	11194	Filled	160	
3	LEA	8:03	1001.9024 mg	1.0016	2529.623	23.59	714	73.8	11199	Filled	150	
4	LEA	8:53	1002.8961 mg	0.9989 mg	2539.48	23.25	705	86	11254	Filled	175	
5	LEA	1:02	1004.9011 mg	1.1150	2536.67	20.17	147	~	11317	Filled	162	
6	LEA	8:17	1005.8958 mg	1.0035	2543.61	21.54	666	76.0	11386	Filled	165	
7	DS	9:30	1005.8631 mg	0.9892 mg	25390.64	23.70	675	89.0	11422	Filled	200	
8	LEA	8:20	1006.8312 mg	0.9651 mg	25473.57	22.93	704	85.0	11476	Filled	171	Flushed filter
9	LEA	8:12	1007.7721 mg	0.9409 mg	25436.22	22.65	692	91.0	11530	Filled	171	
10	LEA	8:17	1008.7463 mg	0.8741 mg	25413.86	21.94	688	85.4	11580	Filled	172	
11	LEA	8:30	1009.6772 mg	1.0304 mg	25481.61	24.21	709	87.0	11637	Filled	174	
12	LEA	8:22	1010.6370 mg	1.0591 mg	25607.99	23.16	690	87.0	11691	Filled	183	
13	LEA	10:05	1011.7384 mg	1.1014 mg	25531.19	26.4	695	96.0	11754	Filled	161	
14	LEA	8:30	1012.7725 mg	1.0401 mg	25556.65	25.46	681	95.0	11813	Filled	180	
15	LEA	8:08	1013.6307 mg	0.8521 mg	25577.19	20.54	691	88.0	11862	Filled	165	
16	LEA	8:50	1014.6486 mg	1.0180 mg	25601.93	24.74	686	92.0	11919	Filled	166	
17	LEA	8:15	1015.6209 mg	0.9723 mg	25625.33	23.40	693	89.0	11974	Filled	163	
18	NEA	8:24	1016.5780 mg	0.9571 mg	25648.37	23.04	692	85.0	12029	Filled	155	Pressure switch 7300
19	LEA	9:22	1017.5915 mg	1.0135 mg	25673.07	24.7	684	85.4	12087	Filled	160	
20	LEA	8:20	1018.5722 mg	1.0207 mg	25698.10	23.09	688	~	12141	Filled	176	
21	LEA	8:47	1019.5341 mg	0.9919 mg	25720.46	24.36	679	96.0	12198	Filled	167	repaired moisture sensor
22	LEA	8:10	1020.4915 mg	0.8571 mg	25743.79	23.33	684	89.0	12253	Filled	172	LEAKY COMPRESSOR OIL
23	LEA	8:15	1021.4839 mg	0.9924 mg	25767.95	24.16	685	82.0	12309	Filled	172	
24	LEA	8:02	1022.4576 mg	0.9757 mg	25791.23	23.68	685	81.5	12365	Filled	170	
25	LEA	8:05	1023.4154 mg	0.9578 mg	25814.94	23.31	685	88.0	12420	Filled	190	FAIL TO START
26	LEA	8:45	1024.4681 mg	1.0527 mg	25840.28	25.76	694	90.0	12479	Filled	181	RESET
27	LEA	10:00	1025.5677 mg	1.0996 mg	25866.58	26.38	695	~	12547	Filled	168	
28	LEA	8:08	1026.5368 mg	0.9825 mg	25892.11	23.83	696	88.0	12615	Filled	171	
29	LEA	9:15	1027.4378 mg	0.9659 mg	25911.89	23.45	686	91.0	12648	Filled	172	
30	LEA	8:40	1028.4125 mg	0.9747 mg	25935.35	23.46	692	90.0	12704	Filled	190	
31	LEA	8:10	1029.3768 mg	0.9390 mg	25958.84	23.49	666	95.0	12759	Filled	161	

Comments: PM Done 5/8/12, 05:55, LEA 5/25 needed

MONTH: June
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Last months Flow read: 1059.3768 MG

Hour read: 25958.84

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	NP	8:54	1030.3983 MG	1.0215 MG	25983.60	24.76	688	104.3	12817	Filled	165	
2	NP	9:05	1031.4177 MG	1.0184 MG	26034.39	24.76	684	104.3	12934	Filled	161	FAIL TO START DAY/UP FAIL
3	NP	11:10	1032.4935 MG	1.0184 MG	26055.06	24.76	684	104.3	13042	Filled	189	FLUSHED BLOW OFF & WASH
4	LEA	8:25	1033.3418 MG	1.0184 MG	26079.23	24.17	684	104.3	13146	Filled	151	
5	LEA	9:05	1034.3309 MG	1.0184 MG	26123.57	25.03	689	104.3	13252	Filled	182	
6	LEA	8:05	1035.0834 MG	1.0184 MG	26170.97	26.28	684	104.3	13369	Filled	178	
7	LEA	9:05	1036.1187 MG	1.0184 MG	26218.78	21.53	673	104.3	13485	Filled	170	
8	LEA	9:10	1037.0572 MG	1.0184 MG	26266.79	24.12	691	104.3	13599	Filled	180	
9	JS	10:00	1038.0568 MG	1.0184 MG	26315.25	24.53	704	104.3	13717	Filled	185	
10	LEA	10:45	1039.1401 MG	1.0184 MG	26361.91	22.12	674	104.3	13822	Filled	169	
11	LEA	8:20	1040.0099 MG	1.0184 MG	26410.92	23.32	699	104.3	13935	Filled	156	
12	LEA	8:15	1040.9810 MG	1.0184 MG	26458.88	24.10	692	104.3	14050	Filled	160	
13	LEA	8:20	1041.9805 MG	1.0184 MG	26507.95	24.05	687	104.3	14168	Filled	157	
14	CC	8:54	1042.9715 MG	1.0184 MG	26557.33	21.69	692	104.3	14278	Filled	160	
15	CC	8:50	1044.0079 MG	1.0184 MG	26602.51	23.33	689	104.3	14387	Filled	155	
16	CC	9:24	1045.0355 MG	1.0184 MG	26646.80	24.84	697	104.3	14498	Filled	167	
17	CC	7:25	1045.9285 MG	1.0184 MG	26691.68	24.86	696	104.3	14612	Filled	156	
18	LEA	9:10	1047.0020 MG	1.0184 MG	26735.60	25.69	696	104.3	14728	Filled	160	
19	LEA	8:25	1047.9803 MG	1.0184 MG	26780.92	23.32	699	104.3	14842	Filled	169	
20	LEA	8:20	1048.9913 MG	1.0184 MG	26826.78	23.86	706	104.3	14957	Filled	156	
21	LEA	8:25	1049.9922 MG	1.0184 MG	26873.90	25.02	695	104.3	15071	Filled	160	
22	LEA	9:25	1051.0349 MG	1.0184 MG	26921.90	25.02	695	104.3	15185	Filled	167	
23	JS	10:40	1052.0261 MG	1.0184 MG	26970.67	24.69	690	104.3	15300	Filled	160	
24	LEA	9:40	1053.0483 MG	1.0184 MG	27019.33	21.69	692	104.3	15415	Filled	157	
25	LEA	7:50	1053.9490 MG	1.0184 MG	27068.80	24.84	690	104.3	15529	Filled	160	
26	LEA	8:40	1054.9787 MG	1.0184 MG	27118.54	24.84	690	104.3	15643	Filled	160	
27	CC	8:06	1055.9434 MG	1.0184 MG	27168.51	23.33	689	104.3	15757	Filled	155	
28	CC	8:20	1056.9513 MG	1.0184 MG	27218.80	24.84	697	104.3	15871	Filled	167	
29	CC	9:16	1057.9717 MG	1.0184 MG	27269.18	24.86	698	104.3	15985	Filled	156	
30	CC	10:20	1058.9816 MG	1.0184 MG	27319.81	25.15	705	104.3	16100	Filled	156	
31												

Comments: 6-5 Replaced a times (only) 6-22 Failed outside. Date 125° inside 97° to 104°

11/17
 11/17
 11/17

MONTH: July
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Last months Flow read: 1059.056 / Hour read: 26676.81

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	CC	12:00	1066.1340	1077.0	26702.71	23.5	704	95°	14808	Empty	155	
2	CC	9:10	1061.0239	830.9	26723.55	21.34	698	88°	14558	Filled	155	
3	CC	8:19	1061.9813	957.4	26746.69	23.14	690	87.8°	14611	Filled	152	
4	LEA	9:21	1063.0238	1042.6	26771.53	24.89	698	96.8°	14671	Filled	150	GREASED MOTOR PERMANENT COMPRESSOR MOISTURE
5	LEA	8:43	1063.9987	974.8	26794.93	23.35	696	98.7°	14726	Filled	150	
6	LEA	11:20	1065.278	1129.1	26821.57	26.64	706	101°	14789	Filled	149	
7	CC	12:43	1066.1619	1031.1	26840.85	25.23	682	101.9°	14848	Filled	162	
8	CC	10:07	1067.0391	877.2	26868.36	21.51	680	93.5°	14898	Filled	161	
9	LEA	8:58	1067.9657	926.6	26891.18	22.82	677	103°	14952	Filled	161	
10	LEA	8:05	1068.9151	949.4	26914.33	23.15	684	107°	15006	Filled	162	
11	LEA	8:25	1069.9004	985.3	26938.67	24.34	675	107°	15063	Filled	161	
12	LEA	7:50	1070.7699	869.5	26960.09	21.42	671	100°	15113	Filled	166	
13	CC	8:08	1071.7017	933.3	26983.31	23.27	667	83.3°	15167	Filled	160	
14	CC	10:19	1072.7830	1081.8	27004.54	26.18	659	98.6°	15228	Filled	160	
15	CC	8:25	1073.6734	890.4	27031.70	22.16	664	—	15280	Filled	162	
16	LEA	9:35	1074.6862	1012.8	27056.84	25.14	671	90°	15338	Filled	188	
17	NB	8:51	1075.6257	939.5	27080.10	23.26	673	103.4°	15393	Filled	184	
18	LEA	8:55	1076.5026	876.9	27101.98	21.88	668	90°	15444	Filled	168	Flushed BO at
19	LEA	8:50	1077.4585	955.9	27125.86	23.88	667	92°	15499	Filled	163	WASH
20	LEA	9:20	1078.4439	989.1	27150.33	24.47	671	97°	15556	Filled	180	
21	SS	11:05	1079.4604	1016.5	27175.63	25.31	669	103°	15615	Filled	190	
22	SS	11:00	1080.4317	971.3	27199.73	24.09	671	112°	15677	Filled	148	
23	CC	8:50	1081.3369	908.2	27221.87	22.15	681	97.4°	15723	Empty	161	
24	LEA	8:25	1082.2952	958.3	27245.46	23.59	677	91°	15778	Filled	166	
25	CC	8:10	1083.2535	953.3	27269.31	23.55	670	95°	15831	Filled	155	
26	LEA	8:50	1084.2559	1002.1	27293.87	24.56	680	93°	15892	Filled	162	
27	CC	8:51	1085.2344	978.5	27317.94	24.07	678	83.1°	15948	Filled	161	
28	CC	11:00	1086.1528	922.1	27340.73	22.79	674	90°	16001	Filled	157	
29	PS	12:00	1087.2192	1062.4	27364.76	24.83	680	100°	16062	Empty	200	
30	LEA	8:20	1088.0408	821.6	27387.14	20.38	672	98°	16110	Filled	188	
31	LEA	9:05	1088.9661	925.3	27410.36	23.22	664	95°	16164	Filled	161	

Comments: 7-5 Flushed BO at wash 7:30
 7-20 Flushed BO at wash 7:30

MONTH: August
 YEAR: 2012
 SITE: W-14

Community Service District
 Pheasant Pinon Hills
 Well Log

Last months Flow read: 1088.9661 MG
 Hour read: 27410.36

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:43	1089.9291 MG	9680 MG	27433.95	23.59	680	92°	16219	Filled	162	
2	LEA	8:30	1090.8956 MG	9665 MG	27452.72	23.77	678	90°	16275	Filled	154	
3	LEA	9:05	1091.9013 MG	10057 MG	27482.31	24.59	682	103°	16332	Filled	168	
4	JS	10:00	1092.9043 MG	10037 MG	27506.39	24.08	694	123°	16389	Filled	165	
5	EPA	10:21	1093.8265 MG	0.9222 MG	27528.66	22.27	690	120°	16448	Filled	160	
6	LEA	9:10	1094.7517 MG	0.9252 MG	27551.39	22.73	678	106°	16495	Filled	185	FLUSH 15.0. 05 025K
7	LEA	8:10	1095.6736 MG	0.9219 MG	27574.38	22.99	668	102.5°	16549	Filled	156	
8	LEA	8:40	1096.6247 MG	1.0011 MG	27598.89	24.51	681	109°	16606	Filled	162	
9	LEA	8:25	1097.6334 MG	0.9587 MG	27622.64	23.75	673	109°	16662	Filled	185	
10	LEA	8:20	1098.6421 MG	0.9625 MG	27647.15	24.14	670	104.7°	16720	Filled	160	
11	JS	11:10	1099.6451 MG	1.0594 MG	27673.52	26.13	679	154°	16781	Filled	161	
12	EPA	9:46	1100.5793 MG	0.8242 MG	27699.27	20.69	664	160°	16829	Filled	160	
13	LEA	8:40	1101.4152 MG	0.8959 MG	27716.25	21.98	679	107°	16880	Filled	155	1504 162°
14	LEA	8:55	1102.3800 MG	0.9648 MG	27739.97	23.72	678	104°	16936	Filled	170	1504 162°
15	LC	8:50	1103.3535 MG	0.9735 MG	27763.90	23.93	678	—	16992	Filled	162	
16	JS	8:30	1104.3266 MG	0.9617 MG	27787.36	23.46	717	103°	17047	Filled	175	
17	LEA	9:10	1105.3151 MG	0.9999 MG	27811.66	24.30	686	108°	17104	Filled	157	
18	JS	8:30	1106.2734 MG	0.9023 MG	27833.43	21.77	690	101°	17156	Filled	150	
19	JS	1:53	1107.3167 MG	1.0997 MG	27859.91	26.48	671	101°	17218	Filled	180	
20	LEA	9:00	1108.2832 MG	0.9765 MG	27883.35	23.44	694	105°	17273	Filled	158	FLUSH 30.05 025K
21	LEA	9:40	1109.2904 MG	0.9972 MG	27907.55	24.2	687	108°	17320	Filled	161	
22	LEA	9:25	1110.2717 MG	0.9813 MG	27931.32	23.97	688	104°	17386	Filled	158	
23	LEA	8:40	1111.2215 MG	0.9498 MG	27954.51	23.19	683	104°	17440	Filled	163	
24	LEA	9:00	1112.2215 MG	1.0000 MG	27978.66	24.15	690	109°	17497	Filled	159	
25	LC	10:15	1113.2454 MG	1.0737 MG	28002.75	15.57	699	—	17558	Filled	157	
26	LEA	10:50	1114.2699 MG	1.0415 MG	28028.60	24.93	692	107°	17615	Filled	155	
27	LEA	8:57	1115.1910 MG	0.8311 MG	28049.95	21.27	690	109°	17665	Filled	155	
28	LEA	8:27	1116.1124 MG	0.9914 MG	28072.16	22.21	691	109°	17718	Filled	158	
29	LEA	8:35	1117.1168 MG	1.0044 MG	28096.28	24.12	694	107°	17774	Filled	157	
30	LEA	8:20	1118.0926 MG	0.9758 MG	28120.01	23.73	685	101°	17830	Filled	158	
31	LEA	9:35	1119.0161 MG	0.9835 MG	28142.25	22.24	692	104°	17883	Filled	165	

Comments:

MC Th: September
 YEAR: 2012
 SITE: W-14

Phelan Pinon Hills Community Service District
 Well Log

Last months Flow read: 1119.616 MG
 Hour read: 28142.25

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	TS	11:40	1170.0271 MG	1.011 MG	28166.31	24.02	700	167°	17940	✓	180	
2	LEA	9:16	1120.9089 MG	8816 MG	28187.82	21.51	682	166°	17970		165	
3	CC	8:25	1121.7917 MG	8335 MG	28209.53	21.76	677	161°	18041	Filled	155	
4	LEA	9:10	1122.8807 MG	10290 MG	28231.35	24.77	692	163°	18099	Filled	160	
5	LEA	8:55	1123.7964 MG	9757 MG	28258.08	23.73	685	160°	18155	Filled	154	FUSFSA 20 ST WASH
6	LEA	9:55	1124.8000 MG	10536 MG	28282.48	24.40	686	161°	18212	Filled	162	
7	CC	8:55	1125.6807 MG	8307 MG	28302.76	20.28	683	163°	18260	Filled	156	
8	CC	9:09	1126.6088 MG	9173 MG	28320.37	23.56	692	166°	18316	Filled	148	
9	CC	8:54	1127.5317 MG	9729 MG	28349.00	22.68	714	165°	18371	Filled	167	36PM 677
10	LEA	8:45	1128.4576 MG	8759 MG	28371.79	22.79	646	161°	18422	Filled	158	
11	LEA	10:15	1129.4671 MG	1.0095 MG	28396.31	24.52	686	160°	18480	Filled	150	
12	LEA	8:20	1130.3452 MG	8841 MG	28427.78	21.46	687	161°	18530	Filled	155	
13	LEA	9:35	1131.3938 MG	1.0426 MG	28443.01	25.23	689	162°	18590	Filled	160	
14	LEA	8:35	1132.3443 MG	69505 MG	28466.02	28.01	688	160°	18644	Filled	170	
15	TS	11:00	1133.3547 MG	1.0104 MG	28490.43	24.41	689	155°	18701	Filled	165	
16	TS	9:16	1134.3159 MG	19612 MG	28513.71	23.28	688	160°	18750	Filled	170	
17	LEA	9:20	1135.2392 MG	9833 MG	28536.40	22.69	678	off	18809	Filled	148	
18	LEA	8:00	1136.0911 MG	8519 MG	28557.16	20.70	686	160°	18858	Filled	161	
19	CC	8:30	1137.0923 MG	1.0017 MG	28581.68	24.58	679	161°	18916	Filled	160	
20	LEA	8:40	1138.0781 MG	9853 MG	28605.82	24.14	680	165°	18972	Filled	170	
21	CC	8:55	1139.0601 MG	9932 MG	28630.01	24.19	677	167°	19029	Filled	167	
22	TS	11:00	1140.1033 MG	10423 MG	28655.15	25.38	680	160°	19088	Filled	166	
23	TS	10:20	1141.0403 MG	9370 MG	28678.09	22.9	681	162°	19141	Filled	167	
24	LEA	8:10	1141.8916 MG	8593 MG	28699.29	21.8	676	161°	19191	Filled	155	
25	MI	1:15	1143.0173 MG	1.2077 MG	28718.36	29.57	692	169°	19260	Filled	165	
26	TS	9:00	1143.8889 MG	7816 MG	28747.41	19.05	683	160°	19305	Filled	165	
27	TC	8:40	1144.8678 MG	9789 MG	28771.14	23.73	687	160°	19361	Filled	156	
28	LEA	9:25	1145.8484 MG	9806 MG	28794.82	23.68	690	160°	19416	Filled	170	Smart 202 shed
29	LEA	12:25	1146.9549 MG	1.1065 MG	28821.25	26.43	698	166°	19479	Filled	160	
30	LEA	9:03	1147.7936 MG	8384 MG	28847.79	20.54	681	161°	19527	Filled	169	
31												

Comments:

Phelan Pinon Hills Community Service District

MONTH: October
 YEAR: 2012
 SITE: W-14

Well Log

Last months Flow read: 1147.7936 MG
 Hour read: 28841.79

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	9:20	1148.6661 MG	.8725 MG	28863.06	21.27	684	82°	19577	Filled	164	
2	LEA	9:46	1149.6389 MG	.9728 MG	28866.65	23.54	687	83°	19632	Filled	146	
3	LEA	10:25	1150.6034 MG	.9645 MG	28909.74	23.09	696	84°	19687	Filled	156	
4	LEA	8:55	1151.5482 MG	.9448 MG	28932.19	22.45	701	84°	19740	Filled	155	
5	CC	8:33	1152.4820 MG	.9253 MG	28954.46	22.27	699	79.7	19793	Filled	155	
6	CC	8:10	1153.4363 MG	.9343 MG	28977.31	22.85	696	—	19847	Filled	161	
7	CC	8:55	1154.4580 MG	1.0217 MG	29001.53	24.22	703	77.5	19904	Filled	157	
8	LEA	8:55	1155.4157 MG	.9577 MG	29024.67	23.14	690	84°	19959	Filled	155	
9	CC	7:50	1155.9794 MG	.5637 MG	29058.43	13.76	682	—	19991	Filled	155	
10	LEA	8:35	1156.9838 MG	1.0044 MG	29068.53	24.10	695	81°	20048	Filled	170	3.00 PM
11	LEA	8:30	1157.9706 MG	.9868 MG	29086.39	23.86	689	82°	20104	Filled	154	18000' - 58 Resid
12	LEA	9:10	1158.9917 MG	1.0211 MG	29110.38	23.99	709	82°	20161	Filled	198	28
13	TS	9:45	1159.9447 MG	.9577 MG	29133.29	22.91	693	82°	20216	Filled	155	1844
14	TS	10:00	1160.8755 MG	.9308 MG	29155.79	22.50	687	80°	20269	Filled	160	
15	LEA	8:35	1161.8162 MG	.9407 MG	29178.46	22.67	693	84°	20322	Filled	175	
16	CC	8:10	1162.7283 MG	.9096 MG	29200.69	22.23	682	74.6	20375	Filled	156	
17	LEA	8:40	1163.7574 MG	1.0316 MG	29225.20	24.51	701	80.0	20433	Filled	172	
18	CC	10:15	1164.8690 MG	1.0616 MG	29250.78	25.54	697	85.1	20493	Filled	165	
19	CC	9:30	1165.7906 MG	.9696 MG	29274.04	23.26	695	82.7°	20548	Filled	165	
20	CC	9:53	1166.7554 MG	.9583 MG	29297.14	23.17	692	84.7°	20602	Filled	156	
21	LEA	10:27	1167.8187 MG	1.0635 MG	29322.02	24.88	712	74°	20661	Filled	175	
22	LEA	8:40	1168.6925 MG	.8738 MG	29347.88	20.86	698	75°	20711	Filled	165	
23	NB	7:50	1169.6868 MG	.9943 MG	29366.02	23.14	716	80°	20766	Filled	172	
24	LEA	8:35	1170.6454 MG	.9586 MG	29388.62	22.60	707	83°	20820	Filled	159	
25	LEA	10:25	1171.5815 MG	.9361 MG	29410.74	22.12	705	78°	20872	Filled	200	
26	LEA	8:50	1172.4230 MG	.8415 MG	29430.85	20.11	697	80°	20920	Filled	172	
27	TS	9:45	1173.2310 MG	.8080 MG	29450.48	19.63	686	80°	20967	Filled	180	
28	LEA	7:25	1174.1433 MG	.7103 MG	29472.19	21.81	697	81°	21019	Filled	165	
29	LEA	9:00	1174.9308 MG	.7875 MG	29491.65	19.36	678	86°	21064	Filled	195	
30	LEA	8:45	1175.5135 MG	.5827 MG	29505.49	13.84	702	81°	21098	Filled	165	
31	LEA	8:50	1176.3602 MG	.8467 MG	29525.85	20.36	693	88°	21146	Filled	173	

Comments: 10/9 Pump Check & Flow Test, 10/15 Blow out casing motor assembly

Phelan Pinon Hills Community Service District

MONTH: November
 YEAR: 2012
 SITE: W-14

Well Log

Last months Flow read: 1176.3602 MG Hour read: 29525.85

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:15	1177.1877 MG	8215 MG	29546.21	20.36	677	82°	21194	Filled	172	
2	CC	10:03	1173.0450 MG	8575 MG	29566.90	20.49	671	68°	21043	Filled	175	
3	AMC	10:25	1178.3735 MG	7985 MG	29586.11	19.21	692	64°	21287	Filled	175	
4	CC	9:22	1179.6696 MG	8261 MG	29606.21	20.1	685	80°	21330	Filled	160	
5	LEA	8:35	1180.5891 MG	9195 MG	29627.99	21.78	704	83°	21388	Filled	160	
6	CC	9:14	1181.6271 MG	1035 MG	29654.54	24.55	703	OFF	21446	Filled	145	well off
7	LEA	8:00	1182.3047 MG	680 MG	29669.01	16.47	689	off	21485	Filled	150	well off
8	CC	8:25	1183.2354 MG	9107 MG	29691.08	22.07	705	92°	21538	Filled	160	
9	LEA	9:50	1184.1702 MG	9348 MG	29713.26	22.18	702	88°	21590	Filled	152	
10	NB	9:00	1185.0268 MG	8566 MG	29733.61	20.35	702	89°	21639	Filled	165	
11	TC	8:02	1185.9134 MG	1886 MG	29754.57	20.96	704	—	21689	Filled	153	
12	CS	5:30	1186.8408 MG	9274 MG	29776.40	21.91	705	—	21741	Filled	150	
13	LEA	9:20	1187.7847 MG	9439 MG	29798.93	22.45	701	88°	21794	Filled	188	
14	LEA	9:05	1188.6928 MG	9681 MG	29820.32	21.39	708	88°	21845	Filled	155	
15	CC	4:25	1189.6400 MG	9472 MG	29841.71	22.39	705	87°	21818	Filled	152	
16	CC	8:39	1190.6275 MG	9875 MG	29865.88	23.17	710	85°	21954	Filled	165	
17	CS	11:15	1191.6986 MG	10711 MG	29890.83	24.95	715	ON	22013	Filled	190	
18	CC	9:00	1192.6656 MG	9427 MG	29913.26	22.43	713	86°	22067	Filled	150	
19	CC	8:50	1193.5276 MG	8626 MG	29933.73	20.47	702	84°	22115	Filled	156	
20	CC	8:24	1194.5172 MG	9896 MG	29956.89	23.14	713	83°	22171	Filled	150	
21	LEA	9:05	1195.4847 MG	9675 MG	29979.48	22.61	713	87°	22225	Filled	160	
22	JS	9:05	1196.4973 MG	10176 MG	30003.34	23.86	707	ON	22281	Filled	150	
23	CS	12:25	1197.6825 MG	11552 MG	30036.81	27.17	719	ON	22347	Filled	160	
24	CS	10:10	1198.6741 MG	9416 MG	30052.84	22.03	712	ON	22399	Filled	160	
25	CS	10:50	1199.6672 MG	10431 MG	30071.23	24.39	713	ON	22457	Filled	156	
26	LEA	8:25	1200.5882 MG	9210 MG	30098.84	21.61	710	88°	22509	Filled	163	
27	CC	8:23	1201.6084 MG	10662 MG	30122.80	23.94	710	85°	22564	Filled	150	
28	LEA	9:05	1202.5863 MG	9879 MG	30145.74	22.94	710	OFF	22620	Filled	146	
29	CC	8:43	1203.4954 MG	9691 MG	30167.17	21.43	707	86°	22671	Filled	150	
30	CC	9:20	1204.4722 MG	9768 MG	30189.99	22.82	713	87°	22720	Filled	150	
31												

Comments:

Phelan Pinon Hills Community Service District

MONTH: December
 YEAR: 2012
 SITE: W-14

Well Log

Last months Flow read: 1204.4712 MG
 Hour read: 30189.99

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	CC	7:18	1205.4258 MG	.9536 MG	30211.93	21.94	724	ON	22778	Filled	155	
2	CC	9:38	1206.5164 MG	1.0906 MG	30237.11	25.18	722	ON	22838	Filled	150	
3	LEA	9:05	1207.4954 MG	.9790 MG	30259.96	22.85	714	ON	22892	Filled	150	
4	LEA	11:30	1208.6304 MG	1.1350 MG	30286.35	26.4	717	ON	22955	Filled	189	
5	LEA	8:20	1209.4457 MG	.8153 MG	30305.51	19.16	709	ON	23001	Filled	155	
6	LEA	8:25	1210.4141 MG	.9684 MG	30328.24	22.73	710	ON	23055	Filled	150	PM's completed Applied lube at 10:00
7	LEA	9:30	1211.4131 MG	.9990 MG	30350.84	22.60	737	ON	23109	Filled	154	
8	NB	9:20	1212.4355 MG	1.024 MG	30374.71	23.87	714	ON	23166	Filled	155	
9	NB	9:25	1213.3641 MG	.9286 MG	30396.33	21.62	716	ON	23218	Filled	160	
10	LEA	9:15	1214.2761 MG	.9130 MG	30417.86	21.53	706	ON	23269	Filled	154	
11	CC	8:12	1215.2676 MG	.9915 MG	30440.82	22.96	720	ON	23323	Filled	160	
12	CC	8:46	1216.2114 MG	.9448 MG	30463.02	22.2	709	ON	23376	Filled	167	
13	NB	10:00	1217.3012 MG	1.0888 MG	30488.41	25.39	714	ON	23437	Filled	200	
14	CC	9:46	1218.1947 MG	.8935 MG	30509.10	20.69	720	ON	23486	Filled	165	
15	B	12:50	1219.2006 MG	1.005 MG	30532.47	23.27	717	NO	23542	Filled	166	
16	AL	9:40	1219.9531 MG	.7525 MG	30549.92	17.95	714	ON	23583	Filled	160	
17	LEA	9:25	1220.9810 MG	1.0279 MG	30573.77	23.85	718	ON	23640	Filled	155	
18	LEA	8:20	1221.0278 MG	.0468 MG	30574.84	1.07	729	OFF	23643	Filled	146	JUST STARTED WELL
19	LEA	9:05	1221.0506 MG	.0228 MG	30575.46	.62	613	ON	23645	Filled	153	
20	LEA	8:56	1221.9719 MG	.9213 MG	30596.76	21.30	721	OFF	23696	Filled	147	
21	LEA	9:15	1222.8214 MG	.8495 MG	30616.69	19.93	710	OFF	23744	Filled	150	WELL FIRED UP
22	CC	9:37	1223.6690 MG	.8476 MG	30636.49	19.8	713	ON	23791	Filled	147	
23	JS	10:00	1224.4932 MG	.8243 MG	30655.60	19.11	718	ON	23837	Filled	160	
24	CC	6:54	1225.1632 MG	.6699 MG	30671.14	15.54	718	ON	23874	Filled	155	
25	CC	7:14	1225.9871 MG	.8239 MG	30690.19	19.05	710	ON	23919	Filled	145	
26	LEA	8:30	1226.7284 MG	.7413 MG	30707.39	17.20	718	ON	23961	Filled	160	WELL FIRED UP
27	LEA	8:30	1227.5204 MG	.7920 MG	30725.73	18.34	720	OFF	24005	Filled	159	
28	CC	9:16	1228.2705 MG	.7501 MG	30743.16	17.43	716	ON	24047	Filled	157	
29	NB	9:45	1229.0458 MG	.7753 MG	30761.34	18.08	715	ON	24090	Filled	159	
30	CC	9:10	1229.6797 MG	.6337 MG	30776.00	14.76	716	ON	24135	Filled	166	
31	LEA	9:00	1230.3889 MG	.7092 MG	30792.49	16.49	717	ON	24165	Filled	155	

Comments: