

Exhibit 17



Since 1958

PUMP CHECK

Pumping Systems Analysts
Hydraulic Test Report

(951) 684-9801 • Lic. 799498 • Fax (951) 684-2988

CERTIFICATE OF ACCURACY

Customer: Phelan Pinon Hills CSD
Location: 13150 263rd Street
Identification: Well #14

Test Date: 10/09/2012

Meter Size: 12" Make: Siemens Mag Flo
Meter No: 7ME652948102N297 Register: MG x .0001

General Data

Meter read before test: 1156.0646 Meter read after test: 1156.0778

Pipe ID: 12 (Inch) Pipe area: 113.1 (sq.in.) Pressure: 151.0 (Lbs/sq.in.)

Test Data

Test Before Inspection

Test Equipment			Totalizer		Volume			Metered GPM	Percent of Flow
Test No.	Mano Read	Actual GPM	Second Read	First Read	Diff.	Convert to Gallons	Time in Seconds		
1	6.40	724	1156.0708	1156.0680	28	2,800	232.05	724	100.0%
2	6.35	718	1156.0743	1156.0711	32	3,200	267.67	717	99.9%
3	6.35	718	1156.0775	1156.0745	30	3,000	251.48	716	99.7%
Avg.		720.1					Avg.	719.0	99.9%


Remarks

34.29.290n117.39.656w
PC 3235/SCE 32127

Approved _____

P.O. Box 5646, Riverside, California 92517

"Pump Testing. The Service You Pay For Yourself"



PUMP CHECK

Pumping Systems Analysts
Hydraulic Test Report

(951) 684-9801 • Lic. 799498 • Fax (951) 684-2988

CERTIFICATE OF ACCURACY

Customer: Phelan Pinon Hills CSD
Location: 13150 263rd Street
Identification: Well #14

Test Date: 09/27/2010

Meter Size: 12" Make: Siemens
Meter No: 7ME652948102N297 Register: Gal x 1 million

General Data

Meter read before test: 462.084 Meter read after test: 462.1106

Pipe ID: 12 (Inch) Pipe area: 113.1 (sq.in.) Pressure: 145.0 (Lbs/sq.in.)

Test Data

Test Before Inspection

Test No.	Mano Read	Actual GPM	Totalizer			Volume		Metered GPM	Percent of Flow
			Second Read	First Read	Diff.	Convert to Gallons	Time in Seconds		
1	6.95	786	462.0936	462.09	0.004	4,000	306.66	783	99.6%
2	6.90	780	462.098	462.094	0.0041	4,100	316.22	778	99.7%
3	6.95	786	462.1023	462.098	0.004	4,000	305.93	784	99.8%
Avg.		784.2				Avg.		781.7	99.7%

Remarks

34.29.290n117.39.656w
PC 3235/SCE 32127

Approved _____

P.O. Box 5646, Riverside, California 92517