

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: July 2003

Date	Mtr. Reading Well #1	Elect. Mtr. Well #1	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	262202	498	0.5	ok	ok	ok	ok
2							
3	262202	498	0.5	ok	ok	ok	ok
4							
5	262202	498	0.5	ok	ok	ok	ok
6							
7	262202	498	0.5	ok	ok	ok	ok
8							
9	262319	503	0.5	ok	ok	ok	ok
10							
11	262319	503	0.5	ok	ok	ok	ok
12							
13							
14	262319	504	0.5	ok	ok	ok	ok
15							
16	262319	504	0.5	ok	ok	ok	ok
17							
18	262319	504	0.5	ok	ok	ok	ok
19							
20				ok	ok	ok	ok
21							
22				ok	ok	ok	ok
23							
24				ok	ok	ok	ok
25							
26				ok	ok	ok	ok
27							
28	262319	516	0.5	ok	ok	ok	ok
29							
30	262321	507	0.5	ok	ok	ok	ok
31							
Totals	119	9					

OFF LINE



NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: July 2003

Date	Mtr. Reading Well #2	Elect. Mtr. Well #2	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	085793	37875	1.0	ok	ok	ok	ok
2							
3	086270	37893	1.0	ok	ok	ok	ok
4							
5	086313	38000	1.0	ok	ok	ok	ok
6							
7	086767	38006	1.0	ok	ok	ok	ok
8							
9	086983	38013	1.0	ok	ok	ok	ok
10							
11							
12	087849	38025	1.0	ok	ok	ok	ok
13							
14	087929	38045	0.5	ok	ok	ok	ok
15							
16	088126	38054	0.5	ok	ok	ok	ok
17							
18	088586	38071	0.5	ok	ok	ok	ok
19							
20	089046	38089	0.5	ok	ok	ok	ok
21							
22	089146	38106	0.5	ok	ok	ok	ok
23							
24	089206	38113	1.0	ok	ok	ok	ok
25							
26	089284	38118	2.0	ok	ok	ok	ok
27							
28	090367	38125	2.0	ok	ok	ok	ok
29							
30	090644	38134	2.0	ok	ok	ok	ok
31	090872	38142	2.0	ok	ok	ok	ok
Totals	5,079	267					

NORTH EDWARDS WATER DISTRICT
DAILY READINGS
 Month of: August 2003

Date	Mtr. Reading Well #2	Elect. Mtr. Well #2	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	090872	38142	1.0	ok	ok	ok	ok
2							
3							
4	091211	38153	1.0	ok	ok	ok	ok
5							
6	091698	38169	1.0	ok	ok	ok	ok
7							
8	092051	38181	1.0	ok	ok	ok	ok
9							
10							
11	092355	38191	1.0	ok	ok	ok	ok
12							
13	092736	38203	1.0	ok	ok	ok	ok
14							
15	092914	38218	1.0	ok	ok	ok	ok
16							
17							
18	093664	38234	1.0	ok	ok	ok	ok
19							
20	093974	38244	1.0	ok	ok	ok	ok
21							
22	094213	38255	1.0	ok	ok	ok	ok
23							
24	094557	38264	1.0	ok	ok	ok	ok
25							
26	094977	38279	1.0	ok	ok	ok	ok
27							
28							
29	095459	38294	1.0	ok	ok	ok	ok
30							
31	095771	38304	1.0	ok	ok	ok	ok
1st	095937	38309	1.0	ok	ok	ok	ok
Totals	5,065	167					

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: September 2003

Date	Mtr. Reading Well #1	Elect. Mtr. Well #1	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	262321	507	0.5	ok	ok	ok	ok
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25	262321	507	2.0	ok	ok	ok	ok
26							
27	262381	511	3.0	ok	ok	ok	ok
28							
29	262441	513	3.0	ok	ok	ok	ok
30	262531	514	3.0	ok	ok	ok	ok
31							
Totals	210	7					

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: September 2003

Date	Mtr. Reading Well #2	Elect. Mtr. Well #2	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	095937	38370	3.0	ok	ok	ok	ok
2							
3	096226	38319	3.0	ok	ok	ok	ok
4							
5	096529	38329	3.0	ok	ok	ok	ok
6							
7							
8	096985	38344	3.0	ok	ok	ok	ok
9	097127	38349	2.5	ok	ok	ok	ok
10							
11	097336	38355	2.5	ok	ok	ok	ok
12							
13	097341	38365	2.5	ok	ok	ok	ok
14							
15	097971	38377	2.5	ok	ok	ok	ok
16							
17	098201	38383	2.5	ok	ok	ok	ok
18							
19	098483	38393	2.5	ok	ok	ok	ok
20							
21							
22	098994	38410	1.5	ok	ok	ok	ok
23							
24	099194	38415	1.5	ok	ok	ok	ok
25							
26							
27							
28							
29							
30							
31							
1st	099377	38424	1.5	ok	ok	ok	ok
Totals	3,440	114					

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: October 2003

Date	Mtr. Reading Well #1	Elect. Mtr. Well #1	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	262531	559	2.5	ok	ok	ok	ok
2							
3							
4							
5							
6	263632	580	2.5	ok	ok	ok	ok
7							
8							
9	263952	597	1.5	ok	ok	ok	ok
10							
11	264110	604	1.5	ok	ok	ok	ok
12							
13					ok	Taper lock broken	ok
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31	264443	626	1.5	ok	ok	ok	ok
Totals	1,912	67					

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: October 2003

Date	Mtr. Reading Well #2	Elect. Mtr. Well #2	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	099377	38424	1.5	ok	ok	ok	ok
2							
3							
4							
5							
6	099396	38425	1.5	ok	ok	ok	ok
7							
8							
9							
10							
11							
12							
13	099432	38428	2.5	ok	ok	ok	ok
14							
15	099692	38436	2.0	ok	ok	ok	ok
16							
17							
18	099967	38446	2.0	ok	ok	ok	ok
19							
20							
21	100282	38457	2.0	ok	ok	ok	ok
22							
23	100508	38464	2.0	ok	ok	ok	ok
24							
25	100762	38473	2.0	ok	ok	ok	ok
26							
27	101042	38473	2.0	ok	ok	ok	ok
28							
29	101249	38490	2.0	ok	ok	ok	ok
30							
31	101473	38498	2.0	ok	ok	ok	ok
Totals	1,096	74					

NORTH EDWARDS WATER DISTRICT
DAILY READINGS
 Month of: November 2003

Date	Mtr. Reading Well #1	Elect. Mtr. Well #1	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	264443	626	2.5	ok	ok	ok	ok
2							
3	264443	626	2.0	ok	ok	ok	ok
4							
5	264443	626	1.5	ok	ok	ok	ok
6							
7	264443	626	1.5	ok	ok	ok	ok
8							
9	264443	626	2.0	ok	ok	ok	ok
10							
11							
12	264502	632	2.0	ok	ok	ok	ok
13							
14	264586	639	1.5	ok	ok	ok	ok
15							
16	264773	656	1.5	ok	ok	ok	ok
17							
18							
19	264853	660	2.0	ok	ok	ok	ok
20							
21	265090	671	2.0	ok	ok	ok	ok
22							
23	265170	675	2.0	ok	ok	ok	ok
24							
25	265259	678	1.0	ok	ok	ok	ok
26							
27	265349	682	1.0	ok	ok	ok	ok
28							
29	265434	686	1.0	ok	ok	ok	ok
30							
31	265587	690	1.0	ok	ok	ok	ok
Totals	1,144	64					

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: November 2003

Date	Mtr. Reading Well #2	Elect. Mtr. Well #2	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	101473	38498	2.0	ok	ok	ok	ok
2							
3	101708	38506	1.0	ok	ok	ok	ok
4							
5	101818	38511	1.0	ok	ok	ok	ok
6							
7	101913	38515	1.0	ok	ok	ok	ok
8							
9							
10	102213	38524	1.0	ok	ok	ok	ok
11							
12	102264	38526	1.0	ok	ok	ok	ok
13							
14	102264	38526	0.5	ok	ok	ok	ok
15							
16							
17	102264	38526	0.5	ok	ok	ok	ok
18							
19	102264	38526	0.5	ok	ok	ok	ok
20							
21							
22	102311	38530	0.5	ok	ok	ok	ok
23							
24	102311	38530	0.5	ok	ok	ok	ok
25							
26	102311	38530	0.5	ok	ok	ok	ok
27							
28	102311	38530	0.5	ok	ok	ok	ok
29							
30	102317	38532	0.5	ok	ok	ok	ok
31							
Totals	834	34					

NORTH EDWARDS WATER DISTRICT
DAILY READINGS
 Month of: December 2003

Date	Mtr. Reading Well #1	Elect. Mtr. Well #1	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	265587	690	2.5	ok	ok	ok	ok
2							
3	265662	694	2.5	ok	ok	ok	ok
4							
5	265737	698	2.5	ok	ok	ok	ok
6							
7							
8	265848	699	2.5	ok	ok	ok	ok
9							
10	265923	704	2.5	ok	ok	ok	ok
11							
12	265998	709	2.5	ok	ok	ok	ok
13							
14	266073	713	2.5	ok	ok	ok	ok
15							
16	266148	717	2.0	ok	ok	ok	ok
17							
18							
19	266259	722	2.0	ok	ok	ok	ok
20							
21	266334	726	2.0	ok	ok	ok	ok
22							
23	266409	731	2.0	ok	ok	ok	ok
24							
25	266484	735	1.0	ok	ok	ok	ok
26							
27	266546	738	1.0	ok	ok	ok	ok
28							
29	266609	746	1.0	ok	ok	ok	ok
30							
31							
	266751	753		ok	ok	ok	ok
Totals	1,164	63					

NORTH EDWARDS WATER DISTRICT

DAILY READINGS

Month of: December 2003

Date	Mtr. Reading Well #2	Elect. Mtr. Well #2	CL2 Res	Inspc. of Press. Tank	Inspc. Of Stor. Tank	Pressure Pump	Deep Well
1	102317	38532	0.5	ok	ok	ok	ok
2							
3	102317	38532	0.5	ok	ok	ok	ok
4							
5							
6	102327	38534	0.5	ok	ok	ok	ok
7							
8	102468	38539	1.5	ok	ok	ok	ok
9							
10	102564	38545	1.5	ok	ok	ok	ok
11							
12							
13	102768	38553	1.5	ok	ok	ok	ok
14							
15	102768	38553	1.5	ok	ok	ok	ok
16							
17							
18	102768	38553	1.0	ok	ok	ok	ok
19							
20	102768	38553	1.0	ok	ok	ok	ok
21							
22	102768	38553	1.0	ok	ok	ok	ok
23							
24							
25	102768	38553	0.05	ok	ok	ok	ok
26							
27	102768	38553	0.05	ok	ok	ok	ok
28							
29	102768	38553	0.05	ok	ok	ok	ok
30							
31							
	102768	38553	0.05	ok	ok	ok	ok
Totals	457	21					