

EXHIBIT A

Phelan Pinon Hills Community Service District

MONTH: JANUARY

YEAR: 2011

SITE: W-14

Well Log

Last months Flow read: 549.9816

Hour read: 10:10:11

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	12:06	10:45	550.7696	.8874	17755.75	19.64	753	37711	✓	154	
2	12	11:00	551.7749	1.0107	14811.15	22.4	752	39965	Filled	150	
3	12	8:30	552.1415 mg	.7119	14822.09	10.44	744	40500	Filled	144	
4	12	8:40	553.3467 mg	.8549	14846.17	19.03	747	40851	Filled	155	
5	12	9:45	554.4811 mg	1.1344	14871.78	25.41	738	40113	Filled	145	
6	12	11:00	555.6237 mg	1.1426	14896.93	25.45	757	40175	Filled	170	
7	LEA	8:45	556.5142 mg	.8905	14916.82	19.89	746	40222	Filled	157	
8	CPA	8:09	557.4372 mg	.923	14937.46	26.64	745	40272	Filled	160	
9	EPA	9:10	558.3107 mg	.8735	14957.28	19.82	735	40320	Filled	165	
10	12	9:00	559.2995	.9831	14979.25	21.95	751	40374	Filled	150	
11	12	9:40	560.2200 mg	.9202	14999.57	26.34	754	40423	Filled	150	
12	12	9:00	561.1813 mg	.9615	15020.95	21.38	749	40475	Filled	150	
13	EPA	7:57	562.0787 mg	.8974	15040.93	19.98	749	40524	Filled	160	
14	12	10:00	563.0620 mg	.9833	15062.87	21.94	747	40577	Filled	165	
15	12	11:45	564.9478 mg	.8854	15082.165	19.76	746	40625	Filled	154	
16	12	9:30	564.6441	.7463	15099.910	16.15	742	40666	Filled	170	
17	12	9:45	565.5474	.8533	15118.52	16.02	743	40773	Filled	170	
18	LEA	7:30	566.3612 mg	.8138	15136.73	18.23	744	40757	Filled	160	
19	12	8:00	567.3039 mg	.9427	15157.69	20.96	730	40808	Filled	155	
20	LEA	8:05	568.1777 mg	.8138	15177.17	19.48	748	40855	Filled	163	
21	12	8:45	569.0521 mg	.8744	15196.62	19.45	749	40903	Filled	160	
22	EPA	9:11	569.9340 mg	.8819	15216.32	19.70	746	40950	Filled	150	
23	LEA	7:45	570.7619 mg	.8279	15234.96	18.64	740	40995	Filled	155	
24	12	8:30	571.7219 mg	.9600	15256.52	21.36	749	41047	Filled	160	
25	12	8:10	572.662 mg	.9393	15277.24	20.72	748	41098	Filled	160	
26	12	9:00	573.5676 mg	1.004	15299.47	22.23	755	41152	Filled	155	
27	12	8:25	574.5032 mg	.8354	15318.35	18.68	738	41198	Filled	156	
28	12	5:15	575.0034 mg	.8602	15329.76	11.11	730	41226	Filled	149	
29	12	11:00	576.0465	1.0431	15352.77	23.01	755	41282	Filled	150	
30	12	9:02	576.8293 mg	.7828	15370.40	17.63	740	41334	Filled	160	
31	12	8:35	577.6173	.8686	15387.15	19.33	746	41371	Filled	160	

Comments:

Phelan Pinon Hills Community Service District

MONTH: FEBRUARY
YEAR: 2011
SITE: W-14

Well Log

Hour read: 15889.78

Flow read: 577.10473

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	CEA	7:25	578.5704 mg	8731	15409.20	19.42	749	41419	Filled	162	
2	RS	7:55	579.4481 mg	8777	15428.83	19.63	745	41446	Filled	146	
3	RS	9:00	580.4557 mg	88676	15451.18	22.35	751	41520	Filled	158	
4	CEA	8:10	581.2720 mg	81663	15469.36	18.18	748	41565	Filled	158	
5	RS	9:30	582.2530 mg	8991	15491.30	21.94	752	41618	Filled	160	
6	TC	9:25	583.2135 mg	89505	15512.57	21.27	744	41670	Filled	151	
7	RS	8:45	584.0667 mg	8532	15531.87	19.13	737	41716	Filled	162	
8	RS	8:15	585.0285 mg	8618	15553.18	21.31	752	41768	Filled	155	
9	RS	10:45	585.9487 mg	8702	15574.72	21.54	751	41820	Filled	155	Adj. oil deep
10	RS	8:10	586.7661 mg	87674	15591.88	17.16	745	41862	Filled	150	
11	RS	9:00	587.6913 mg	8252	15612.52	20.64	747	41912	Filled	150	
12	RS	1:10	588.7553 mg	10642	15634.21	23.69	749	41970	Filled	171	
13	RS	11:50	589.6500 mg	8745	15656.52	22.11	741	42019	Filled	166	
14	RS	5:30	590.4272 mg	8772	15673.86	17.54	739	42061	Filled	150	
15	RS	1:15	591.5513 mg	11241	15699.04	25.18	744	42122	Filled	162	
16	RS	10:00	592.3014 mg	7531	15715.03	16.89	743	42163	Filled	190	
17	RS	8:45	593.2051 mg	8807	15735.97	19.94	752	42211	Filled	160	
18	RS	9:45	594.2441 mg	8841	15756.58	15.03	753	42267	Filled	180	
19	CEA	9:50	595.0993 mg	8532	15777.75	18.85	754	42313	Filled	160	
20	EPA	10:44	596.0197 mg	9204	15798.19	20.44	750	42363	Filled	148	
21	EPA	8:53	596.8258 mg	8661	15815.50	17.61	743	42406	Filled	151	
22	RS	9:00	597.7241 mg	9183	15835.32	20.12	761	42455	Filled	150	
23	RS	9:00	598.4627 mg	7186	15852.21	16.29	735	42493	Filled	156	
24	RS	7:15	599.3534 mg	8707	15871.79	19.58	748	42541	Filled	151	
25	RS	10:00	600.2822 mg	9288	15892.19	20.40	759	42591	Filled	150	
26	CC	11:59	601.3016 mg	10194	15914.68	22.49	755	42646	11	158	
27	CC	8:55	602.0792 mg	7676	15930.25	15.67	753	42684	11	155	
28	RS	9:00	602.9938 mg	9846	15952.31	21.96	747	42737	Filled	190	
29											
30											
31											

Comments:

Phelan Pinon Hills Community Service District

MONTH: MARCH
YEAR: 2011
SITE: W-14

Well Log

Last months Flow read: 602.9938 mg

Hour read: 15452.31

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Edison	Oil	PSI	Comments
1	RS	8:00	603.9566 mg	9628	15973.66	21.35	752	42789	Filled	153	
2	RS	9:00	604.8962 mg	9376	15974.47	20.81	753	42861	Filled	150	
3	RS	9:15	605.8904 mg	9942	16086.22	21.75	762	42893	Filled	155	
4	EPA	8:00	606.7768 mg	8864	16035.72	19.5	758	42940	Filled	149	
5	TS	11:00	607.7376 mg	9688	16057.33	21.61	741	42942	Filled	160	
6	TC	9:40	608.5533 mg	8157	16075.54	18.21	746	43036	Filled	155	
7	RS	9:00	609.4393	8866	16095.18	19.64	752	43084	Filled	150	
8	RS	8:45	610.3610	9217	16115.65	20.47	750	43133	Filled	150	Adj. 1 drop
9	RS	8:50	611.2270 mg	8660	16134.98	19.83	747	43180	Filled	156	
10	RS	8:45	612.1906 mg	9134	16155.42	20.44	745	43230	Filled	151	
11	RS	9:30	613.1644 mg	10238	16178.37	22.95	744	43286	Filled	155	
12	RS	2:25	614.7682 mg	11038	16202.92	20.55	749	43345	Filled	179	
13	ALU	11:15	615.0530	7646	16220.18	17.26	754	43388	Filled	175	
14	RS	10:00	615.8631	8161	16238.67	18.49	730	43432	Filled	150	
15	RS	10:30	616.7813	9182	16257.34	20.67	746	43483	Filled	155	
16	RS	9:30	617.7000	9181	16277.73	20.39	751	43532	Filled	150	
17	TC	7:40	618.4812	7812	16297.60	17.87	728	43575	Filled	148	
18	TS	8:15	619.4513 mg	9701	16319.39	21.79	742	43628	Filled	155	
19	LEA	10:15	620.4630 mg	10117	16341.97	22.58	747	43682	Filled	160	
20	EPA	10:44	621.4982 mg	10352	16364.86	22.59	754	43738	Filled	149	
21	ALU	2:25	621.9715 mg	4733	16375.75	10.99	724	43761	Filled	150	
22	RS	8:20	622.8145 mg	8430	16394.82	19.07	737	43811	Filled	152	Adj. oil drop
23	RS	9:30	623.4560 mg	6115	16407.85	15.03	711	43846	Filled	171	
24	RS	8:45	624.2180 mg	7620	16426.79	16.94	750	43887	Filled	150	
25	RS	9:30	625.0374 mg	58194	16445.69	18.3	744	43932	Filled	163	
26	CL	8:33	625.8966 mg	8592	16463.96	18.87	759	43978	Filled	140	
27	TC	11:21	626.7790 mg	8824	16483.83	19.87	740	44027	Filled	158	
28	RS	9:00	627.5527 mg	7737	16501.06	17.23	748	44069	Filled	155	
29	RS	9:00	628.3846 mg	8319	16517.42	18.32	747	44114	Filled	157	
30	RS	9:00	629.3375 mg	9529	16540.59	20.37	757	44165	Filled	146	
31	RS	9:15	630.1658 mg	8483	16559.45	19.07	741	44211	Filled	148	

Comments:

15973.66

Phelan Pinon Hills Community Service District

MONTH: APRIL
YEAR: 2011
SITE: W-14

Well Log

Last months Flow read: 630.1858 mg

Hour read: 16557.66

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	53	9:05	631.1179 mg	9371	16500.63	20.17	741	44262	✓	160	
2	53	6:35	631.8848 mg	9719	16548.48	17.85	720	44304	Filled	150	
3	71C	10:34	632.9736 mg	1,0338	16621.76	23.28	740	44301	Filled	150	
4	85	9:00	633.8252 mg	19016	16642.05	20.29	741	44410	Filled	150	
5	85	8:30	634.6822 mg	8570	16661.37	19.32	739	44456	Filled	150	
6	85	8:40	635.5583 mg	18761.00	16681.71	20.34	718	44505	Filled	147	
7	85	8:30	636.5120 mg	9537.00	16702.90	21.28	747	44558	Filled	186	
8	85	9:15	637.4986 mg	9866.00	16724.98	21.39	748	44610	Filled	150	
9	82	12:16	638.5191 mg	1,0205	16747.45	22.67	750	44665	Filled	173	
10	86	10:34	639.9858 mg	5647	16767.08	19.13	741	44712	Filled	170	
11	85	8:10	640.1971 mg	8933	16785.86	13.58	730	44757	Filled	149	
12	LEA	8:13	641.2105 mg	1,0134	16808.35	22.69	744	44812	Filled	162	
13	85	7:06	642.2413 mg	1,0305	16831.44	23.09	744	44867	Filled	185	
14	85	7:30	643.2194 mg	9784	16853.42	21.98	742	44920	Filled	163	
15	85	9:00	644.0792 mg	9598	16873.11	19.62	730	44968	Filled	145	
16	EPA	9:55	644.9754 mg	9162	16893.92	20.88	731	45018	Filled	170	
17	LEA	8:55	645.9424 mg	9470	16915.51	21.59	731	45070	Filled	160	
18	85	9:10	646.9196 mg	9772	16937.76	22.19	734	45123	Filled	150	
19	85	7:40	647.8683 mg	9487.00	16957.20	21.5	735	45175	Filled	158	
20	85	7:45	648.8739 mg	1,0056	16978.09	22.37	732	45230	Filled	150	
21	85	12:50	650.0748 mg	1,2019	17007.46	27.27	732	45295	Filled	160	
22	85	9:00	650.1716 mg	9028.00	17029.57	26.11	748	45344	Filled	149	
23	85	10:30	652.0370 mg	1,8582	17053.73	24.16		45402	Filled	160	
24	85	10:55	653.0210 mg	19832	17076.11	22.38	732	45456	Filled	160	
25	85	3:00	654.2048 mg	1,1858	17102.91	26.8	732	45520	Filled	190	
26	85	7:00	655.2740 mg	1,0675	17126.82	23.91	744	45573	Filled	155	
27	85	9:00	655.9915 mg	17172	17143.20	16.28	730	45611	Filled	175	
28	85	8:30	656.9887 mg	9974	17166.72	23.02	722	45673	Filled	149	
29	EPA	8:12	658.0004 mg	1,0115	17189.46	23.24	725	45727	Filled	156	
30	85	9:30	659.0480 mg	1,0470	17213.35	23.89	731	45785	Filled	145	
31											

Comments:

170

Phelan Pinon Hills Community Service District

MONTH: MAY

YEAR: 2011

SITE: W-14

Well Log

Last months Flow read: 659.0480 mg

Hour read: 1723.35

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	J3	9:30	600.1285 mg	1.0805	17238.10	24.75	727	45844	Oil	175	
2	PS	10:30	661.2744 mg	1.1457	17264.54	26.44	722	45708	Oil	166	
3	PS	10:00	663.1783 mg	1.0391	17235.54	26.02	717	45552	Filled	166	
4	PS	8:15	663.1274 mg	1.9491	17200.42	23.42	715	46012	Filled	167	
5	PS	8:15	664.1471 mg	1.0207	17331.14	23.46	710	46062	Filled	165	
6	PS	8:45	665.2247 mg	1.0768	17334.71	23.07	714	46122	Filled	167	
7	PS	11:00	666.3254 mg	1.1607	17382.03	25.75	712	46187	Filled	166	Agal drop
8	PS	10:45	667.3324 mg	1.007	17466.04	23.58	712	46245	Filled	159	
9	PS	8:30	668.2838 mg	1.9514	17427.35	21.91	724	46298	Filled	190	
10	PS	9:00	669.3231 mg	1.0553	17452.35	24.44	710	46363	Filled	190	
11	PS	8:30	670.3222 mg	1.9912	17475.67	23.32	714	46411	Filled	151	
12	PS	8:40	671.3661 mg	1.0432	17500.15	24.46	711	46470	Filled	165	
13	J3	9:00	672.4306 mg	1.0646	17524.82	24.67	719	46529	Filled	165	
14	EPA	9:15	673.4541 mg	1.0235	17548.73	23.91	713	46586	Filled	158	
15	LEA	9:40	674.5032 mg	1.0491	17573.03	24.3	720	46644	Filled	190	
16	PS	9:00	675.6762 mg	1.9730	17595.55	22.52	717	46695	Filled	170	
17	LEA	8:10	676.3995 mg	1.9283	17617.29	21.64	711	46749	Filled	168	
18	PS	9:10	677.3956 mg	1.9461	17640.53	23.24	714	46805	Filled	160	
19	PS	9:45	678.3959 mg	1.0053	17663.96	23.47	712	46860	Filled	170	
20	PS	10:15	679.4665 mg	1.9696	17683.51	24.91	714	46920	Filled	169	
21	PS	12:10	680.5377 mg	1.0712	17714.28	25.37	703	46980	Filled	196	
22	DE	9:19	681.3770 mg	1.8393	17734.20	19.92	702	47027	Filled	160	
23	PS	9:20	682.3412 mg	1.9643	17757.20	23.00	698	47031	Filled	172	
24	PS	8:25	683.2594 mg	1.9180	17778.65	21.45	713	47132	Filled	172	
25	PS	8:40	684.2328 mg	1.9734	17801.96	23.31	696	47188	Filled	160	
26	PS	9:20	685.2689 mg	1.0340	17826.51	24.55	703	47246	Filled	180	
27	J3	10:10	686.3122 mg	1.0453	17851.50	24.49	700	47305	Filled	120	
28	J3	10:20	687.2951 mg	1.9829	17875.04	23.54	696	47361	Filled	170	
29	J3	9:30	688.2435 mg	1.9484	17877.89	22.85	692	47415	Filled	175	
30	J3	8:04	689.1504 mg	1.9069	17919.52	21.63	693	47460	Filled	150	
31	PS	9:40	690.1699 mg	1.0714	17944.29	24.77	685	47525	Filled	160	

Comments:

Phelan Pinon Hills Community Service District

MONTH: JUNE

YEAR: 2011

SITE: W-14

Well Log

Last months Flow read: 696.1628 mg

Hour read: 12:00

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	8:45	LEA	691.1489 mg	.9809	17967.77	23.48	696	47580	Filled	177	
2	8:25	LEA	692.1456 mg	.9967	17991.48	23.71	701	47636	Filled	175	
3	8:45	PS	693.1652 mg	1.0196	18015.82	24.34	698	47694	Filled	162	
4	PS	10:15	694.2350 mg	1.0498	18041.24	25.44	701	47754	Filled	176	
5	PS	12:00	695.3885 mg	1.1535	18067.76	25.94	741	47816	Filled	141	
6	LEA	8:45	696.2926 mg	.9041	18087.77	20.57	733	47865	Filled	210	
7	LEA	9:00	697.3107 mg	1.0181	18112.07	24.3	698	47922	Filled	190	
8	LEA	8:35	698.3039 mg	.9932	18135.64	23.57	702	47978	Filled	205	
9	LEA	8:10	699.1476 mg	.9437	18155.97	20.33	691	48026	Filled	162	
10	LEA	8:30	700.0203 mg	.8727	18176.74	20.77	700	48075	Filled	165	
11	LEA	10:10	701.1076 mg	1.0873	18202.38	25.64	707	48136	Filled	160	
12	FPA	9:03	702.0807 mg	.9773	18225.38	23	705	48190	Filled	174	
13	LEA	8:10	703.0541 mg	.9724	18248.18	22.8	712	48245	Filled	175	
14	LEA	8:10	704.0668 mg	1.0127	18272.16	23.98	704	48301	Filled	170	
15	LEA	8:25	705.0856 mg	1.0128	18296.14	23.98	708	48358	Filled	162	Flushed 30 DIE
16	LEA	7:50	706.0742 mg	.9886	18319.48	23.34	706	48414	Filled	170	
17	PS	8:15	707.1023 mg	1.0281	18343.92	24.44	701	48472	Filled	171	
18	CC	9:10	708.1641 mg	1.0618	18368.97	25.05	706	48531	Filled	155	
19	CC	9:51	709.2113 mg	1.0472	18393.54	24.57	710	48589	Filled	155	
20	LEA	10:08	710.1840 mg	.9727	18416.38	22.84	710	48644	Filled	175	
21	LEA	8:00	711.1077 mg	.9237	18438.28	21.9	703	48695	Filled	160	
22	LEA	8:10	712.1151 mg	1.0074	18462.39	24.11	696	48752	Filled	165	
23	LEA	8:40	713.1441 mg	1.029	18486.91	24.52	699	48810	Filled	172	
24	LEA	8:40	714.1591 mg	1.015	18510.91	24.0	705	48867	Filled	177	
25	PS	8:20	715.1667 mg	1.0211	18534.95	23.97	697	48924	Filled	175	
26	LEA	8:37	716.1576 mg	.9974	18558.86	23.98	693	48980	Filled	179	
27	LEA	8:10	717.1386 mg	.9810	18582.39	23.53	695	49035	Filled	194	
28	LEA	7:47	718.1277 mg	.9891	18606.02	23.63	698	49091	Filled	180	
29	LEA	8:45	719.1676 mg	1.0399	18630.00	23.98	723	49150	Filled	173	
30	LEA	8:40	720.1628 mg	.9952	18654.91	24.91	666	49207	Filled	175	
31											

Comments:

1000

Phelan Pinon Hills Community Service District

MONTH: July
YEAR: 2011
SITE: W-14

Well Log

Hour read: 18654.91

Last months Flow read: 720.1628 mg

Flow Meter Read

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Edison	Oil	PSI	Comments
1	RS	9:30	721.2038	1.04100	18679.73	24.84	693	49265	Filled	162	
2	RS	10:00	732.2685	1.084700	18700.01	25.21	694	49320	Filled	160	
3	ALA	9:25	723.2041	.9356	18717.55	22.41	695	49379	Filled	160	
4	ALA	9:57	724.2216	1.0205	18757.00	24.45	695	49436	Filled	163	Flushed @ 0.2 WASH
5	LEA	8:30	725.1764 mg	.9518	18774.72	22.72	698	49490	Filled	184	
6	LEA	8:25	726.1713 mg	.9949	18798.64	23.93	693	49547	Filled	166	
7	LEA	8:35	727.1917 mg	1.0204	18822.81	24.17	704	49604	Filled	184	
8	LEA	8:20	728.1726 mg	.9809	18846.58	23.77	688	49660	Filled	168	
9	LEA	9:10	729.2050 mg	1.0824	18871.43	24.85	693	49719	Filled	182	
10	EPA	7:49	730.1442 mg	.9392	18894.06	22.63	692	49772	Filled	164	Adj Driller
11	LEA	8:50	731.1949 mg	1.0507	18919.09	25.03	700	49831	Filled	162	
12	LEA	7:57	732.1612 mg	.9663	18942.20	23.11	697	49886	Filled	164	
13	EPA	7:57	733.1680 mg	1.0068	18966.25	24.05	698	49943	Filled	176	
14	LEA	8:00	734.1370 mg	.969	18989.48	23.23	695	49998	Filled	160	
15	RS	8:40	735.1520 mg	1.0150	19013.75	24.27	697	50055	Filled	179	
16	LE	9:12	736.1703 mg	1.0183	19038.25	24.5	693	50113	Filled	190	
17	LE	9:07	737.1818 mg	1.0115	19062.15	23.9	705	50170	Filled	179	
18	LEA	9:20	738.2157 mg	1.0339	19086.35	24.2	712	50228	Filled	157	
19	LEA	8:10	739.1833 mg	.9626	19109.25	22.9	704	50282	Filled	178	Flushed Blow off
20	LEA	8:33	740.1822 mg	.9989	19132.75	23.5	700	50338	Filled	155	ext wash
21	LEA	9:32	741.2398 mg	1.0576	19157.73	24.98	706	50397	Filled	173	
22	LEA	8:42	742.2165 mg	.9767	19180.89	23.16	703	50452	Filled	155	
23	RS	10:10	743.2406 mg	1.0001	19204.50	23.67	704	50508	Filled	145	
24	LE	12:14	744.3484 mg	1.1238	19231.93	26.17	707	50571	Filled	175	
25	LEA	8:10	745.1263 mg	.7859	19250.06	19.03	688	50616	Filled	169	
26	LEA	8:10	746.1345 mg	1.0082	19274.06	24.00	700	50673	Filled	157	Flushed Blow off
27	LEA	8:30	747.1502 mg	1.0157	19298.38	24.32	696	50730	Filled	175	at wash
28	RS	11:30	748.2213 mg	1.11100	19325.30	26.95	687	50794	Filled	196	
29	RS	8:50	749.1469 mg	.8556	19346.67	21.34	692	50844	Filled	145	
30		12:30	750.2404 mg	1.143200	19374.30	27.63	690	50909	Filled	175	
31			751.1689	.8785	19395.80	21.56	679	50954	Filled	145	

Comr ts:

(Signature)

Phelan Pinon Hills Community Service District

MONTH: August
YEAR: 2011
SITE: W-14

Well Log

Hour read: 19395.86

Flow Meter Read: 751.1689 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	LEA	8:38	752.0547 mg	8858	19417.03	21.17	697	51010	Filled	160	
2	LEA	8:20	752.9787 mg	9240	19439.26	22.23	693	51062	Filled	187	
3	LEA	10:15	754.0553 mg	1.0766	19465.19	25.93	692	51123	Filled	187	
4	LEA	8:08	754.9640 mg	9087	19487.07	21.88	692	51175	Filled	198	
5	LEA	8:40	755.9814 mg	1.0174	19511.58	22.51	690	51223	Filled	165	
6	EPA	7:57	756.9470 mg	9656	19534.99	23.41	687	51288	Filled	162	
7	LEA	9:55	758.0166 mg	1.0656	19560.86	25.87	689	51349	Filled	187	Flushed 80 @ WASH
8	LEA	8:13	758.9431 mg	9265	19583.15	22.29	693	51402	Filled	162	
9	LEA	8:18	759.9435 mg	1.0004	19607.22	24.07	693	51459	Filled	167	
10	IS	8:30	760.9528 mg	1.0193	19631.77	24.55	685	51517	Filled	180	
11	LEA	8:25	761.9324 mg	9796	19655.35	23.58	692	51572	Filled	188	
12	OS	10:45	763.0844 mg	1.1525	19683.46	23.13	690	51637	Filled	167	
13	EL	9:14	763.9413 mg	9854	19704.15	24.67	691	51687	Filled	210	
14	EPA	8:33	764.9068 mg	9655	19727.52	23.37	689	51742	Filled	180	
15	LEA	8:50	765.9132 mg	1.0064	19751.79	24.27	691	51800	Filled	172	
16	LEA	8:25	766.8913 mg	9781	19775.10	23.31	699	51855	Filled	175	
17	LEA	8:05	767.8702 mg	9789	19798.75	23.65	690	51911	Filled	182	
18	LEA	9:20	768.9100 mg	1.0398	19823.99	25.24	687	51970	Filled	188	
19	LEA	8:32	769.8689 mg	9589	19847.20	23.31	689	52025	Filled	162	
20	JS	10:45	770.9443 mg	1.0754	19873.04	25.86	693	52086	Filled	200	
21	TC	11:12	771.9678 mg	1.0235	19897.81	24.75	689	52145	Filled	181	
22	EPA	8:55	772.8703 mg	9025 mg	19919.60	21.79	690	52196	Filled	169	Adj. Dripper
23	EPA	8:51	773.8614 mg	9911 mg	19943.55	23.95	689	52252	Filled	181	
24	EPA	8:08	774.8243 mg	9962 mg	19966.91	23.36	687	52307	Filled	179	
25	EPA	8:40	775.8455 mg	1.0212 mg	19991.52	24.61	692	52365	Filled	162	
26	OS	9:00	776.8545 mg	1.0110 mg	20015.97	24.45	689	52423	Filled	160	
27	OS	10:20	777.8945 mg	1.0380	20041.14	25.17	687	52483	Filled	161	
28	AL	8:40	778.7436 mg	9491	20067.05	26.91	680	52532	Filled	162	
29	LEA	10:40	779.8202 mg	1.0766	20087.98	26.03	689	52593	Filled	188	
30	LEA	8:25	780.7262 mg	9060	20109.75	21.77	694	52644	Filled	182	3 seconds per Drop
31	LEA	7:54	781.6877 mg	9615	20133.22	23.47	683	52700	Filled	163	

Comr ts:

Phelan Pinon Hills Community Service District

MONTH: September
YEAR: 2011
SITE: W-14

Well Log

Hour read: 20133.22

781.6877 mg

Last months Flow read:

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Edison	Oil	PSI	Comments
1	LEA	8:35	782.7074 mg	1.0197	20157.91	24.69	688	52758	Filled	155	
2	LEA	8:35	783.6953 mg	.9879	20181.89	23.98	687	52814	Filled	180	
3	EPA	10:00	784.6447 mg	.9494	20204.87	22.98	689	52869	Filled	158	
4	LEA	10:30	785.6552 mg	1.0105	20229.36	24.49	688	52926	Filled	162	Idle pump 3 seconds
5	EPA	11:04	786.4434 mg	.7902	20248.90	19.54	674	52972	Filled	168	Flushed 3/000
6	LEA	8:15	787.3111 mg	.8657	20269.98	21.08	684	53022	Filled	198	WASH
7	LEA	7:18	788.2497 mg	.9386	20293.05	23.07	678	53076	Filled	188	
8	LEA	9:02	789.3021 mg	1.0524	20318.77	25.72	682	53137	Filled	185	
9	LEA	8:50	790.2335 mg	.9314	20341.50	22.77	681	53190	Filled	162	
10	LEA	8:50	791.2281 mg	.9946	20365.51	23.95	692	53247	Filled	198	
11	LEA	9:27	792.2329 mg	1.0048	20390.21	24.7	692	53305	Filled	170	
12	LEA	8:33	793.1723 mg	.9444	20413.24	23.03	683	53359	Filled	183	
13	LEA	7:54	794.1026 mg	.9253	20435.73	22.49	686	53412	Filled	198	
14	LEA	7:51	794.9809 mg	.8803	20456.93	21.2	692	53462	Filled	195	
15	LEA	9:18	796.0357 mg	1.0528	20482.35	25.42	680	53522	Filled	190	
16	LEA	8:53	797.0096 mg	.9739	20505.92	23.57	689	53578	Filled	174	
17	LEA	8:00	797.9887 mg	.9791	20529.42	23.50	694	53634	Filled	185	
18	LEA	11:38	799.0493 mg	1.0606	20555.08	25.66	688	53694	Filled	163	
19	LEA	8:43	799.8490 mg	.7997	20574.25	19.17	695	53740	Filled	163	Finished BOD at 10:00
20	LEA	8:54	800.8537 mg	1.0047	20598.45	24.2	692	53797	Filled	176	
21	LEA	8:26	801.8367 mg	.9835	20622.85	23.58	695	53851	Filled	157	
22	LEA	8:20	802.7893 mg	.9526	20644.94	22.91	693	53905	Filled	166	
23	LEA	10:10	803.8596 mg	1.0703	20670.82	25.88	689	53956	Filled	161	Run - 113
24	LEA	10:00	804.8753 mg	1.0157	20694.70	23.88	709	54013	Filled	180	Run - 105
25	LEA	9:20	805.8372 mg	.9619	20717.43	25.23	690	54068	Filled	190	
26	LEA	9:00	806.7787 mg	.9415	20740.64	22.71	691	54121	Filled	190	Run - 83
27	LEA	8:05	807.7378 mg	.9591	20763.71	23.07	693	54176	Filled	183	Run - 88
28	LEA	9:10	808.7842 mg	1.0464	20789.73	25.07	696	54235	Filled	167	Run - 93
29	LEA	8:05	809.7385 mg	.9543	20811.72	22.94	693	54289	Filled	190	Run - 89
30	LEA	9:17	810.7976 mg	1.0591	20836.90	25.18	701	54349	Filled	180	Run - 93
31											

Com' its:

Phelan Pinon Hills Community Service District

WTH: October
YEAR: 2011
SITE: W-14

Well Log

Last months Flow read: 810,797.6 mg

Hour read: 20836.90

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	12:17	811,943.1 mg	1,145.5	20863.89	26.99	707	100°	00613	Filled	160	1 drop per 3 sec.
2	EPA	10:27	812,870.1 mg	927	20866.10	22.21	696	98°	00605	Filled	173	22; Dripped
3	LEA	8:05	813,773.4 mg	903.3	20907.71	21.61	697	83°	00716	Filled	170	
4	LEA	8:15	814,782.2 mg	1,008.8	20931.88	24.17	696	83°	00773	Filled	166	
5	LEA	8:25	815,736.6 mg	954.4	20954.65	22.77	699	73°	00827	Filled	162	
6	LEA	8:30	816,750.5 mg	1,013.9	20978.71	24.06	702	67°	00885	Filled	185	
7	CS	9:20	817,813.8 mg	1,063.3	21003.71	25.00	703	63°	00944	Filled	161	
8	CC	9:33	818,767.2 mg	943.4	21026.11	22.4	709	73°	00998	Filled	161	
9	CC	9:47	819,753.1 mg	988.9	21049.55	22.44	701	73°	1053	Filled	167	Discontinued Report
10	LEA	9:17	820,630.2 mg	877.1	21070.63	21.08	693	85°	01103	Filled	160	Air Compressor
11	LEA	8:47	821,534.3 mg	904.1	21092.09	21.46	702	82°	01154	Filled	169	
12	LEA	8:28	822,525.8 mg	991.5	21115.77	23.68	698	85°	01210	Filled	165	Flush Blows off
13	LEA	8:25	823,523.1 mg	997.3	21139.72	23.95	694	96°	01267	Filled	173	WASH
14	LEA	10:07	824,583.9 mg	1,070.8	21165.43	25.71	694	103°	01328	Filled	200	
15	TS	12:37	825,638.8 mg	1,044.9	21190.39	27.45	694	91°	1387	Filled	187	
16	JS	9:30	826,488.6 mg	849.8	21210.74	20.35	695	87°	1435	Filled	175	
17	LEA	9:32	827,460.2 mg	971.6	21233.99	25.25	694	95°	01490	Filled	173	
18	LEA	10:30	828,482.5 mg	1,022.3	21258.57	24.58	693	103°	01548	Filled	185	
19	LEA	8:13	829,394.3 mg	911.8	21280.29	21.72	700	87°	01599	Filled	166	
20	LEA	8:15	830,297.2 mg	902.9	21301.95	21.66	695	79°	01650	Filled	180	Deaired moisture from Air Compressor
21	CC	8:32	831,312.3 mg	1,015.1	21326.20	24.75	698	73°	1708	Filled	160	
22	CC	9:38	832,305.7 mg	993.4	21349.90	23.7	699	73°	1764	Fill	160	
23	LEA	12:30	833,419.4 mg	1,115.7	21376.61	24.77	693	90°	1827	Filled	160	
24	LEA	8:35	834,273.9 mg	854.5	21396.88	20.21	705	94°	01875	Filled	166	
25	LEA	9:25	835,313.9 mg	1,040.0	21421.72	24.84	698	83°	01934	Filled	190	
26	LEA	9:50	836,294.3 mg	980.4	21445.13	23.41	698	87°	01989	Filled	153	
27	LEA	8:50	837,278.5 mg	1,004.2	21469.16	24.03	696	76°	02046	Filled	168	
28	LEA	9:05	838,317.5 mg	1,019.0	21493.35	24.19	702	81°	02103	Filled	158	
29	EPA	1:30	839,303.0 mg	984.5	21516.95	23.5	698	83°	02159	Filled	169	
30	LEA	7:55	839,999.3 mg	697.3	21533.42	16.57	701	91°	02198	Filled	168	
31	LEA	8:50	840,969.3 mg	970.0	21556.50	23.08	700	89°	02253	Filled	195	

Comments: 10/29 Pms EPA/LEA

Phelan Pinon Hills Community Service District
Well Log

MONTH: November
YEAR: 2011
SITE: W-14

Hour read: 21556.50

Last months Flow read: 840,969.3 mg

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:45	841,930.5 mg	.9612	21579.28	22.78	703	84°	02307	Filled	160	Flushed Blow off at wash
2	LEA	9:35	842,905.8 mg	.9753	21602.43	23.15	702	72°	02362	Filled	170	
3	LEA	9:10	843,808.2 mg	.9024	21623.94	21.51	699	76°	02413	Filled	184	
4	DS	9:20	844,777 mg	.9199	21645.41	21.47	707	-	02464	Filled	199	
5	DS	9:35	845,821.9 mg	1.0547	21671.27	23.48	711	60°	7525	Filled	154	
6	DS	9:35	846,649.4 mg	.8275	21690.54	19.29	715	62°	2571	Filled	155	
7	LEA	9:25	847,398.0 mg	.7486	21708.17	17.61	708	66°	02613	Filled	162	
8	LEA	8:00	848,179.7 mg	.7817	21726.48	18.31	712	60°	02657	Filled	199	Flushed Blow off at wash
9	LEA	9:00	849,089.6 mg	.9089	21747.73	21.25	714	60°	02707	Filled	189	
10	LEA	10:00	850,019.8 mg	.9302	21769.31	21.58	718	74°	02759	Filled	170	
11	DS	9:30	850,005.0 mg	.7853	21787.73	18.42	711	64°	2803	Filled	170	
12	DS	7:45	851,500.3 mg	.7607	21806.31	17.58	721	64°	2845	Filled	145	
13	TC	10:32	852,501.9 mg	.9356	21827.22	21.91	711	-	2897	Filled	168	
14	LEA	10:10	853,379.1 mg	.8772	21847.64	20.42	716	78°	02946	Filled	150	
15	LEA	7:40	854,197.2 mg	.8181	21866.11	18.47	738	68°	02991	Filled	150	Flushed Blow off at wash
16	LEA	9:18	855,224.6 mg	1.0374	21889.80	23.69	730	85°	03047	Filled	168	
17	LEA	9:05	856,121.9 mg	.8873	21910.57	20.77	712	98°	03097	Filled	186	
18	DS	9:00	857,200.8 mg	1.0839	21936.01	25.44	710	83°	454	Filled	156	
19	DS	9:26	857,354.3 mg	.6435	21951.12	15.11	715	95°	3144	Filled	163	
20	DS	9:10	858,645.7 mg	.7914	21969.78	18.64	706	82°	3239	Filled	149	Flushed Blow off at wash
21	LEA	8:45	859,478 mg	.8261	21989.05	19.27	714	90°	03284	Filled	150	
22	LEA	8:20	860,364.9 mg	.8931	22009.84	20.79	716	90°	03334	Filled	150	
23	LEA	7:50	861,224.6 mg	.8597	22029.65	19.81	723	89°	03381	Filled	156	
24	LEA	9:50	862,116.1 mg	.8915	22050.50	20.85	713	85°	03431	Filled	195	
25	LEA	10:25	862,926.8 mg	.8107	22069.40	18.90	715	85°	03477	Filled	155	
26	CPA	9:31	863,829.7 mg	.9029	22090.17	20.77	724	93°	03526	Filled	169	
27	CPA	9:27	864,723.9 mg	.8947	22109.94	20.77	718	78°	03576	Filled	178	
28	LEA	8:30	865,626.0 mg	.9021	22131.72	20.78	724	67°	03626	Filled	165	
29	LEA	9:10	866,522.5 mg	.8965	22152.77	21.05	710	72°	03676	Filled	170	
30	LEA	9:25	867,417 mg	.8892	22173.58	20.81	712	92°	03725	Filled	170	
31												

Comments: Repaired water leak in Chlorinator Re 11/2

11/6

Phelan Pinon Hills Community Service District
Well Log

M' TH: December
YEAR: 2011
SITE: W-14

Last months Flow read: 867.4117 mg Hour read: 22173.58

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	CEA	8:45	868.3424 mg	.9307	22194.97	21.39	725	60°	03776	Filled	156	
2	CE	8:23	869.0940 mg	.7516	22212.13	17.46	717	71°	3818	"	160	
3	CS	8:45	870.0326 mg	.9428	22230.13	21.76	722	70°	3870	Filled	150	
4	CS	9:45	870.7297 mg	.8731	22259.93	26.13	711	71°	3920	Filled	150	
5	CS	10:00	871.7917 mg	.8618	22275.37	26.47	704	60°	3968	Filled	154	
6	CEA	9:00	872.6522 mg	.8605	22295.45	30.13	712	64°	04016	Filled	163	
7	CS	8:30	873.5133 mg	.8611	22315.00	30.13	713	60°	4064	Filled	156	
8	CEA	8:50	874.3497 mg	.8964	22334.86	19.28	723	65°	04110	Filled	163	
9	CEA	8:40	875.2112 mg	.8615	22354.70	19.84	724	72°	04158	Filled	167	
10	CS	9:30	875.9240 mg	.7138	22371.17	16.47	721	61°	4198	Filled	155	
11	CE	11:30	876.8188 mg	.8748	22392.07	20.90	713	-	4248	Filled	156	
12	CS	10:00	877.4084 mg	.7576	22410.13	19.02	729	60°	4271	Filled	155	Flushed S.O.
13	CEA	9:30	878.2667 mg	.6583	22425.49	15.36	714	53°	04328	Filled	153	Well not running
14	CS	9:30	879.0937 mg	.8270	22444.57	19.03	722	-	4314	Filled	145	Alarm Test
15	CEA	9:25	879.8498 mg	.7561	22462.33	17.76	710	65°	04416	Filled	167	
16	CS	10:00	880.6386 mg	.7885	22480.57	18.24	721	64°	4460	Filled	150	
17	CS	9:15	881.3058 mg	.7270	22497.20	16.13	729	59°	4500	Filled	165	
18	CS	9:31	882.1488 mg	.7530	22515.10	17.19	729	61°	4543	Filled	180	
19	CS	9:30	883.0709 mg	.9221	22536.22	21.12	728	68°	4594	Filled	150	
20	CEA	8:45	883.7952 mg	.7243	22553.20	16.98	711	64°	04634	Filled	195	
21	CS	10:00	884.7397 mg	.9445	22574.81	21.11	728	150°	4636	Filled	150	
22	CEA	8:15	885.4378 mg	.6981	22591.10	16.29	714	50°	04725	Filled	170	
23	CEA	11:06	886.4251 mg	.9873	22613.65	22.55	730	58°	04779	Filled	156	
24	CEA	9:30	887.1977 mg	.7726	22631.53	17.88	720	60°	04822	Filled	182	
25	CEA	9:40	888.1095 mg	.9118	22652.69	31.16	718	78°	04873	Filled	158	
26	CEA	10:10	888.8576 mg	.7481	22670.08	17.39	717	64°	04915	Filled	174	
27	CEA	8:40	889.6865 mg	.7689	22687.93	17.85	718	64°	04958	Filled	163	
28	CEA	9:15	890.5013 mg	.8748	22708.13	20.2	722	65°	05007	Filled	150	
29	CEA	9:45	891.4721 mg	.9708	22730.46	22.33	725	83°	05060	Filled	150	
30	CS	9:30	892.1957 mg	.7231	22747.35	16.59	714	121°	5101	Filled	170	
31	CS	8:45	893.0481 mg	.8529	22766.85	19.5	729	-	5148	Filled	160	

Comments:

Phelan Pinon Hills Community Service District

ONTH: January
 YEAR: 2012
 SITE: W-14

Well Log

Last months Flow read: 893.0481 mg

Hour read: 22166.55

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	CC	9:08	893.9562 mg	.9081	22788.91	21.36	709	71.6	5199	Filled	150	
2	CC	8:49	894.7153 mg	.7591	22865.55	17.52	722	63.1	5241	Filled	169	
3	CS	9:10	895.5587 mg	.9434	22855.22	19.53	720	-	5288	Filled	165	
4	CS	10:00	896.5207 mg	.9620	22843.42	22.32	722	127	5342	Filled	181	
5	LEA	8:05	897.2557 mg	.7350	22864.61	17.13	715	89	05283	Filled	176	
6	LEA	8:50	898.1209 mg	.8652	22884.67	20.06	719	89	05431	Filled	169	
7	CS	9:40	898.9864 mg	.8655	22904.59	19.92	704	89	5479	Filled	185	
8	CC	12:24	899.7919 mg	.8055	22923.45	16.86	746	-	5524	Filled	158	
9	CS	10:00	900.5335 mg	.7410	22940.66	17.23	717	89	5566	Filled	186	
10	LEA	8:25	901.2148 mg	.6813	22956.48	15.8	719	89	05604	Filled	170	
11	CS	8:40	901.9570 mg	.7422	22973.82	17.34	713	127	5646	Filled	170	
12	LEA	8:30	902.8050 mg	.8480	22993.47	19.65	719	89	05693	Filled	150	
13	CS	10:30	903.6487 mg	.5437	23003.10	19.65	704	-	5740	Filled	160	
14	CS	10:30	904.4064 mg	.8207	23011.77	19.59	725	-	5787	Filled	168	
15	LEA	11:00	905.3311 mg	.9780	23028.80	16.45	705	89	5834	Filled	165	
16	LEA	9:20	905.5428 mg	.6039	23066.58	19.59	705	70	5848	Filled	170	
17	CS	9:00	906.7878 mg	.8450	23080.53	19.65	717	110	5916	Filled	95	
18	CS	11:00	907.5106 mg	.7222	23093.10	16.89	710	-	5956	Filled	192	Flushed Blow off at 192
19	LEA	10:30	908.1433 mg	.6327	23117.83	14.71	717	89	05992	Filled	158	
20	LEA	8:45	908.9076 mg	.7643	23135.79	17.96	709	89	06035	Filled	188	
21	LEA	8:56	909.8604 mg	.9528	23157.53	21.74	730	89	06087	Filled	150	
22	LEA	9:20	910.6093 mg	.7489	23175.12	17.59	710	89	06130	Filled	176	
23	CS	9:00	911.2994 mg	.6401	23191.32	16.8	697	113	6169	Filled	160	
24	LEA	8:05	912.1615 mg	.8621	23211.53	19.41	722	89	06217	Filled	150	
25	CS	10:00	913.0639 mg	.9024	23232.21	20.68	727	112	6247	Filled	157	
26	LEA	8:30	913.8854 mg	.8215	23250.66	18.45	742	89	06311	Filled	157	
27	LEA	9:00	914.6114 mg	.7260	23267.77	16.91	715	89	6352	Filled	199	
28	CC	8:54	915.4019 mg	.7905	23285.83	18.26	722	71.2	6396	Filled	151	
29	CC	10:24	916.2269 mg	.8240	23305.21	19.38	709	-	6443	Filled	160	system is paying better
30	CS	1:45	917.0884 mg	.8415	23325.32	20.11	714	143	6491	Filled	157	
31	LEA	8:55	917.8512 mg	.7628	23343.15	17.83	713	89	06534	Filled	183	

Comments:

Phelan Pinon Hills Community Service District
Well Log

VTH: February
YEAR: 2012
SITE: W-14

Last months Flow read:

917.8512 mg

Hour read: 23343.15

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	BS	10:00	918.7418 mg	.8996 mg	23353.98	23.84	712	—	1584	Filled	179	
2	LEA	8:10	919.4518 mg	.7100 mg	23380.58	16.59	713	52°	06624	Filled	189	
3	LEA	8:40	920.3715 mg	.9197 mg	23401.94	21.36	718	63°	06675	Filled	163	
4	BS	11:30	921.1817 mg	.8107 mg	23421.04	19.1	707	50°	06724	Filled	170	
5	TCL	11:12	922.0285 mg	1.8468 mg	23440.69	19.65	718	—	06769	Filled	165	
6	LEA	8:30	922.7023 mg	.6738 mg	23456.74	16.05	700	50°	06807	Filled	156	
7	LEA	8:10	923.3867 mg	.6844 mg	23473.12	16.38	696	50°	06846	Filled	195	
8	BS	9:30	924.2723 mg	.8856 mg	23494.92	21.8	715	127°	06877	Filled	190	
9	CC	8:14	925.1350 mg	.8847 mg	23513.83	18.91	716	68°	06944	Filled	167	
10	CC	8:20	926.0197 mg	.8847 mg	23534.34	20.51	719	71°	06994	Filled	195	
11	BS	11:20	926.9205 mg	.9008 mg	23555.47	21.09	712	110°	07044	Filled	119	
12	BS	11:00	927.6473 mg	.7468 mg	23572.03	17.5	711	50°	07086	Filled	190	
13	LEA	8:10	928.3723 mg	.7050 mg	23589.58	16.65	706	61°	07126	Filled	158	
14	LEA	8:45	929.1036 mg	.7313 mg	23607.29	17.71	688	48°	07169	Filled	180	Flushed Blowoff/wash
15	LEA	8:25	929.9460 mg	.8424 mg	23626.31	19.02	738	52°	07215	Filled	180	
16	BS	11:00	930.5633 mg	.6173 mg	23643.87	17.00	700	—	07254	Filled	160	
17	LEA	9:10	931.3963 mg	.7330 mg	23660.11	16.72	731	50°	07296	Filled	162	
18	LEA	8:50	932.2956 mg	.8993 mg	23680.25	20.14	744	70°	07345	Filled	152	
19	LEA	9:00	933.0363 mg	.7407 mg	23697.33	17.08	723	04°	07387	Filled	145	
20	EPA	11:02	933.9786 mg	.9423 mg	23713.72	21.29	734	54°	07438	Filled	162	
21	LEA	8:30	934.7620 mg	.7834 mg	23736.59	17.87	731	50°	07481	Filled	190	
22	BS	1:00	935.8826 mg	1.1200 mg	23761.99	25.9	735	74°	7542	Filled	200	
23	BS	10:30	936.6842 mg	.8016 mg	23780.29	18.3	730	43°	7587	Filled	195	
24	BS	10:50	937.4203 mg	.9411 mg	23802.70	21.91	720	138°	7639	Filled	175	
25	CC	9:32	938.4975 mg	.8677 mg	23822.34	20.14	718	21	7687	Filled	183	
26	CC	9:16	939.4530 mg	.9555 mg	23844.49	22.15	696	50°	7741	Filled	151	
27	LEA	9:40	940.5074 mg	1.0644 mg	23868.94	24.45	719	60°	07799	Filled	150	
28	CC	8:30	941.3766 mg	.8692 mg	23883.87	19.93	727	54°	7847	Filled	190	
29	LEA	8:27	942.1091 mg	.7325 mg	23905.99	17.12	713	58°	07888	Filled	150	
30												
31												

Comments:

186

186

Phelan Pinon Hills Community Service District

MONTH: Mar. 2012
YEAR: 2012
SITE: W-14

Well Log

Last months Flow read: 942.1091 mg

Hour read: 2390.5.99

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:08	943.0555	9464	23927.54	21.55	732	55.9	7940	Filled	155	
2	LEA	9:00	944.0224 mg	9469	23949.71	22.17	710	57°	7993	Filled	188	
3	LEA	10:30	945.0210 mg	9486	23972.64	22.93	726	62°	8048	Filled	172	
4	LEA	11:00	946.0359 mg	1,0149	23996.02	23.38	723	—	8104	Filled	190	
5	LEA	8:30	946.8420 mg	8061	24014.86	18.84	713	78°	8149	Filled	200	
6	LEA	8:45	947.7535 mg	9115	24035.98	21.12	696	74.3°	8199	Filled	160	
7	LEA	9:12	948.7287 mg	9752	24058.37	22.39	726	57.3°	8253	Filled	156	
8	LEA	10:01	949.6326 mg	9757	24080.61	22.34	715	63.5°	8306	Filled	187	
9	LEA	8:53	950.5557 mg	8731	24106.96	20.35	715	76.4°	8354	Filled	158	
10	LEA	12:00	951.6317 mg	1,0755	24176.66	25.1	714	—	8414	Filled	160	
11	LEA	10:31	952.9407 mg	8295	24194.53	19.41	710	73.3°	8465	Filled	160	
12	LEA	10:19	953.3596 mg	8784	24166.41	20.83	718	74°	8510	Filled	200	
13	LEA	8:01	954.1730 mg	8154	24185.52	19.11	709	64.1°	8556	Filled	150	
14	LEA	9:10	955.1367 mg	9637	24207.76	22.24	722	68.8°	8609	Filled	159	
15	LEA	9:00	956.0332 mg	8965	24223.66	20.84	717	126°	8658	Filled	154	
16	LEA	9:00	956.9242 mg	901	24244.45	20.35	720	122°	8703	Filled	150	
17	LEA	10:08	957.9864 mg	1,0572	24273.03	24.21	724	117°	8764	Filled	110	
18	LEA	10:25	958.8236 mg	8372	24292.72	19.66	732	111°	8811	Filled	161	
19	LEA	9:30	959.1354 mg	8118	24311.29	18.12	727	78°	8860	Filled	160	
20	LEA	8:50	960.6000 mg	9646	24333.39	21.95	732	68°	8909	Filled	164	
21	LEA	8:30	961.4649 mg	8649	24353.10	19.71	731	67°	8956	Filled	155	
22	LEA	8:30	962.3817 mg	9168	24374.32	21.22	720	67°	8907	Filled	165	
23	LEA	8:45	963.2746 mg	8929	24394.94	20	744	71°	8956	Filled	168	
24	LEA	10:50	964.2259 mg	9552	24417.09	22.1	720	—	9009	Filled	165	
25	LEA	12:30	965.2066 mg	9480	24431.71	22.62	720	—	9063	Filled	149	9747
26	LEA	9:00	965.9543 mg	9477	24456.88	17.17	726	68°	9104	Filled	154	Flushed Bleed off/wash
27	LEA	9:20	966.7592 mg	8049	24475.39	18.51	725	70°	9149	Filled	150	
28	LEA	8:35	967.5539 mg	7947	24492.45	18.06	733	72°	9192	Filled	172	
29	LEA	8:25	968.4375 mg	8836	24513.76	20.31	725	68°	9241	Filled	156	
30	LEA	8:50	969.3964 mg	9589	24535.84	22.08	724	68°	9293	Filled	166	
31	LEA	10:15	970.2755 mg	8791	24556.46	20.56	712	62°	9343	Filled	170	

Comments:

Page 1

Phelan Pinon Hills Community Service District

MONTH: April
YEAR: 2012
SITE: W-14

Well Log

Flow read: 970.2755 mg

Hour read: 24555.40

Rate	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	35	10:30	971.0058 mg	970.7 mg	24575.55	19.15	722	54	9483	Filled	185	
2	LEA	8:40	971.9796 mg	.8738 mg	24595.87	20.32	717	620	9537	Filled	152	
3	LEA	8:30	972.9201 mg	.9405 mg	24617.63	21.76	720	620	9589	Filled	153	SWEETPOINT Chlorinator Ln
4	LEA	8:10	973.8402 mg	.9201 mg	24639.25	21.62	709	630	9640	Filled	155	
5	LEA	8:05	974.8285 mg	.9883 mg	24662.22	22.97	717	570	9695	Filled	152	
6	LEA	8:17	975.7696 mg	.9141 mg	24684.23	22.51	713	52.1	9747	Filled	149	
7	LEA	8:09	976.6793 mg	.9077 mg	24705.38	21.15	717	68	9797	Filled	156	
8	LEA	10:00	977.6411 mg	.9689 mg	24727.83	22.45	714	750	9851	Filled	176	
9	LEA	9:30	978.6580 mg	1.0169 mg	24751.51	23.68	716	800	9908	Filled	158	Flushed Blow off
10	LEA	8:30	979.6291 mg	.9711 mg	24774.07	22.56	717	740	9961	Filled	156	
11	LEA	8:25	980.6629 mg	1.0338 mg	24797.98	23.91	721	610	10018	Filled	163	
12	LEA	8:25	981.5896 mg	.9267 mg	24819.30	21.32	724	820	10069	Filled	150	
13	LEA	8:30	982.5240 mg	.9344 mg	24840.91	21.61	721	850	10120	Filled	155	DEED:107
14	LEA	10:55	983.5031 mg	.9791 mg	24863.69	22.78	716	54	10175	Filled	163	
15	LEA	10:58	984.4619 mg	.9588 mg	24885.56	21.87	731	24	10227	Filled	167	
16	LEA	8:55	985.2624 mg	.8005 mg	24904.15	18.59	718	720	10271	Filled	175	
17	LEA	9:55	986.2151 mg	.9527 mg	24926.35	22.20	715	820	10324	Filled	162	
18	LEA	9:05	987.1380 mg	.9179 mg	24947.66	21.31	718	780	10375	Filled	181	
19	LEA	8:05	987.9854 mg	.8524 mg	24967.98	20.32	699	824	10423	Filled	158	
20	NB	9:27	988.4943 mg	1.0089 mg	24991.53	23.55	714	840	10479	Filled	160	
21	LEA	9:25	990.0211 mg	1.0263 mg	25015.62	24.09	717	920	10536	Filled	160	
22	LEA	8:31	990.9967 mg	.9756 mg	25038.73	23.11	703	—	10591	Filled	150	703 GPM
23	AM	9:30	992.0444 mg	1.0477 mg	25063.70	24.97	699	880	10650	Filled	185	
24	AM	8:10	993.0173 mg	.9729 mg	25086.50	22.8	711	820	10704	Filled	155	
25	NB	8:50	994.0667 mg	1.0734 mg	25111.10	24.6	707	840	10762	Filled	162	
26	LEA	8:28	994.9580 mg	.8973 mg	25132.80	21.7	689	710	10812	Filled	151	
27	AM	8:54	996.0086 mg	1.0500 mg	25157.14	24.39	719	80	10870	Filled	150	
28	LEA	10:00	997.6604 mg	1.0518 mg	25181.96	24.77	707	80	10929	Filled	172	
29	LEA	9:20	998.0191 mg	.9587 mg	25204.73	22.77	707	—	10983	Filled	150	
30	LEA	8:43	998.9944 mg	.9753 mg	25227.90	23.17	702	89	11037	Filled	182	
31												

Comments:

Phelan Pinon Hills Community Service District
Well Log

MONTH: May
YEAR: 2012
SITE: W-14

Last months Flow read: 998.9944 mg Hour read: 2522.790

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	NEA	8:24	999.9978 mg	1.0034	25251.53	23.63	708	83.9	110.3	Filled	155	OUT WEEPS
2	LEA	8:17	1000.9006 mg	.99038 mg	25272.84	21.31	706	80	111.4	Filled	160	
3	LEA	8:03	1001.9024 mg	1.0016	25296.23	23.59	714	78.8	111.9	Filled	150	
4	LEA	8:53	1002.8361 mg	0.9834	25319.48	23.25	705	86	112.5	Filled	175	
5	LEA	1:02	1004.0011 mg	1.1150	25346.47	20.67	147	~	113.1	Filled	162	
6	LEA	8:17	1004.5759 mg	.9735	25371.82	20.13	706	76	113.6	Filled	165	
7	DS	9:30	1005.8631 mg	.9882	25390.64	23.70	695	89	114.2	Filled	200	
8	DS	8:20	1006.8312 mg	.9765 mg	25413.57	22.93	704	85	114.7	Filled	171	Slugged filter
9	LEA	8:12	1007.7721 mg	.9409 mg	25436.22	22.65	692	91	115.30	Filled	171	
10	LEA	8:17	1008.6637 mg	.8747 mg	25463.96	21.94	688	84	115.80	Filled	172	
11	LEA	8:30	1009.6772 mg	1.0304 mg	25481.101	24.21	709	87	116.37	Filled	174	
12	LEA	8:32	1010.6370 mg	.9759 mg	25504.79	23.16	690	87	116.51	Filled	165	
13	LEA	10:05	1011.7384 mg	1.1014 mg	25531.19	26.4	695	92	117.54	Filled	161	
14	LEA	8:30	1012.7725 mg	1.0401 mg	25556.65	25.46	681	95	118.3	Filled	180	
15	LEA	8:08	1013.6307 mg	.8521 mg	25577.19	20.54	691	88	118.62	Filled	165	
16	LEA	8:50	1014.6486 mg	1.0180 mg	25600.93	24.74	686	92	119.9	Filled	166	
17	LEA	8:15	1015.6209 mg	.9723 mg	25625.33	23.40	693	89	119.74	Filled	163	
18	NEA	8:24	1016.5780 mg	0.9571 mg	25648.37	23.04	692	85	120.29	Filled	155	Pressure switch 3300
19	LEA	9:22	1017.5915 mg	1.0135 mg	25673.07	24.7	684	85.4	120.87	Filled	160	
20	LEA	8:20	1018.5722 mg	.9920 mg	25692.10	23.09	688	~	121.41	Filled	176	
21	LEA	8:47	1019.5341 mg	.9919 mg	25720.46	24.36	679	96	121.98	Filled	167	Pressure switch 3300
22	LEA	8:10	1020.4915 mg	.9757 mg	25743.79	23.33	684	89	122.53	Filled	172	Pressure switch 3300
23	LEA	8:15	1021.4839 mg	.9924 mg	25767.95	24.16	685	82	123.09	Filled	172	
24	LEA	8:02	1022.4576 mg	.9757 mg	25791.123	23.68	685	81.5	123.65	Filled	170	
25	LEA	8:05	1023.4154 mg	.9578 mg	25814.94	23.31	685	82	124.20	Filled	190	Pressure switch 3300
26	LEA	9:45	1024.4681 mg	1.0527 mg	25840.22	25.26	694	90	124.79	Filled	181	Pressure switch 3300
27	LEA	10:00	1025.5677 mg	1.0996 mg	25866.58	26.38	695	91	125.47	Filled	169	
28	LEA	8:20	1026.5316 mg	.9757 mg	25892.11	23.57	690	88	125.97	Filled	171	
29	LEA	9:15	1027.4378 mg	.9659 mg	25911.89	23.48	686	91	126.48	Filled	172	
30	LEA	8:40	1028.4125 mg	.9747 mg	25935.35	23.46	692	90	127.04	Filled	190	
31	LEA	8:10	1029.3768 mg	.9390 mg	25958.84	23.49	666	95	127.59	Filled	161	

Comments: PM Done 5/8/12, 05:45, LEA 9/25 need

MONTH: June
YEAR: 2012
SITE: W-14

Phelan Pinon Hills Community Service District

Well Log

Last months Flow read: 1059.3768 MG

Hour read: 25558.84

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	NB	8:54	1030.3983 MG	1.0215 MG	25483.60	24.76	688	104.3	12817	Filled	165	
2	EA	9:00	1031.5717 MG	1.1764 MG	26067.63	24.83	689	112	12878	Filled	160	
3	EA	11:40	1032.4935 MG	1.0184 MG	26034.39	24.76	686	-	12936	Filled	161	
4	EA	8:25	1033.3418 MG	.8483 MG	26055.06	20.67	684	85°	12985	Filled	161	FAIL TO START
5	EA	9:05	1034.3309 MG	.9891 MG	26079.23	24.17	682	off	13042	Filled	189	CLAY/FIL
6	EA	8:05	1035.0834 MG	.7525 MG	26098.54	19.31	649	92°	13087	Filled	151	
7	EA	9:05	1036.1187 MG	1.0353 MG	26123.57	25.03	689	84°	13146	Filled	168	FLUSHED BLOW OFF
8	EA	9:10	1037.0572 MG	.9185 MG	26147.61	24.04	678	87°	13252	Filled	167	AT WASH
9	JS	10:00	1038.0568 MG	.9188 MG	26170.97	23.36	674	72°	13257	Filled	182	
10	EA	10:45	1039.1401 MG	1.0843 MG	26197.25	26.28	681	-	13319	Filled	181	
11	EA	8:20	1040.0099 MG	.8698 MG	26218.78	21.53	673	98°	13369	Filled	178	
12	EA	3:15	1040.9810 MG	.9711 MG	26242.67	25.24	677	96°	13425	Filled	170	
13	EA	8:20	1041.9805 MG	.9995 MG	26266.79	24.12	691	95°	13482	Filled	180	
14	EA	8:44	1042.9715 MG	1.0108 MG	26290.65	24.86	692	86°	13539	Filled	170	
15	EA	8:50	1044.0019 MG	1.0314 MG	26315.29	24.53	704	88.1°	13577	Filled	165	
16	EA	9:01	1045.0335 MG	1.0143 MG	26339.79	24.56	695	93.8°	13665	Filled	160	
17	EA	7:25	1045.9285 MG	.8950 MG	26361.91	22.12	674	-	13706	Filled	185	
18	EA	9:10	1047.0020 MG	1.0735 MG	26387.60	25.69	696	98°	13767	Filled	156	
19	EA	8:25	1047.9803 MG	.9783 MG	26410.92	23.32	699	100°	13822	Filled	169	
20	EA	8:20	1048.9913 MG	1.0110 MG	26434.78	23.86	706	98°	13878	Filled	156	
21	EA	8:25	1049.9922 MG	1.0009 MG	26458.88	24.10	692	99°	13935	Filled	156	
22	EA	9:25	1051.0349 MG	1.0427 MG	26483.90	25.02	695	93°	13994	Filled	160	
23	JS	10:40	1052.0261 MG	.9912 MG	26507.95	24.05	687	92°	14050	Filled	167	
24	EA	9:40	1053.0483 MG	1.0212 MG	26532.61	24.69	690	90°	14108	Filled	160	
25	EA	7:50	1053.9490 MG	.9007 MG	26554.33	21.69	692	88°	14159	Filled	157	
26	EA	8:40	1054.9787 MG	1.0296 MG	26579.10	24.84	690	99°	14218	Filled	160	
27	EA	8:06	1055.9434 MG	.9641 MG	26602.51	23.33	689	88°	14272	Filled	155	
28	EA	8:20	1056.9513 MG	1.0071 MG	26626.80	24.89	697	93°	14327	Filled	167	
29	EA	9:16	1057.9912 MG	1.0404 MG	26651.60	24.86	698	94°	14388	Filled	156	
30	EA	10:20	1059.0561 MG	1.0639 MG	26676.81	25.15	705	-	14448	Filled	156	
31												

Comments: 6-5 Replaced 2 times (only) 6-23 electrical shock - run panel 6-23 Edison outside Door 125° inside 97° to 104°

Phelan Pinon Hills Community Service District

MONTH: July
YEAR: 2012
SITE: W-14

Well Log

Last months Flow read: 1057.0561

Hour read: 26676.81

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	12:00	1066.1340	1077.9	26710.271	26710.271	704	95°	14100	Filled	155	
2	LEA	9:10	1066.10239	838.9	26712.355	26712.355	698	88°	14358	Filled	155	
3	LEA	8:19	1066.19813	957.4	26746.69	26746.69	690	87°	14612	Filled	152	
4	LEA	9:21	1066.0838	1042.6	26771.53	26771.53	698	90°	14671	Filled	150	GREASED MOTOR DERIVED COMPRESSOR MOISTURE
5	LEA	8:43	1063.9987	974.8	26794.93	26794.93	696	98°	14726	Filled	150	
6	LEA	11:20	1065.1278	1129.1	26821.57	26821.57	706	101°	14789	Filled	149	
7	LEA	12:43	1066.1619	1031.1	26846.85	26846.85	682	101°	14848	Filled	162	
8	LEA	10:07	1067.0391	877.2	26868.36	26868.36	680	93°	14898	Filled	161	
9	LEA	8:58	1067.9657	926.6	26891.18	26891.18	677	103°	14952	Filled	161	
10	LEA	8:05	1068.9151	949.4	26914.33	26914.33	684	107°	15006	Filled	162	
11	LEA	8:25	1069.9004	985.3	26938.67	26938.67	675	107°	15063	Filled	161	
12	LEA	7:50	1070.7699	869.5	26960.09	26960.09	677	100°	15113	Filled	166	
13	LEA	8:08	1071.7011	913.3	26983.36	26983.36	667	83°	15167	Filled	160	
14	LEA	10:19	1072.7830	1081.8	27004.54	27004.54	659	98°	15228	Filled	160	
15	LEA	8:25	1073.6734	890.4	27031.70	27031.70	664	—	15280	Filled	162	
16	LEA	9:35	1074.6862	1012.8	27056.84	27056.84	671	90°	15388	Filled	188	
17	LEA	8:51	1075.6257	939.5	27080.10	27080.10	673	103°	15343	Filled	184	
18	LEA	8:55	1076.5026	876.9	27106.98	27106.98	668	90°	15444	Filled	168	Flushed BO at
19	LEA	8:50	1077.4585	955.9	27125.86	27125.86	667	92°	15499	Filled	163	WASH
20	LEA	9:20	1078.4489	989.4	27150.33	27150.33	671	89°	15556	Filled	180	
21	LEA	11:05	1079.4604	1016.5	27175.63	27175.63	669	103°	15615	Filled	190	
22	LEA	11:00	1080.4317	971.3	27199.72	27199.72	671	112°	15671	Filled	148	
23	LEA	8:50	1081.3369	905.2	27221.87	27221.87	681	91°	15723	Filled	161	
24	LEA	8:25	1082.2952	958.3	27245.46	27245.46	677	91°	15778	Filled	166	
25	LEA	8:10	1083.2535	953.3	27269.31	27269.31	670	85°	15834	Filled	155	
26	LEA	8:50	1084.2559	1002.4	27293.87	27293.87	680	93°	15892	Filled	162	
27	LEA	8:51	1085.2344	917.8	27317.91	27317.91	678	83°	15948	Filled	161	
28	LEA	11:00	1086.1568	922.1	27340.73	27340.73	674	90°	16001	Filled	157	
29	LEA	12:00	1087.2192	1062.4	27366.76	27366.76	680	101°	16062	Filled	200	
30	LEA	8:20	1088.0408	821.6	27387.14	27387.14	672	88°	16110	Filled	188	
31	LEA	9:05	1088.9661	925.3	27410.36	27410.36	664	95°	16164	Filled	161	

ments: 7-5 Flushed BO at wash 7-30

Phelan Pinon Hills Community Service District
Well Log

ONTH: August
YEAR: 2012
SITE: W-14

Last months Flow read:

1088.9661 mg

Hour read: 27410.36

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Run	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:43	1089.9291 mg	9680 mg	27433.95	23.59	680	92°	16219	Filled	162	
2	LEA	8:50	1090.8956 mg	9665 mg	27452.72	23.77	678	93°	16275	Filled	154	
3	LEA	9:05	1091.9013 mg	10057 mg	27482.31	24.59	682	103°	16332	Filled	168	
4	JS	10:00	1092.9043 mg	10033 mg	27506.39	24.08	694	123°	16389	Filled	165	
5	EPA	10:21	1093.8265 mg	0.9222 mg	27528.64	22.27	690	124°	16448	Filled	160	
6	LEA	9:10	1094.7517 mg	0.9252 mg	27551.39	22.73	678	106°	16495	Filled	185	FLUSH 15.0. AS WASH
7	LEA	8:10	1095.6736 mg	0.9219 mg	27574.38	22.99	668	102.5°	16549	Filled	156	
8	LEA	8:40	1096.6747 mg	1.0061 mg	27598.89	24.51	681	109°	16606	Filled	162	
9	LEA	8:25	1097.6834 mg	9587 mg	27622.64	23.75	673	109°	16662	Filled	185	
10	LEA	8:20	1098.6751 mg	0.0025 mg	27647.18	24.94	670	104.7°	16720	Filled	160	
11	JS	11:10	1099.6951 mg	1.0594 mg	27673.52	26.03	679	154°	16781	Filled	161	
12	EPA	9:46	1100.5193 mg	8242 mg	27699.27	26.69	664	160°	16829	Filled	160	
13	LEA	8:40	1101.4152 mg	8959 mg	27716.25	21.98	679	107°	16880	Filled	155	2004 162°
14	LEA	8:55	1102.3800 mg	9648 mg	27739.97	23.72	678	104°	16936	Filled	170	
15	LEA	8:50	1103.3535 mg	9473 mg	27763.90	23.93	678	—	16992	Filled	162	
16	JS	8:30	1104.3562 mg	9617 mg	27787.36	23.46	717	103°	17047	Filled	175	
17	LEA	9:10	1105.3151 mg	9999 mg	27811.66	24.30	686	108°	17104	Filled	157	
18	JS	8:30	1106.2134 mg	9023 mg	27833.43	21.77	690	101°	17156	Filled	150	
19	JS	1:55	1107.3167 mg	1.0993 mg	27859.91	26.48	671	101°	17218	Filled	180	
20	LEA	9:00	1108.2832 mg	9765 mg	27888.35	23.44	694	103°	17273	Filled	158	FLUSH 30.0. AS WASH
21	LEA	9:40	1109.2904 mg	9972 mg	27907.55	24.2	687	108°	17320	Filled	161	
22	LEA	9:25	1110.2717 mg	9813 mg	27931.32	23.97	688	94°	17386	Filled	158	
23	LEA	8:40	1111.2215 mg	9498 mg	27954.51	23.19	683	94°	17440	Filled	163	
24	LEA	9:00	1112.2245 mg	1.1608 mg	27976.66	24.15	690	109°	17497	Filled	159	
25	LEA	10:15	1113.2954 mg	1.0737 mg	28004.75	15.57	699	—	17558	Filled	157	
26	LEA	10:50	1114.3699 mg	1.0455 mg	28029.68	24.93	692	97°	17615	Filled	155	
27	LEA	8:57	1115.1910 mg	8381 mg	28049.95	21.27	690	89°	17665	Filled	155	
28	LEA	8:27	1116.1124 mg	9214 mg	28072.16	22.21	691	94°	17718	Filled	158	
29	LEA	8:35	1117.1168 mg	1.0044 mg	28096.28	24.12	694	107°	17774	Filled	157	
30	LEA	8:20	1118.0926 mg	9758 mg	28120.01	23.73	685	101°	17830	Filled	158	
31	LEA	9:35	1119.0161 mg	9235 mg	28142.25	22.24	692	94°	17883	Filled	165	

Comments:

Phelan Pinon Hills Community Service District
Well Log

MC Th: September
YEAR: 2012
SITE: W-14

Last months Flow read:

1119.616 MG

Hour read:

28142.25

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	TS	11:40	1120.0271 MG	1.011 MG	28166.31	24.00	700	167°	17940	✓	180	
2	CPA	9:16	1120.9084 MG	.888 MG	28187.82	21.51	682	166°	17970	✓	165	
3	CC	8:25	1121.7917 MG	.8833 MG	28209.53	21.76	677	161°	18041	Filled	155	
4	LEA	9:10	1122.8207 MG	1.0290 MG	28234.35	24.77	692	163°	18099	Filled	160	
5	LEA	8:55	1123.7964 MG	.9757 MG	28258.08	23.73	685	160°	18155	Filled	154	FUSED 200 BT WASH
6	LEA	9:55	1124.8000 MG	1.0036 MG	28282.48	24.40	686	161°	18212	Filled	162	
7	CC	8:35	1125.6307 MG	.8307 MG	28302.76	20.28	683	163°	18260	Filled	156	
8	CC	9:07	1126.6088 MG	.9781 MG	28320.37	23.56	692	164°	18316	Filled	148	
9	CC	8:54	1127.5317 MG	.9729 MG	28344.00	22.68	714	165°	18371	Filled	167	2000 677
10	LEA	8:45	1128.4576 MG	.8759 MG	28371.79	22.79	640	164°	18422	Filled	158	
11	LEA	10:15	1129.4671 MG	1.0095 MG	28396.31	24.52	686	160°	18480	Filled	150	
12	LEA	8:20	1130.3512 MG	.8841 MG	28417.78	21.46	687	161°	18530	Filled	155	
13	LEA	9:25	1131.3938 MG	1.0426 MG	28443.01	25.23	689	162°	18590	Filled	160	
14	LEA	8:25	1132.3443 MG	.9505 MG	28466.02	23.01	688	160°	18644	Filled	170	
15	TS	11:00	1133.2547 MG	1.0104 MG	28490.43	24.41	689	155°	18701	Filled	165	
16	TS	9:16	1134.3159 MG	.9612 MG	28513.71	23.28	688	155°	18750	Filled	170	
17	LEA	9:20	1135.2392 MG	.9233 MG	28536.40	22.69	678	off	18809	Filled	148	
18	LEA	8:00	1136.0911 MG	.8519 MG	28557.16	20.70	686	160°	18858	Filled	161	
19	CC	8:30	1137.0923 MG	1.0017 MG	28581.68	24.58	679	161°	18916	Filled	160	
20	LEA	8:40	1138.0781 MG	.9853 MG	28605.82	24.14	680	162°	18972	Filled	170	
21	CC	8:55	1139.0601 MG	.9826 MG	28630.04	24.19	677	161°	19029	Filled	167	
22	TS	11:00	1140.1033 MG	1.0423 MG	28655.15	25.36	690	160°	19088	Filled	160	
23	TS	10:20	1141.0403 MG	.9370 MG	28678.09	22.9	651	162°	19141	Filled	167	
24	LEA	8:10	1141.8996 MG	.8593 MG	28699.29	21.2	676	161°	19191	Filled	155	
25	TS	1:15	1143.1073 MG	1.2077 MG	28718.36	29.57	692	161°	19260	Filled	165	
26	TS	9:00	1143.8889 MG	.7816 MG	28747.41	19.05	683	160°	19305	Filled	165	
27	TS	8:40	1144.8678 MG	.9789 MG	28771.14	23.73	687	160°	19361	Filled	156	
28	LEA	9:25	1145.8484 MG	.9806 MG	28794.82	23.68	690	160°	19416	Filled	170	3000 200 200
29	LEA	12:25	1146.9549 MG	1.1065 MG	28821.25	26.43	698	160°	19479	Filled	160	
30	CPA	9:05	1147.7936 MG	.8381 MG	28844.79	20.59	681	161°	19527	Filled	169	
31												

Comments:

1119.616 MG

28142.25

Phelan Pinon Hills Community Service District

MONTH: October
YEAR: 2012
SITE: W-14

Well Log

Hour read: 28841.79

Flow Meter Read: 1147.7936 MG

Last months Flow read: 1147.7936 MG

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	9:20	1148.6661 MG	0.8725 MG	28863.06	21.27	684	82°	19577	Filled	164	
2	LEA	9:46	1149.6389 MG	0.9728 MG	28866.5	23.54	687	85°	19632	Filled	146	
3	LEA	10:25	1150.6034 MG	0.9645 MG	28909.74	23.09	696	89°	19687	Filled	156	
4	LEA	8:55	1151.5482 MG	0.9448 MG	28932.19	22.45	701	94°	19740	Filled	155	
5	CC	8:33	1152.4820 MG	0.9339 MG	28954.46	20.27	699	79°	19793	Filled	155	
6	CC	8:10	1153.4365 MG	0.9543 MG	28977.31	22.85	696	—	19847	Filled	161	
7	CC	8:55	1154.4580 MG	1.0217 MG	29001.53	24.22	703	77°	19904	Filled	157	
8	LEA	8:55	1155.4157 MG	0.9577 MG	29024.67	23.4	690	84°	19959	Filled	155	
9	CC	7:50	1155.9744 MG	0.5637 MG	29038.43	13.76	682	84°	19991	Filled	155	
10	LEA	8:35	1156.9838 MG	1.0044 MG	29062.53	24.10	695	80°	20048	Filled	170	3:00 PM
11	LEA	8:30	1157.9706 MG	0.9868 MG	29086.39	23.86	689	82°	20104	Filled	154	180 PSI - 58 Resid
12	LEA	9:10	1158.9917 MG	1.0211 MG	29110.38	23.99	709	80°	20161	Filled	198	184 PSI - 42
13	TS	9:45	1159.9447 MG	0.9573 MG	29133.29	22.91	693	80°	20216	Filled	155	
14	TS	10:00	1160.8755 MG	0.9308 MG	29155.79	22.50	687	80°	20269	Filled	160	
15	LEA	8:35	1161.8162 MG	0.9407 MG	29178.46	22.67	693	84°	20322	Filled	175	
16	CC	8:10	1162.7234 MG	0.9096 MG	29200.69	22.23	682	74°	20375	Filled	156	
17	LEA	8:40	1163.7574 MG	1.0316 MG	29225.20	24.51	701	80°	20433	Filled	172	
18	CC	10:15	1164.8690 MG	1.0616 MG	29250.78	25.54	697	85°	20493	Filled	165	
19	CC	9:30	1165.7966 MG	0.9296 MG	29274.04	23.26	695	82°	20543	Filled	165	
20	CC	9:55	1166.7554 MG	0.9588 MG	29297.14	23.1	692	84°	20602	Filled	156	
21	LEA	10:27	1167.8187 MG	1.0633 MG	29322.02	24.88	712	74°	20661	Filled	175	
22	LEA	8:40	1168.6925 MG	0.8738 MG	29342.88	20.86	698	75°	20711	Filled	185	
23	NB	7:50	1169.6868 MG	0.9943 MG	29366.02	23.14	716	98°	20766	Filled	172	
24	LEA	8:35	1170.6454 MG	0.9586 MG	29388.62	22.60	707	83°	20820	Filled	153	
25	LEA	10:25	1171.5815 MG	0.9361 MG	29410.74	22.12	705	78°	20872	Filled	200	
26	LEA	8:50	1172.4230 MG	0.8435 MG	29430.85	20.1	697	71°	20920	Filled	172	
27	TS	9:45	1173.2310 MG	0.8080 MG	29450.48	19.63	686	80°	20967	Filled	180	
28	LEA	10:25	1174.1433 MG	0.9123 MG	29472.29	21.81	697	84°	21019	Filled	165	
29	LEA	9:00	1174.9308 MG	0.7875 MG	29491.65	19.36	678	80°	21064	Filled	195	
30	LEA	8:45	1175.5135 MG	0.5821 MG	29505.49	13.84	702	81°	21098	Filled	165	
31	LEA	8:50	1176.3602 MG	0.8467 MG	29525.85	20.36	693	88°	21146	Filled	173	

Comments: 10/9 Pump Check & Flow Test, 10/15 Blow out & 22-gpm motor removed

Phelan Pinon Hills Community Service District

MONTH: November
YEAR: 2012
SITE: W-14

Well Log

Last months Flow read: 1176.3602 MG

Hour read: 29525.85

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	LEA	8:15	1177.1877 MG	8275 MG	29546.21	20.36	677	80°	21194	Filled	172	
2	CC	10:03	1178.0450 MG	8575 MG	29566.90	20.49	691	68°	21043	Filled	175	
3	RMG	10:25	1178.3435 MG	7985 MG	29580.11	19.21	692	67°	21287	Filled	175	
4	CC	9:20	1179.6696 MG	8261 MG	29600.21	20.1	685	80°	21336	Filled	160	
5	LEA	8:35	1180.5891 MG	9195 MG	29627.99	21.78	704	82°	21388	Filled	160	
6	CC	9:14	1181.6271 MG	1035 MG	29652.54	24.55	703	OFF	21446	Filled	145	well off
7	LEA	8:00	1182.3047 MG	6806 MG	29669.01	16.47	689	off	21485	Filled	150	well off
8	CC	8:25	1183.2354 MG	9101 MG	29691.08	22.07	703	92°	21538	Filled	160	
9	LEA	9:50	1184.1702 MG	9348 MG	29713.26	22.18	702	88°	21590	Filled	152	
10	NB	9:00	1185.0368 MG	8566 MG	29733.61	20.35	702	89°	21639	Filled	165	
11	TC	8:02	1185.4134 MG	8866 MG	29754.57	21.96	704	—	21689	Filled	153	
12	CC	5:30	1186.5408 MG	9274 MG	29776.48	21.91	705	—	21741	Filled	150	
13	LEA	9:20	1187.7847 MG	9439 MG	29798.93	22.45	701	88°	21794	Filled	188	
14	LEA	9:05	1188.6928 MG	9681 MG	29820.32	21.39	708	88°	21845	Filled	155	
15	CC	4:25	1189.6400 MG	9472 MG	29841.71	22.29	705	87°	21898	Filled	152	
16	CC	8:39	1190.6275 MG	9875 MG	29865.88	23.17	710	85°	21954	Filled	165	
17	RS	11:15	1191.6986 MG	10711 MG	29890.83	24.95	715	87°	22013	Filled	190	
18	CC	10:00	1192.6650 MG	9427 MG	29913.26	22.93	715	86°	22067	Filled	150	
19	CC	8:50	1193.5276 MG	8626 MG	29933.73	20.47	702	87°	22115	Filled	156	
20	CC	8:24	1194.5172 MG	9896 MG	29956.87	23.14	713	88°	22171	Filled	150	
21	LEA	9:05	1195.4847 MG	9675 MG	29979.48	22.61	713	87°	22225	Filled	160	
22	JS	9:15	1196.4973 MG	10176 MG	30003.34	23.86	707	87°	22281	Filled	150	
23	RS	12:25	1197.6825 MG	11352 MG	30030.81	27.17	714	87°	22347	Filled	160	
24	CC	10:10	1198.6241 MG	9416 MG	30052.84	22.03	712	87°	22399	Filled	160	
25	RS	10:50	1199.6672 MG	10431 MG	30071.23	24.39	713	87°	22457	Filled	156	
26	LEA	8:25	1200.5882 MG	9210 MG	30098.84	21.61	710	88°	22509	Filled	163	
27	CC	8:23	1201.6084 MG	10062 MG	30122.80	23.96	710	92°	22564	Filled	150	
28	LEA	9:05	1202.5863 MG	9879 MG	30145.74	22.94	710	87°	22620	Filled	146	
29	CC	8:43	1203.4954 MG	9691 MG	30167.17	21.43	707	87°	22671	Filled	150	
30	CC	9:20	1204.4722 MG	9768 MG	30189.99	20.82	713	87°	22726	Filled	150	
31												

Comments:

Phelan Pinon Hills Community Service District

MONTH: December

YEAR: 2012

SITE: W-14

Well Log

Last months Flow read: 1204.4712 MG

Hour read: 30189.99

Date	Initial	Time	Flow Meter Read	24 Hr Total Flow	Hour Meter	24 hr Total Ran	gpm	Temp	Edison	Oil	PSI	Comments
1	CC	7:18	1205.4158 MG	1.9536 MG	30211.93	21.74	724	ON	22778	Filled	155	
2	CC	9:38	1206.5164 MG	1.0906 MG	30237.11	25.18	722	ON	22838	Filled	150	
3	LEA	9:05	1207.4954 MG	.9790 MG	30259.96	22.85	714	ON	22892	Filled	150	
4	LEA	11:30	1208.6304 MG	1.1350 MG	30286.35	26.4	717	ON	22955	Filled	189	
5	LEA	8:20	1209.4457 MG	.8153 MG	30305.51	19.16	709	ON	23001	Filled	155	
6	LEA	8:25	1210.4141 MG	.9684 MG	30328.24	22.73	710	ON	23055	Filled	150	2nd completed Expected fire at 10:00
7	LEA	9:30	1211.4131 MG	.9990 MG	30350.84	22.60	737	ON	23109	Filled	154	
8	NB	9:20	1212.4355 MG	1.0274 MG	30374.71	23.87	714	ON	23166	Filled	155	
9	NB	9:25	1213.3641 MG	.9286 MG	30396.33	21.62	716	ON	23218	Filled	160	
10	LEA	9:15	1214.2761 MG	.9130 MG	30417.86	21.53	706	ON	23269	Filled	154	
11	CC	8:12	1215.2676 MG	.9915 MG	30440.82	22.46	720	ON	23323	Filled	160	
12	CC	8:40	1216.2114 MG	.9448 MG	30463.02	22.2	709	ON	23376	Filled	167	
13	NB	10:00	1217.3012 MG	1.0888 MG	30488.41	25.39	714	ON	23437	Filled	200	
14	CC	9:40	1218.1947 MG	.8935 MG	30509.10	20.69	720	ON	23486	Filled	165	
15	CC	12:00	1219.2006 MG	1.005 MG	30532.47	23.27	717	NO	23542	Filled	166	
16	CC	9:40	1219.4531 MG	.7525 MG	30549.92	17.45	718	ON	23583	Filled	160	
17	LEA	9:25	1220.9810 MG	1.0279 MG	30573.77	23.85	718	ON	23640	Filled	155	
18	LEA	8:20	1221.0278 MG	.0468 MG	30574.84	1.07	729	OFF	23643	Filled	146	JUST STARTED WELL
19	LEA	9:05	1221.0506 MG	.0228 MG	30575.46	.62	613	ON	23645	Filled	153	
20	LEA	8:50	1221.9719 MG	.9213 MG	30596.76	21.30	721	OFF	23696	Filled	147	
21	LEA	9:15	1222.8214 MG	.8495 MG	30616.69	19.93	710	OFF	23744	Filled	150	WELL FIRED UP
22	CC	9:37	1223.6690 MG	.8476 MG	30636.49	19.8	713	ON	23791	Filled	147	
23	JS	10:00	1224.4933 MG	.8243 MG	30655.60	19.11	718	ON	23837	Filled	160	
24	CC	6:54	1225.1632 MG	.6699 MG	30671.14	15.54	718	ON	23874	Filled	155	
25	CC	7:14	1225.9871 MG	.8239 MG	30690.19	19.05	720	ON	23919	Filled	145	
26	LEA	8:30	1226.2284 MG	.7413 MG	30707.39	17.20	718	ON	23961	Filled	160	WELL FIRED UP
27	LEA	8:30	1227.5204 MG	.7920 MG	30725.73	18.34	720	OFF	24005	Filled	159	
28	CC	9:16	1228.2705 MG	.7501 MG	30743.16	17.43	718	ON	24047	Filled	157	
29	NB	9:45	1229.0458 MG	.7753 MG	30761.24	18.08	715	ON	24090	Filled	159	
30	CC	9:10	1229.6797 MG	.6339 MG	30776.00	14.76	716	ON	24135	Filled	146	
31	LEA	9:00	1230.3889 MG	.7092 MG	30792.49	16.49	717	ON	24165	Filled	155	

aments: