

EXHIBIT “C”

Multiple Point Test Summary

Pumping Plant Name		LAKE E WELL			LAKE S E WELL			LAKE S E WELL			LAKE S E WELL		
Test Date		10/11/2006			11/28/2012								
Pump Tester Name		RICK KOCH			RICK KOCH								
CSS Service Account		022-9335-87			022-9335-87								
Meter Number		345M-6166			345M-6166								
Reference Number		10537			10537								
Rate		TOU-PA-7B			TOU-PA-B-I								
Average \$ Cost/kWh		0.08669			0.09055								
Type		TW			TW								
Motor HP		125			125								
Motor Mfg.		GE			GE								
Pump Mfg.													
Test Points		T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	46				62.5								
Suction Pressure, PSI													
Drawdown, Ft.	36.4				26.3								
Pumping Level, Ft.	290.4				275.4								
Standing Level, Ft.	254				249.1								
Discharge Head Ft.	105.3				144.4								
Suction Head Ft.													
Total Head Ft.	396.7				419.8								
Customer GPM	703				592								
Capacity GPM	677				512								
GPM/Ft. Drawdown, Ft.	18.6				19.5								
Acre Ft./24 Hour	2,992				2,263								
kW Input	95.5				90.5								
HP Input	128.1				121.4								
Pump Speed, RPM	1782				1783								
Motor Load %	93.2				89.6								
kWh/Acre Ft.	766				960								
Overall Plant Eff., %	53				44.7								
Improved Plant Eff., %		69%			69%								
Improved kWh/Acre Ft.		588.0			622.0								
Potential Savings, \$					\$9,270								
Note: For more detailed info													

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

Confidential/Proprietary Information

December 7, 2012

GARY VAN DAM
HIGH DESERT DAIRY
9753 EAST AVENUE F-8
LANCASTER, CA 93535

HYDRAULIC TEST RESULTS, Plant LAKES S WELL

Location: 7305 E AVENUE I HP: 150
Cust #: 0-000-4753 Serv. Acct. #: 022-8730-28
Meter: 345M-6048 Pump Ref. #: 10538

In accordance with your request, an energy efficiency test was performed on your turbine well pump on July 27, 1989. If you have any questions regarding the results which follow, please contact UNKNOWN USER at .

	Equipment
Pump:	L & B
Motor:	US
	No: '15207
	No: 'NO PLATE
Discharge Pressure, PSI	.5
Standing Water Level, Feet	237.6
Drawdown, Feet	64.4
Discharge Head, Feet	1.2
Pumping Water Level, Feet	302.0
Total Head, Feet	303.2
Capacity, GPM	994
GPM per Foot Drawdown	15.4
Acre Feet Pumped in 24 Hours	4.393
KW Input to Motor	105.1
HP Input to Motor	140.9
Motor Load (%)	86.0
kWh per Acre Foot	574
Overall Plant Efficiency (%)	54.0

DAN L. JOHNSON
Manager
Hydraulic Services

HDD000025

Confidential/Proprietary Information

December 7, 2012

NICK VAN DAM
HIGH DESERT DAIRY
9753 EAST AVENUE F-8
LANCASTER, CA 93535

HYDRAULIC TEST RESULTS, Plant: LAKES N WELL
Location: 75TH ST EAST HP: 75
Cust #: 0-000-4753 Serv. Acct. #: 026-9261-82
Meter: 256000-182132 Pump Ref. #: 10539

In accordance with your request, an energy efficiency test was performed on your turbine well pump on July 28, 1989. If you have any questions regarding the results which follow, please contact UNKNOWN USER at .

	Equipment	
Pump:	PEERL	No: '86079
Motor:	GE	No: 'DRJ425341
Discharge Pressure, PSI		2.1
Standing Water Level, Feet		199.8
Drawdown, Feet		66.6
Discharge Head, Feet		4.9
Pumping Water Level, Feet		266.4
Total Head, Feet		271.3
Capacity, GPM		830
GPM per Foot Drawdown		12.5
Acre Feet Pumped in 24 Hours		3.669
kW Input to Motor		67.1
HP Input to Motor		90.0
Motor Load (%)		108.0
kWh per Acre Foot		439
Overall Plant Efficiency (%)		63.2

DAN L. JOHNSON
Manager
Hydraulic Services

HDD000026

Customer: HIGH DESERT DAIRY Multiple Point Test Summary

Pumping Plant Name	LAKESEN WDELL	LAKESEN WDELL
Test Date	10/10/2006	11/28/2012
Pump Tester Name	RICK KOCH	RICK KOCH
CSS Service Account	026-9261-82	026-9261-82
Meter Number	0828W-147	256000-182132
Reference Number	10539	10539
Rate	TOU-PA-A	TOU-PA-B-I
Average \$ Cost/kWh	0.11006	0.09202
Type	TW	TW
Motor HP	75	75
Motor Mfg.	GE	GE
Pump Mfg.	PEERL	PEERL

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	59			57.5								
Suction Pressure, PSI												
Drawdown, Ft.												
Pumping Level, Ft.												
Standing Level, Ft.	214.4			208.6								
Discharge Head Ft.	136.3			132.8								
Suction Head Ft.												
Total Head Ft.												
Customer GPM	568											
Capacity GPM	591			508								
GPM/Ft. Drawdown, Ft.												
Acre Ft./24 Hour	2,612			2,245								
kW Input	69			68.3								
HP Input	92.5			91.6								
Pump Speed, RPM	1775			1778								
Motor Load %	111			112.1								
kWh/Acre Ft.	634			730								
Overall Plant Eff., %												

Improved Plant Eff., %	69%	69%
Improved kWh/Acre Ft.		
Potential Savings, \$		

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

[illegible]

Pumping Plant Name	LAKE'S WELL	LAKE'S WELL	Test Date	Pumping Plant Name	LAKE'S WELL	LAKE'S WELL
Test Date	9/3/1998	10/10/2006				
Pump Tester Name	GARY PARDUE	RICK KOCH				
CSS Service Account	013-6278-92	022-8730-28				
Meter Number	P729K-2017	345M-6048				
Reference Number	10538	10538				
Rate	PA-1	TOU-PA-7B				
Average \$ Cost/kWh	0.078961	0.09739				
Type	TW	TW				
Motor Hp	150	150				
Motor Mfg.	US	-US				
Pump Mfg.	L & B	L & B				

[illegible]

Improved Plant Eff., %	70%	69%			
Improved kWh/Acre Ft.		547.0			
Potential Savings, \$		\$7,265			

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

Multiple Point Test Summary


Pumping Plant Name	3/11/1992	3/17/1994	10/24/2006	11/27/2012
Test Date				
Pump Tester Name	GARY PARDUE	GARY PARDUE	RICK KOCH	RICK KOCH
CSS Service Account			000-0392-11	000-0392-11
Meter Number	732K-1075	732K-1075	3416M-6339	3416M-6339
Reference Number	17856	17856	17856	17856
Rate	TOU-PA-A	TOU-PA-A	TOU-PA-A	TOU-PA-A
Average \$ Cost/kWh	0.605401	0.098441	0.09579	0.10391
Type	TW	TW	TW	TW
Motor HP	40	40	40	40
Motor Mfg.	US	US	US	US
Pump Mfg.	L & B	L & B	L & B	L & B

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	0.4			1.1			57.5	76.3	89	66.5	74.3	
Suction Pressure, PSI												
Drawdown, Ft.	26.1			18			35	30.8	26.8	34.9	32.7	
Pumping Level, Ft.	169.9			174.8			190.6	186.4	182.4	188.6	186.4	
Standing Level, Ft.	143.8			156.8			155.6	155.6	155.6	153.7	153.7	
Discharge Head Ft.	0.9			2.5			132.8	176.3	205.6	151.3	171.6	
Suction Head Ft.												
Total Head Ft.	170.8			177.3			323.4	362.7	388	339.9	358	
Customer GPM							370					
Capacity GPM	391			332			557	302	256	362	327	
GPM/Ft. Drawdown, Ft.	15			18.4			10.2	9.8	9.6	10.4	10	
Acres Ft./24 Hour	1.728			1.467			1.578	1.335	1.132	1.6	1.445	
kW Input	28.4			27.6			40.5	37.9	36.1	40.7	39.9	
HP Input	38.1			37			54.3	50.8	48.4	54.6	53.5	
Pump Speed, RPM				1778			1767			1776		
Motor Load %	84.7			82.4			120.8	113.1	107.7	122.1	119.7	
kWh/Acre Ft.	394			451			616	682	766	611	663	
Overall Plant Eff., %	44.3			40.2			53.7	54.4	51.8	56.9	55.3	

Improved Plant Eff., %	64%	64%	64%	64%
Improved kWh/Acre Ft.				543.0
Potential Savings, \$				\$1,286.

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

Multiple Point Test Summary



Pumping Plant Name	MIDDLE WELL	MIDDLE WELL	MIDDLE WELL
Test Date	10/3/2006	11/27/2012	
Pump Tester Name	RICK KOCH	RICK KOCH	
CSS Service Account	024-7632-19	024-7632-19	
Meter Number	V349N-648	V349N-648	
Reference Number	25940	25940	
Rate	TOU-PA-5	TOU-PA-B-I	
Average \$ Cost/kWh	0.08874	0.07258	
Type	TW	TW	
Motor HP	200	200	
Motor Mfg	US	US	
Pump Mfg	B/J	B/J	

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	65			82.3											
Suction Pressure, PSI															
Drawdown, Ft	26.7			22.7											
Pumping Level, Ft	331.9			258.3											
Standing Level, Ft	305.2			235.6											
Discharge Head Ft	150.2			190.1											
Suction Head Ft															
Total Head Ft	482.1			448.4											
Customer GPM															
Capacity GPM	1382			1320											
GPM/Ft. Drawdown, Ft.	51.8			58.1											
Acre Ft./24 Hour	6.108			5.834											
kW Input	163			160.1											
HP Input	218.6			214.7											
Pump Speed, RPM	1783			1785											
Motor Load %	105.1			103.3											
kWh/Acre Ft.	641			659											
Overall Plant Eff., %	77			69.6											

Improved Plant Eff., %	72%		
Improved kWh/Acre Ft.	637.0		
Potential Savings, \$	\$1,655		

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters


Multiple Point Test Summary

Pumping Plant Name	MARZUOLO SOUTH	MARZUOLO SOUTH
Test Date	10/3/2006	11/27/2012
Pump Tester Name	RICK KOCH	RICK KOCH
CSS Service Account	026-3166-81	026-3166-81
Meter Number	V349N-1208	V349N-18219
Reference Number	25941	25941
Rate	PA-2	TOU-PA-B-I
Average \$ Cost/kWh	0.11823	0.06901
Type	TW	TW
Motor HP	200	200
Motor Mfg.	US	US
Pump Mfg.	L&B	L&B

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	55.5	70	86	60.7	78.5										
Suction Pressure, PSI															
Drawdown, Ft.	33.8	32.6	30.4	40.6	39.1										
Pumping Level, Ft.	315.8	314.6	312.4	271.2	269.7										
Standing Level, Ft.	282	282	282	230.6	230.6										
Discharge Head Ft.	128.2	161.7	198.7	140.2	181.3										
Suction Head Ft.															
Total Head Ft.	444	476.3	511.1	411.4	451										
Customer GPM															
Capacity GPM	1682	1606	1527	1710	1614										
GPM/Ft. Drawdown, Ft.	49.8	49.3	50.2	42.1	41.3										
Acre Ft./24 Hour	7,434	7,099	6,749	7,558	7,134										
kW Input	201.3	203.8	205.2	196.7	201.1										
HP Input	269.9	273.3	275.2	263.8	269.7										
Pump Speed, RPM	1768			1774											
Motor Load %	124.2	125.7	126.6	123.3	126.1										
kWh/Acre Ft.	650	689	730	625	677										
Overall Plant Eff., %	69.9	70.7	71.6	67.3	68.2										

Improved Plant Eff., %	72%	
Improved kWh/Acre Ft.	584.0	
Potential Savings, \$	\$3,850	

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters



SCE Hydraulic/Industrial Services

Customer: HIGH DESERT DAIRY

Multiple Point Test Summary

Pumping Plant Name	LAKE MIDDLE W/L	LAKE MIDDLE W/L	LAKE MIDDLE W/L
Test Date	10/11/2006	11/28/2012	
Pump Tester Name	RICK KOCH	RICK KOCH	
CSS Service Account	022-8729-98	022-8729-98	
Meter Number	3412M-6383	3412M-7385	
Reference Number	25943	25943	
Rate	TOU-PA-7B	TOU-PA-B-I	
Average \$ Cost/kWh	0.08744	0.08351	
Type	TW	TW	
Motor HP	125	125	
Motor Mfg.	GE	GE	
Pump Mfg.			

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	52			55.7								
Suction Pressure, PSI												
Drawdown, Ft.	99.5			98.2								
Pumping Level, Ft.	350.7			347.4								
Standing Level, Ft.	251.2			249.2								
Discharge Head Ft.	120.1			128.7								
Suction Head Ft.												
Total Head Ft.	470.8			476.1								
Customer GPM	794			799								
Capacity GPM	776			776								
GPM/Ft. Drawdown, Ft.	7.8			7.9								
Acre Ft./24 Hour	3.43			3.43								
kW Input	113.8			115.5								
HP Input	152.6			154.9								
Pump Speed, RPM	1777			1780								
Motor Load %	111.1			114.4								
kWh/Acre Ft.	796			808								
Overall Plant Eff., %	60.5			60.2								

Improved Plant Eff., %	69%	69%
Improved kWh/Acre Ft.	698.0	706.0
Potential Savings, \$		\$3,297

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

HDD000032

Multiple Point Test Summary

Pumping Plant Name	CORNER WELL	CORNER WELL
Test Date	10/16/2006	3/22/2012
Pump Tester Name	RICK KOCH	RICK KOCH
CSS Service Account	001-9609-71	001-9609-71
Meter Number	3412M-7004	3412M-7004
Reference Number	25946	25946
Rate	TOU-PA-5	TOU-PA-B
Average \$ Cost/kWh	0.08285	0.09843
Type	TW	TW
Motor HP	40	50
Motor Mfg.	US	US
Pump Mfg.	GOULD	GOULD

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	8.3			7.7	21.4							
Suction Pressure, PSI												
Drawdown, Ft.	61.7			32.9	30.3							
Pumping Level, Ft.	244.6			214.6	212							
Standing Level, Ft.	182.9			181.7	181.7							
Discharge Head Ft.	19.2			17.8	49.4							
Suction Head Ft.												
Total Head Ft.	263.8			232.4	261.4							
Customer GPM												
Capacity GPM	219			249	219							
GPM/Ft. Drawdown, Ft.	3.5			7.6	7.2							
Acre Ft./24 Hour	0.968			1.101	0.968							
kW Input	20.4			19.5	18.5							
HP Input	27.4			26.1	24.8							
Pump Speed, RPM	1787			1791								
Motor Load %	60.9			47.7	45.3							
kWh/Acre Ft.	506			425	459							
Overall Plant Eff., %	53.3			55.9	58.3							

Improved Plant Eff., %	64%	65%
Improved kWh/Acre Ft.	422.0	366.0
Potential Savings, \$		\$822

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

SCE Hydraulic/Industrial Services

Customer: High Desert Dairy

Multiple Point Test Summary

Pumping Plant Name	9/17/1998	8/24/1999	10/19/2000	9/10/2001	9/23/2002	8/25/2003
Test Date						
Pump Tester Name	GARY PARDUE	GARY PARDUE	GARY PARDUE	GARY PARDUE	GARY PARDUE	GARY PARDUE
CSS Service Account	003-4224-65	003-4224-65	003-4224-65	003-4224-65	003-4224-65	003-4224-65
Meter Number	732K-2095	732K-2095	732K-2095	732K-2095	732K-2095	732K-2095
Reference Number	18545	18545	18545	18545	18545	18545
Rate	TOU-PA-6B	TOU-PA-SOP	TOU-PA-SOP	TOU-PA-SOP	TOU-PA-SOP	TOU-PA-SOP
Average \$ Cost/kWh	0.095458	0.081487	0.053696	0.063322	0.080201	0.085301
Type	TW	TW	TW	TW	TW	TW
Motor HP	100	100	100	100	100	100
Motor Mfg.						
Pump Mfg.	PEERL	PEERL	PEERL	PEERL	PEERL	PEERL
Test Points	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	57.8	67.8	49.4	54.5	64.5	54.5
Suction Pressure, PSI	22.2	19.9	23.8	21.1	19	21.9
Drawdown, Ft.	281	278.7	282.6	289	286.9	279.5
Pumping Level, Ft.	258.8	258.8	258.8	267.9	267.9	257.6
Standing Level, Ft.	133.5	156.6	114.1	125.9	149	125.9
Discharge Head Ft.	414.5	435.3	396.7	414.9	435.9	405.4
Suction Head Ft.						
Total Head Ft.						
Customer GPM	516	458	548	511	458	526
Capacity GPM	23.2	23	23	24.2	24.1	24
GPM/Ft. Drawdown, Ft.	2.281	2.024	2.422	2.259	2.024	2.325
Acre Ft./24 Hour	80	76.8	81	78.9	75.6	79.7
kW Input	107.3	103	108.6	105.8	101.4	106.9
HP Input	1780			1780		1781
Pump Speed, RPM	97.6	93.7	98.8	96.3	92.3	97.3
Motor Load %	842	911	803	839	896	823
kWh/Acre Ft.	50.3	48.9	50.5	50.6	49.7	50.4
Overall Plant Eff., %	68%	68%	68%	68%	68%	68%
Improved Plant Eff., %						
Improved kWh/Acre Ft.						
Potential Savings, \$						

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

Multiple Point Test Summary

SCE Hydraulic/Industrial Services
Customer: HIGH DESERT DAIRY

Pumping Plant Name:	MARZUOLO NORDH
Test Date	11/27/2012
Pump Tester Name	RICK KOCH
CSS Service Account	030-1435-96
Meter Number	V349N-1668
Reference Number	25302
Rate	TOU-PA-B-I
Average \$ Cost/kWh	0.07869
Type	TW
Motor HP	350
Motor Mfg.	US
Pump Mfg.	JLINE

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	75.9														
Suction Pressure, PSI															
Drawdown, Ft.	134.8														
Pumping Level, Ft.	360.5														
Standing Level, Ft.	225.7														
Discharge Head Ft.	175.3														
Suction Head Ft.															
Total Head Ft.	535.8														
Customer GPM	1540														
Capacity GPM	1699														
GPM/Ft. Drawdown, Ft.	12.6														
Acre Ft./24 Hour	7.51														
kW Input	230.6														
HP Input	309.2														
Pump Speed, RPM	1789														
Motor Load %	83.6														
kWh/Acre Ft.	737														
Overall Plant Eff. %	74.3														

Improved Plant Eff., %	
Improved kWh/Acre Ft.	
Potential Savings, \$	

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

HDD000035

Multiple Point Test Summary

Pumping Plant Name	END WELL	END WELL
Test Date	10/2/2006	3/22/2012
Pump Tester Name	RICK KOCH	RICK KOCH
CSS Service Account	013-7894-12	013-7894-12
Meter Number	Y249M-5048	Y349M-18967
Reference Number	25939	25939
Rate	TOU-PA-B	TOU-PA-B-I
Average \$ Cost/kWh	0.09322	0.07007
Type	TW	TW
Motor HP	300	300
Motor Mfg.	US	US
Pump Mfg.		

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	51.5			68.4											
Suction Pressure, PSI															
Drawdown, Ft.	22.1			21.3											
Pumping Level, Ft.	312.7			301.3											
Standing Level, Ft.	290.6			280											
Discharge Head Ft.	119			146.5											
Suction Head Ft.															
Total Head Ft.	431.7			447.8											
Customer GPM															
Capacity GPM	1631			1636											
GPM/Ft. Drawdown, Ft.	73.8			76.8											
Acre Ft./24 Hour	7,209			7,231											
kW Input	186.6			188.7											
HP Input	250.2			253											
Pump Speed, RPM	1787			1791											
Motor Load %	79.2			80.1											
kWh/Acre Ft.	621			626											
Overall Plant Eff. %	71.1			73.1											

Improved Plant Eff., %															
Improved kWh/Acre Ft.															
Potential Savings, \$															

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

SCE Hydraulic / Industrial Services

Customer: HIGH DESERT DAIRY



Pumping Plant Name / Test Date	Pump Location	CSS Service Account #	Motor HP	kWh / Year	kW	Annual Acre-ft.	Avg S / Acre Ft.	Annual Cost	Test Eff %	Impr Eff %	kWh Annual Savings	%KW Savings	Impr Annual Cost	Est. \$ Annual Savings	Potential kWh Incentive	Potential kW Incentive	Total Potential Incentive
LAKE E WELL 11/28/2012	7435 E AVENUE I	022-9335-87	125	250,976	90.5	303	\$86.32	\$28,348	45%	69%	102,373	31.8	\$17,078	\$9,270	\$9,214	\$2,067	\$11,281
LAKE BIG WELL 11/28/2012	7361 E AVENUE H	025-8297-95	350	985,838	271.2	1,400	\$55.32	\$77,457	66%	72%	83,258	22.9	\$70,916	\$6,542	\$7,493	\$1,489	\$8,982
GROVEN WELL 12/9/2012	44770 55TH ST EAST	037-0456-09	125	358,104	101.0	451	\$65.00	\$29,282	54%	69%	75,945	21.4	\$23,072	\$6,210	\$5,835	\$1,391	\$8,226
MANZULO SOUTH 11/27/2012	7565 E AVENUE E-12	026-3065-81	200	863,628	196.7	1,383	\$43.11	\$59,599	67%	72%	55,786	12.7	\$55,749	\$3,850	\$5,021	\$826	\$5,846
LAKE MIDDLE WEL 11/26/2012	7505 E AVENUE I	022-8729-98	125	310,848	115.5	385	\$67.50	\$25,959	60%	69%	39,484	14.7	\$22,662	\$3,297	\$3,554	\$956	\$4,509
MIDDLE WELL 11/27/2012	47359 100TH ST EAST	024-7892-19	200	689,460	160.1	1,047	\$47.81	\$50,041	70%	72%	22,805	5.3	\$48,386	\$1,655	\$2,052	\$345	\$2,397
MICK'S WELL 11/27/2012	7259 E AVE F-4	000-0392-11	40	112,068	40.7	184	\$63.45	\$11,645	57%	64%	12,380	4.5	\$10,359	\$1,286	\$1,114	\$293	\$1,407
CORNER WELL 3/12/2012	9955 E AVE F-0	001-9603-71	50	59,520	19.5	140	\$41.89	\$5,859	59%	65%	8,349	2.7	\$5,037	\$822	\$751	\$176	\$927
END WELL 3/22/2012	5745 E AVE F-0	013-7806-12	300	1,017,072	188.7	1,624	\$43.89	\$71,266	73%								
MANZULO NORTH 11/27/2012	7307 E AVENUE F-4	030-4485-96	350	895,284	230.6	1,133	\$58.00	\$65,729	74%								
LAKE N WELL 11/29/2012	75TH ST EAST	026-9261-82	75	168,012	68.3	230	\$67.19	\$15,460									
										Totals:	400,380	116.0		\$32,932			\$43,574

*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. The savings used for incentive calculations is 65% of on-peak kW

HDD000037

Multiple-Point Test Summary

Potential Savings, \$

Report Date 12/7/2012

HDD000038

SCE Hydraulic/Industrial Services
Customer: HIGH DESERT DAIRY

Multiple Point Test Summary

Pumping Plant Name:	END WELL	CORNER WELL	NICKS WELL	MARZUO NORTH	MIDDLE WELL	MARZUO SOUTH
Test Date	3/22/2012	3/22/2012	11/27/2012	11/27/2012	11/27/2012	11/27/2012
Pump Tester Name	RICK KOCH	RICK KOCH	RICK KOCH	RICK KOCH	RICK KOCH	RICK KOCH
CSS Service Account	013-7894-12	001-9609-71	000-0392-11	030-1435-96	024-7632-19	026-3166-81
Meter Number	V349M-18967	3412M-7004	3416M-6339	V349N-1668	V349N-648	V349N-18219
Reference Number	25939	25946	17856	25302	25940	25941
Rate	TOU-PA-B-I	TOU-PA-B	TOU-PA-A	TOU-PA-B-I	TOU-PA-B-I	TOU-PA-B-I
Average \$ Cost/kWh	0.07007	0.09843	0.10391	0.07869	0.07258	0.06901
Type	TW	TW	TW	TW	TW	TW
Motor HP	300	50	40	350	200	200
Motor Mfg.	US	US	US	US	US	US
Pump Mfg.		GOULD	L & B	JENE	B/J	L & B

Test Points	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3	T-1	T-2	T-3
Discharge Pressure, PSI	63.4			7.7	21.4		65.5	74.3		82.3		
Suction Pressure, PSI												
Drawdown, Ft.	21.3			32.9	30.3		34.9	32.7		22.7		
Pumping Level, Ft.	301.3			214.6	212		188.6	186.4		258.3		
Standing Level, Ft.	280			181.7	181.7		153.7	153.7		235.6		
Discharge Head Ft.	146.5			17.8	49.4		151.3	171.6		190.1		
Suction Head Ft.												
Total Head Ft.	447.8			232.4	261.4		339.9	358		448.4		
Customer GPM												
Capacity GPM	1636			249	219		362	327		1320		
GPM/Ft. Drawdown, Ft.	76.8			7.6	7.2		10.4	10		58.1		
Acres Ft./24 Hour	7.231			1.101	0.968		1.6	1.445		5.834		
kW Input	188.7			19.5	18.5		40.7	39.9		160.1		
HP Input	253			26.1	24.8		54.6	53.5		214.7		
Pump Speed, RPM	1791			1791			1776			1785		
Motor Load %	80.1			47.7	45.3		122.1	119.7		103.3		
kWh/Acre Ft.	626			425	459		611	663		659		
Overall Plant Eff., %	73.1			55.9	58.3		56.9	55.3		59.6		
Improved Plant Eff., %				65%			64%			72%		
Improved kWh/Acre Ft.				366.0			543.0			637.0		
Potential Savings, \$				\$822			\$1,286			\$1,655		

Note: For more detailed information pertaining to pump test results, please refer to Pump Test Results and Cost Analysis Letters

HDD000039