no pump test for 2001)

on B well from

So Calif Edison Co.



ATTN: JEAN MARITORENA JOSE MARITORENA, INC

300 E PANAMA RD

BAKERSFIELD, CA 93307-6261

October 4, 2002

SUBJECT: HYDRAULIC TEST RESULTS - B WELL

14551 W AVE B

CUST #: 0-007-7591 SERV ACCT #: 018-2022-56

DATE OF TEST: October 2, 2002

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EOUIPMENT

PUMP: L & B NO: 72824

MOTOR: WH NO: 229V8908 125 HP

METER: 3412M0-20

HYDRAULIC TEST REFERENCE NUMBER: 10589

TEST RESULTS

Discharge Pressure, PSI	50.5
Standing Water Level, Ft.	282.4
Drawdown, Ft.	23.1
Discharge Head, Ft.	116.7
Pumping Water Level, Ft.	305.5
Total Head, Ft.	422.2
Capacity, GPM	850.0
GPM per Ft. Drawdown	36.8
Acre Ft. Pumped in 24 Hrs.	3.757
kW Input to Motor	93.0
HP Input to Motor	124.7
Motor Load (%)	90.8
Measured Speed of Pump, RPM	1,778
kWh per Acre Ft.	594
Overall Plant Efficiency (%)	72.7

The pump was running 3 lines during this test.

DAN L. JOHNSON

Manager



October 4, 2002

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 125 - PLANT: B WELL

CUST #: 0-007-7591 SERV ACCT #: 018-2022-56

HYDRAULIC TEST REFERENCE NUMBER: 10589

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 2, 2002 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B

Current Rate

Total kWh	, 188,820
kW Input	93.0
kWh per Acre Ft.	594
Acre Ft. per Year	317.8
Avg. Cost per kWh	\$0.10
Avg. Cost per Acre Ft.	\$61.36
Overall Plant Eff. (%)	72.7
TOTAL ANNUAL COST	\$19,499.63

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at 1661) 726-5662.

DAN IS. JOHNSON

Manager



August 3, 2003

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - B WELL

14551 W AVE B

CUST #: 0-007-7591 - SERV ACCT #: 018-2022-56

DATE OF TEST: July 28, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: 72824

MOTOR: WH NO: 229V8908 125 HP

METER: 3412M0-20

HYDRAULIC TEST REFERENCE NUMBER: 10589

TEST RESULTS

TIDE TUDOMEN,	
Discharge Pressure, PSI	58.3
Standing Water Level, Ft.	280.2
Drawdown, Ft.	19.5
Discharge Head, Ft.	134.7
Pumping Water Level, Ft.	299.7
Total Head, Ft.	434.4
Capacity, GPM	716.0
GPM per Ft. Drawdown	36.7
Acre Ft. Pumped in 24 Hrs.	3.165
kW Input to Motor	86.6
HP Input to Motor	116.1
Motor Load (%)	84.5
Measured Speed of Pump, RPM	1,778
kWh per Acre Ft.	657
Overall Plant Efficiency (%)	67.6
OAGLUTT LIGHT HITTOTOHOM ()	3

The pump was running Alines daring this test.

Manager



August 3, 2003

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 125 - PLANT: B WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2022-56

HYDRAULIC TEST REFERENCE NUMBER: 10589

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed July 28, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B Current Rate

Total kWh	255,156
kW Input	86.6
kWh per Acre Ft.	657
Acre Ft. per Year	388.4 <i>)</i>
Avg. Cost per kWh	\$0.10
Avg. Cost per Acre Ft.	\$68.81
Overall Plant Eff. (%)	67.6
Mile had start that the own time the case was the case own own time and the case they take the time	
TOTAL ANNUAL COST	\$26 , 729.86

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at 1661,726,5662.

DAN L. JOHNSON

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

September 29, 2004

2004

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - B WELL

14551 W AVE B

CUST #: 0-007-7591 - SERV ACCT #: 018-2022-56

DATE OF TEST: September 28, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

PUMP: L & B NO: NO PLATE

MOTOR: WH NO: 229V8908 125 HP

METER: 3412M0-20

HYDRAULIC TEST REFERENCE NUMBER: 10589

TEST RESULTS

Discharge Pressure, PSI	34.3
Standing Water Level, Ft.	289.8
Drawdown, Ft.	31.3
Discharge Head, Ft.	79.3
Pumping Water Level, Ft.	321.1
Total Head, Ft.	400.4
Capacity, GPM	975.0
GPM per Ft. Drawdown	31.2
Acre Ft. Pumped in 24 Hrs.	4.310
kW Input to Motor	106.0
HP Input to Motor	142.1
Motor Load (%)	103.5
Measured Speed of Pump, RPM	1,771
kWh per Acre Ft.	590
Overall Plant Efficiency (%)	69.4

The pump was running to the center pivot during this test.

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

September 29, 2004

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 125 - PLANT: B WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2022-56

HYDRAULIC TEST REFERENCE NUMBER: 10589

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 28, 2004 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B Current Rate

350,256 Total kWh 106.0 kW Input 590 kWh per Acre Ft. 593.2 Acre Ft. per Year / \$0.08 Avg. Cost per kWh \$46.06 Avg. Cost per Acre Ft. 69.4 Overall Plant Eff. (%) \$27,322.07 TOTAL ANNUAL COST

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at $\sqrt{3}05$)654-7312.

DAN L JOHNSON

Manager



September 9, 2005



JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - B WELL

14551 W AVE B CUST #: 0-007-7591 - SERV ACCT #: 018-2022-56

DATE OF TEST: September 7, 2005

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

L & B PUMP:

NO: 72824 NO: 229V8908

125 HP

MOTOR: WH

METER: 3412M0-20 HYDRAULIC TEST REFERENCE NUMBER: 10589

TEST RESULTS

Customer Mayer 3 111/	Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM kWh per Acre Ft. Overall Plant Efficiency (%)	40.5 292.2 31.7 93.6 323.9 417.5 915.0 28.9 4.044 101.2 135.7 98.8 1,772 601 71.1 963.0
	Customer Meter GPM	963.0

TOHNSON

Manager



September 9, 2005

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 125 - PLANT: B WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2022-56

HYDRAULIC TEST REFERENCE NUMBER: 10589

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 7, 2005 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B Current Rate

344,772 Total kWh 101.2 kW Input 601 kWh per Acre Ft. 574.0 / Acre Ft. per Year \$0.08 Avg. Cost per kWh \$45.83 Avg. Cost per Acre Ft. 71.1 Overall Plant Eff. (%) \$26,306.10 TOTAL ANNUAL COST

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at (805) 654-7312.

> A day DAN J. JOHNSON

Manager



September 15, 2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261



HYDRAULIC TEST RESULTS, Plant: B WELL

Location: 14551 W AVE B HP: 125

Cust. #: 0-007-7591

Serv. Acct. #: 018-2022-56

Meter: 3412M-20 Pump Ref #: 10589

In accordance with your request, a test was made on your turbine well pump on September 13, 2006. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

Pump Mfg.: L & B No.: 72824 Motor Mfg.: WH No.: 229V8908

RESULTS

RESULIS	
	59.3
Discharge Pressure, PSI	294.4
Standing Water Level, Feet	23.9
Drawdown, Feet	137.0
Discharge Head, Feet	
Pumping Water Level, Feet	318.3
Tetal Head Foot	455.3
Total Head, Feet	809.0
Capacity, GPM_	33.8
GPM per Foot Drawdown	3,576
Acre Feet Pumped in 24 Hours	
kW Input to Motor	98.6
HP Input to Motor	132.2
Martin Lood (%)	96.3
Motor Load (%)	1,772
Measured Speed of Pump, RPM	662
kWh per Acre Foot:	70.3
Overall Plant Efficiency (%)	
Customer Meter, GPM	849.0
Ouotomor manning	

DAN L. JOHNSON

Manager



September 15, 2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: B WELL

Location: 14551 W AVE B HP: 125

Cust. #: 0-007-7591

Serv. Acct. #: 018-2022-56

Meter: 3412M-20

Pump Ref #: 10589

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 13, 2006, billing history for the past 12 months, and your current rate of TOU-PA-7B. Evicting

	<u>Existing</u>
	384,792
Total kWh	98.6
kW Input	662
kWh per Acre Foot	581.3
Acra Feet per Year	\$0.08
Avorage Cost per kWh	\$52.34
Average Cost per Acre Foot Overall Plant Efficiency (%)	70.3
Total Annual Cost	\$30,425.50
l otal Allituai Cost	

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

DAN L. JOHNSON

Manager



September 14, 2007



46.5

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: B WELL

Location: 14551 W AVE B HP: 125

Cust. #: 0-007-7591

Serv. Acct. #: 018-2022-56

Meter: 3412M-20

Pump Ref #: 10589

In accordance with your request, a test was made on your turbine well pump on September 12, 2007. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

Pump Mfg.: L & B No.: 12824 Motor Mfg.: WH No.: 229V8908

RESULTS

Discharge Pressure, PSI 296.1 Standing Water Level, Feet 34.8 Drawdown, Feet 107.4 Discharge Head, Feet 330.9 Pumping Water Level, Feet 438.3 Total Head, Feet 860.0 Capacity, GPM 24.7 GPM per Foot Drawdown 3,801 Acre Feet Pumped in 24 Hours 101.8

kW Input to Motor 136.5
HP Input to Motor 99.4
Motor Load (%)
Measured Speed of Pump, RPM 643
kWh per Acre Foot: 69.7
Overall Plant Efficiency (%) 920
Customer Meter, GPM

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: B WELL

Location: 14551 W AVE B HP: 125

Serv. Acct. #: 018-2022-56 Cust. #: 0-007-7591 Pump Ref #: 10589 Meter: 3412M-20

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 12, 2007, billing history for the past 12 months, and your current rate of TOU-PA-7B.

12 112 113	Existing
	487,512
Total kWh	101.8
kW Input	643
kINh per Acre Foot	758.3
Acre Feet per Year	\$0.09
Avorage Cost per KVVN	\$57.24
Average Cost per Acre Foot Overall Plant Efficiency (%)	69.7
Overall items	\$43,408.07
Total Annual Cost	• •

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 19, 2008



ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant. **BWELL** HP: 125 Location: 14551 W AVE B

018-2022-56 Serv. Acct. #: Cust #: 0-007-7591 10589

Pump Ref.#: 3412M-20 Meter:

In accordance with your request, a test was made on your turbine well pump on September 15, 2008. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment No: 12824 L&B Pump: No: 229V8908 WH Motor:



September 19, 2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

BWELL

Location: 14551 W AVE B

HP: 125

Cust #: 0-007-7591

018-2022-56

Serv. Acct. #: Pump Ref.#:

10589

3412M-20 The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 15, 2008, billing history for the past 12 months, and your current rate of TOU-PA-7B. Existina

u 1	EXISTING
	437,028
1110th	102.3
Total kWh	618
kW Input	707.2/
kWh per Acre Foot	\$0.09
Acre Feet per Year	\$55.43
Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	70.2
Overall Flant Emore,	\$39,197.04
Total Annual Cost	

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 11, 2009



ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: B WELL
Location: 14551 W AVE B HP: 125
Cust #: 0-007-7591 Serv. Acct. #: 018-2022-56
Meter: 3412M-7924 Pump Ref.#: 10589

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 9, 2009. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment L & B WH		12824 229V8908
--------------------------	--	-------------------

Results

Pump: Motor:

Discharge Pressure, PSI Standing Water Level, Feet Drawdown, Feet Discharge Head, Feet Pumping Water Level, Feet Total Head, Feet Capacity, GPM GPM per Foot Drawdown Acre Feet Pumped in 24 Hours kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM	35.7 308.8 31.4 82.5 340.2 422.7 893 28.4 3.947 101.9 136.6 100.9
HP Input to Motor	100.9



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

B WELL PUMPING COST ANALYSIS, Plant: HP: 125 Location: 14551 W AVE B 018-2022-56 Serv. Acct. #: Cust #: 0-007-7591 10589 Pump Ref.#: 3412M-7924 Meter:

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 9, 2009, billing history for the past 12 months, and your current rate of TOU-PA-7B. Evicting

	<u>Existing</u>
	370,488
Total kWh	101.9
kW Input	620
kWh per Acre Foot	597.8
Acre Feet per Year	\$0.09
Avorage Cost per KVVN	\$55.85
Average Cost per Acre Foot Overall Plant Efficiency (%)	69.8
	\$33,388.38
Total Annual Cost	tion in an efficient mann

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



October 8, 2010



ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant. B WELL HP: 125

Location: 14551 W AVE B

018-2022-56 Serv. Acct. #: Cust #: 0-007-7591 10589

Pump Ref.#: 3412M-7924 Meter:

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 5, 2010. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

No: 12824 L&B Pump: No: 229V8908 WH Motor:

Results

54.1 286.0 28.6 125.0 314.6 439.6 850 29.7 3.757 100.7 135.0 99.7 1,774
99.7

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

BWELL PUMPING COST ANALYSIS, Plant: HP: 125 Location: 14551 W AVE B 018-2022-56 Serv. Acct. #:

Cust #: 0-007-7591 10589 Pump Ref.#: 3412M-7924 Meter:

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 5, 2010, billing history for the past 12 months, and your current rate of TOU-PA-B.

	Existing
	290,256
Total kWh	100.7
kW Input	643
kWh per Acre Foot	451.1
Acre Feet per Year	\$0.11
Average Cost ner KVVII	\$70.10
Average Cost per Acre Foot Overall Plant Efficiency (%)	69.9
	\$31,623.39
Total Annual Cost	er :

The hydraulic test results indicate that this pump is operating in an efficient manner. Total Annual Cost

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 9, 2011



ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: B WELL

HP: 125

Location: 14551 W AVE B 0-007-7591 Cust #:

018-2022-56

3412M-7924 Meter:

Serv. Acct. #: Pump Ref.#:

10589

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 8, 2011. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Equipment Pump: L & B Motor: WH		12824 229V8908
---------------------------------	--	-------------------

Results -

Discharge Pressure, PSI	39.6
Standing Water Level, Feet	291.0
Standing Water Level, 1 301	28.8
Drawdown, Feet	91.5
Discharge Head, Feet	319.8
Pumping Water Level, Feet	411.3
Total Head, Feet	919
Capacity, GPM	31.9
CDM per Foot Drawdown	4.062
Acre Feet Pumped in 24 Hours	102.2
kW Input to Motor	137.1
HP Input to Motor	
Motor Load (%)	101.2
Measured Speed of Pump, RPM	1,770
Measured Speed of Family	958
Customer Meter, GPM	604
kWh per Acre Foot	69.6
Overall Plant Efficiency (%)	



September 9, 2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

Plant: B WELL PUMPING COST ANALYSIS,

HP: 125 Location: 14551 W AVE B

018-2022-56 Serv. Acct. #: Cust #: 0-007-7591 10589

Pump Ref.#: 3412M-7924 Meter:

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 8, 2011, billing history for the past 12 months, and your current rate of TOU-PA-B.

	<u>Existing</u>
	375,816
Total kWh	102.2
kW Input	604
kWh per Acre Foot	622.3
Acre Feet per Year	\$0.11
A COST DEL KVVII	\$65.58
Average Cost per Acre i oor	69.6
Overall Plant Efficiency (%)	
	\$40,806.10
Total Annual Cost	: officient mann

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 14, 2012



JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: B WELL

Location: 14551 W AVE B

HP: 125

Cust #: 0-007-7591

018-2022-56

3412M-7924 Meter:

Serv. Acct. #: 10589 Pump Ref.#:

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 10, 2012. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump: Motor:	Equipment L & B WH	No: No:	12824 229V8908
	L&B	No:	

Results

Discharge Pressure, PSI Standing Water Level, Feet Drawdown, Feet Discharge Head, Feet Pumping Water Level, Feet Total Head, Feet Capacity, GPM GPM per Foot Drawdown Acre Feet Pumped in 24 Hours kW Input to Motor HP Input to Motor	44.3 259.2 29.4 102.3 288.6 390.9 985 33.5 4.354 101.6 136.2
kW Input to Motor	136.2
Motor Load (%) Measured Speed of Pump, RPM Customer Meter, GPM	1,770 1,005 560
kWh per Acre Foot Overall Plant Efficiency (%)	71.4



September 14, 2012



JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS,

Plant: B WELL

Location: 14551 W AVE B

Cust #: 0-007-7591

018-2022-56 Serv. Acct. #:

3412M-7924

Pump Ref.#:

10589

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 10, 2012, billing history for the past 12 months, and your current rate of TOU-PA-B.

	<u>Existing</u>
	385,524
Total kWh	101.6
	560
kW Input kWh per Acre Foot	688.2
Acre Feet per Year	\$0.10
Cost Der KVVII	\$55.50
Average Cost per Acre Foot Average Cost per Acre Foot Overall Plant Efficiency (%)	71.4
	\$38,193.86
Total Annual Cost	an efficient mann

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 21, 2001

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - YARD WELL

51251 140TH ST W

SERV ACCT #: 018-2031-52 CUST #: 0-007-7591

DATE OF TEST: September 19, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EOUIPMENT

NO: NO PLATE PEERL

PUMP: 125 HP NO: 1291749 MOTOR: US

METER: P831W-48

HYDRAULIC TEST REFERENCE NUMBER: 10590

UIDIVODITO 1			Charlestine -
TEST RESULTS Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM kWh per Acre Ft. Overall Plant Efficiency (%)	TEST 1 31.7 254.6 12.2 73.2 266.8 340.0 936.0 76.7 4.137 98.2 131.7 95.9 1781 570 61.0	TEST 2 39.3 254.6 11.1 90.8 265.7 356.5 840.0 75.7 3.713 95.1 127.5 92.8 615 59.3	TEST 3 50.0 254.6 9.7 115.5 264.3 379.8 700.0 72.2 3.094 89.2 119.6 87.1 692 56.1

The above test results indicate various operating conditions of this pump. The pump was running 5 lines for test 1, 4 lines for test 2, and 3 lines for test 3. DAN JOHNSON

Manager



September 21, 2001

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 125 - PLANT: YARD WELL

CUST #: 0-007-7591 SERV ACCT #: 018-2031-52

HYDRAULIC TEST REFERENCE NUMBER: 10590

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 19, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP

Current Rate

Total kWh kW Input	239388 98.2
kWh per Acre Ft.	570
Acre Ft. per Year	420.1
Avg. Cost per kWh	\$0.07
Avg. Cost per Acre Ft.	\$41.77
Overall Plant Eff. (%)	61.0
TOTAL ANNUAL COST	\$17,549.53

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (661)726-5662.

ĎAŇ JOHŃSÓN Manager



October 4, 2002

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - YARD WELL

51251 140TH ST W

SERV ACCT #: 018-2031-52 CUST #: 0-007-7591

DATE OF TEST: October 1, 2002

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

NO: NO PLATE PEERL PUMP:

150 HP NO: 1291749 MOTOR: US

METER: P831W-48

HYDRAULIC TEST REFERENCE NUMBER: 10590

TEST RESULTS

TEST RESOURS	47.7
Discharge Pressure, PSI	267.2
Standing Water Level, Ft.	17.4
Drawdown, Ft.	110.2
Discharge Head, Ft.	284.6
Pumping Water Level, Ft.	394.8
Total Head, Ft.	1,135.0
Capacity, GPM	65.2
CDM ner Ft. Drawdown	5.017
Acre Ft. Pumped in 24 Hrs.	126.6
kW Input to Motor	
HP Input to Motor	169.8
Motor Load (%)	103.6
Measured Speed of Pump, RPM	1,777
kWh per Acre Ft.	606
Overall Plant Efficiency (%)	66.7
Overgit Franc prize	

The pump was running 5 lines during this test.

JÖHNSON

Manager



October 4, 2002

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

- PLANT: YARD WELL

SERV ACCT #: 018-2031-52 HP: 150 CUST #: 0-007-7591

HYDRAULIC TEST REFERENCE NUMBER:

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2002 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B Current Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	464,964 126.6 606 767.6 \$0.10 \$58.00 66.7
TOTAL ANNUAL COST	\$44,522.16

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

(6**6**1)726-5662. If you have any questions, please contact GARY PARPUE at

DAN L. GOHNSON

Manager



August 3, 2003

2003

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - YARD WELL

51251 140TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 018-2031-52

DATE OF TEST: July 28, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

NO: NO PLATE PEERL PUMP: NO: 1291749 MOTOR: US

150 HP

METER: P831W-48

HYDRAULIC TEST REFERENCE NUMBER: 10590

TEST RESULTS

TEST RESULTS Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM kWh per Acre Ft. Overall Plant Efficiency (%)	53.5 272.8 14.2 123.6 287.0 410.6 1,054.0 74.2 4.659 122.9 164.8 100.5 1,769 633 66.3
Overarr rrans	

The pump was running /5 lines during this test.

MOMNSON Manager



August 3, 2003

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 150 - PLANT: YARD WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2031-52

HYDRAULIC TEST REFERENCE NUMBER: 10590

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed July 28, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B Current Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	516,672 122.9 633 815.9 \$0.10 \$65.50 66.3
TOTAL ANNUAL COST	\$53,442.43

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE At (661)726-5662.

DAN M. JOHNSON

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: JOHN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261 2004

SUBJECT: HYDRAULIC TEST RESULTS - YARD WELL

51251 140TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 018-2031-52

DATE OF TEST: August 25, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

NO: NO PLATE PEERL PUMP: NO: 1291749 MOTOR: US

150 HP

METER: P831W-48

HYDRAULIC TEST REFERENCE NUMBER: 10590

TEST RESULTS

TEST KEDGETS	41.1
Discharge Pressure, PSI	
Standing Water Level, Ft.	275.4
Desirating With	16.2
Drawdown, Ft.	94.9
Discharge Head, Ft.	291.6
Pumping Water Level, Ft.	386.5
Total Head, Ft.	
Capacity, GPM	1,039.0
GPM per Ft. Drawdown	64.1
Acre Ft. Pumped in 24 Hrs.	4.592
Acre Ft. Pumped III 21 111	126.5
kW Input to Motor	169.6
HP Input to Motor	103.5
Motor Load (%)	
Measured Speed of Pump, RPM	1,774
Measured Special	661 -
kWh per Acre Ft.	59.8
Overall Plant Efficiency (%)	

DAN WYJOHNSON

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: JOHN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS - HP: 150 - PLANT: YARD WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2031-52

HYDRAULIC TEST REFERENCE NUMBER: 10590

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 25, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 59.8% to 70.0%. These improvements can save you up to 81,446 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

TATELLING DIA	NT EFFICIENCY	IMPROVED PLANT	EFFICIENCY
EXISTING	TOU-PA-7B Current Rate	TOU-PA-7B Current Rate	Savings
Total kWh kW Input kWh per Acre Ft.	557,808 126.5 661 843.6	476,362 108.0 565 843.6	81,446 18.5 97
Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	\$0.08 \$51.18 59.8	\$43.71 70.0	\$7.47
TOTAL ANNUAL COST	\$43,174.34	\$36,870.43	\$6,303.91

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at 1895)654/7312.

Manager Hvd Hydraulic Services



September 9, 2005

2005

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD

BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - YARD WELL

51251 140TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 018-2031-52

DATE OF TEST: September 7, 2005

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EOUIPMENT

NO: NO PLATE PEERL PUMP:

150 HP NO: 1291749 MOTOR: US

METER: P831W-48

HYDRAULIC TEST REFERENCE NUMBER: 10590

TEST RESULTS

Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM	35.5 277.5 16.1 82.0 293.6 375.6 1,135.0 70.5 5.017 125.5 168.3 102.7 1,770 601
Motor Load (%) Measured Speed of Pump, RPM	1,770
kWh per Acre Ft. Overall Plant Efficiency (%) Customer Meter, GPM	64.0 1,116.0

Hydraulic Services

TOTALSON



September 9, 2005

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

> SUBJECT: PUMPING COST ANALYSIS - HP: 150 - PLANT: YARD WELL CUST #: 0-007-7591 - SERV ACCT #: 018-2031-52 HYDRAULIC TEST REFERENCE NUMBER: 10590

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 7, 2005 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 64.0% to 70.0%. These improvements can save you up to 44,103 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING PLAN	T EFFICIENCY	IMPROVED PLANT	EFFICIENCY
EVIDITIO 1777	TOU-PA-7B Current Rate	TOU-PA-7B Current Rate	Savings
Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	511,692 125.5 601 852.1 \$0.08 \$45.10 64.0	467,589 114.7 549 852.1 \$41.21 70.0	44,103 10.8 52 \$3.89
TOTAL ANNUAL COST	\$38,428.07	\$35,115.94	\$3,312.13

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at \$\\ 805\ 654_7312.

> FORNSON Manager



September 15, 2006

2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: YARD WELL

Location: 51251 140TH ST W HP: 150

Cust. #: 0-007-7591

Serv. Acct. #: 018-2031-52 OK

Meter: P831W-48

Pump Ref #: 10590

In accordance with your request, a test was made on your turbine well pump on September 11, 2006. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

No.: NO PLATE Pump Mfg.: PEERL No.: 1291749 Motor Mfg.: US

RESULTS

RESULTS	36.0
Discharge Pressure, PSI	280.8
Standing Water Level, Feet	13.1
Drawdown, Feet	83.2
Discharge Head, Feet	293.9
Pumping Water Level, Feet	377.1
Total Head, Feet	1,120.0
Conscity GPM	85.5
ODIA POR EOOF I ITAWQOWII	4.950
Acre Feet Pumpeu III 24 Hours	124.5
kW Input to Motor	167.0
HP Input to Motor	101.8
**-*1 cod (%)	1,770
Measured Speed of Pump, RPM	604
WATE POR ACTE FOOL	63.9
Overall Plant Efficiency (%) Customer Meter, GPM	1,172.0

DANEL JÖHNSON

Manager



Save energy, Save money... Your test results show that you can!

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261 PUMPING COST ANALYSIS, Plant: YARD WELL

Location: 51251 140TH ST W HP: 150

Cust. #: 0-007-7591 Meter: P831W-48

Serv. Acct. #: 018-2031-52 Pump Ref #: 10590

Helping California businesses save energy and money is a major goal at SCE. As you know, our technical specialists performed a free pump-efficiency test on one or more pumps at your facility on September 11, 2006. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

	Plant Efficiency		0
Total kWh kW Input kWh per Acre Foot Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	Existing 557,520 124.5 604 923.5 \$0.08 \$46.24 63.9	1mproved 508,796 113.6 551 \$42.20 70.0	<u>Savings</u> 48,724 10.9 53 \$4.04
Total Annual Cost Cash Incentive	\$42,700.46	\$38,968.68	\$3,731.77 \$3,897.92

Case studies show that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 63.9% to 70.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-7B, we estimate that you may save up to 48,724 kWh annually, resulting in energy cost savings of \$3,731.77.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you would receive an incentive of \$0.08 per kWh saved, courtesy of SCE's Agricultural Energy Efficiency Program. Based on your estimated kWh savings, you would be eligible for a potential cash incentive of \$3,897.92, capped at 50% of your project cost. (See contract for details.)

You may also be eligible for pump motor incentives. For more information about your test results, options, and incentive opportunities, contact RICK KOCH at (805)654-7312.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

Program funded by California utility ratepayers, and administered by Southern California Edison under the auspices of the California Public Utilities Commission.



September 14, 2007

2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: YARD WELL

Location: 51251 140TH ST W HP: 150

Cust. #: 0-007-7591

Serv. Acct. #: 018-2031-52

Meter: P831W-48

Pump Ref #: 10590

In accordance with your request, a test was made on your turbine well pump on September 12, 2007. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

Pump Mfg.: PEERL No.: NO PLATE Notor Mfg.: US No.: 1291749

RESULTS

RESUL 15	
Discharge Pressure, PSI	46.4
Discharge Meter Level Feet	283.2
Standing Water Level, Feet	14.4
Drawdown, Feet	107.2
Discharge Head, Feet	297.6
Pumping Water Level, Feet	404.8
Total Head, Feet	• • • • • • • • • • • • • • • • • • • •
Capacity, GPM	1,010.0
GPM per Foot Drawdown	70.1
Acre Feet Pumped in 24 Hours	4.464
Acre reel rumped in 24 mount	122.0
kW Input to Motor	163.6
HP Input to Motor	99.8
Motor Load (%)	1,772
Measured Speed of Pump, RPM	
kWh per Acre Foot:	656
Overall Plant Efficiency (%)	63.1
Customer Meter, GPM	965
Customer merci, or m	

SOUTHERN CALIFORNIA ED SON® An EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: YARD WELL

Location: 51251 140TH ST W HP: 150

Cust. #: 0-007-7591

Serv. Acct. #: 018-2031-52

Meter: P831W-48

Pump Ref #: 10590

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 12, 2007, billing history for the past 12 months, and your current rate of TOU-PA-7B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall Plant Efficiency can be improved from 63.1% to 70.0%.
- 2. This can save you up to 66,436 kWh and \$5,829.72 annually.

	Plant E	Cavingo	
Total kWh kW Input kWh per Acre Foot Acre Feet per Year	Existing 674,676 122.0 656 1,028.5	<u>Improved</u> 608,240 110.0 591	<u>Savings</u> 66,436 12.0 65
Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.09 \$57.56 63.1	\$51.90 70.0	\$5.67
Total Annual Cost	\$59,202.82	\$53,373.10	\$5,829.72

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 19, 2008

2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

YARD WELL

Location: 51251 140TH ST W

HP: 150

Cust #: 0-007-7591

Serv. Acct. #:

018-2031-52

Meter:

345M-6685

Pump Ref.#:

10590

In accordance with your request, a test was made on your turbine well pump on September 15, 2008. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump:	PEERL	No:	NO PLATE
Motor:	US	No:	1291749

Results

Discharge Pressure, PSI 35.0	
Standing Water Level, Feet 286.0	
Drawdown, Feet 15.4	
Discharge Head, Feet 80.9	
Pumping Water Level, Feet 301.4	
Total Head, Feet 382.3	
Capacity, GPM 1,102	
GPM per Foot Drawdown 71.6	
Acre Feet Pumped in 24 Hours 4.871	
kW Input to Motor 123.3	
HP Input to Motor 165.3	
Motor Load (%) 102.5	
Measured Speed of Pump, RPM 1,770	
kWh per Acre Foot 608	mit co
Overall Plant Efficiency (%) 64.3	ser,
Customer Meter, GPM 1,055	



September 19, 2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

YARD WELL

Location: 51251 140TH ST W Serv. Acct. #: HP: 150

Cust #: 0-007-7591

018-2031-52

345M-6685 Meter:

Pump Ref.#:

10590

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 15, 2008, billing history for the past 12 months, and your current rate of TOU-PA-7B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 64.3% to 70.0%.
- 2. This can save you up to 48,913 kWh and \$4,239.25 annually.

2. This can save you up to ver	<u>Existing</u>	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot Acre Feet per Year	605,208 123.3 608 996.0	556,295 113.3 559	48,913 10.0 49
Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.09 \$52.66 64.3	\$48.41 70.0	\$4.26
Total Annual Cost	\$52,453.38	\$48,214.12	\$4,239.25

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

YARD WELL

Location: 51251 140TH ST W

HP: 150

Cust #: 0-007-7591

Serv. Acct. #:

018-2031-52

Meter:

345M-6685

Pump Ref.#:

10590

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 8, 2009. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump: Motor: PEERL US

No: NO PLATE

No: 1291749

Results -

Discharge Pressure, PSI	33.8
Standing Water Level, Feet	288.0
Drawdown, Feet	15.5
Discharge Head, Feet	78.1
Pumping Water Level, Feet	303.5
	381.6
Total Head, Feet	1,076
Capacity, GPM	69.4
GPM per Foot Drawdown	4.756
Acre Feet Pumped in 24 Hours	123.1
kW Input to Motor	165.1
HP Input to Motor	103.1
Motor Load (%)	• • • • • • • • • • • • • • • • • • • •
Measured Speed of Pump, RPM	1,772
Customer Meter, GPM	1,080
kWh per Acre Foot	621
Overall Plant Efficiency (%)	62.8



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

YARD WELL

Location: 51251 140TH ST W

HP: 150

Cust #: 0-007-7591

018-2031-52 Serv. Acct. #:

Pump Ref.#: 345M-6685 Meter:

10590

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 8, 2009, billing history for the past 12 months, and your current rate of TOU-PA-7B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 62.8% to 70.0%.
- 2. This can save you up to 49,376 kWh and \$4,337.65 annually.
- 3. These kWh savings translate to a 21-ton decrease in CO₂ emissions.

THESE KAME COMPANY	Existing	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot Acre Feet per Year	480,804 123.1 621 773.8	431,428 110.5 558	49,376 12.6 64
Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.09 \$54.58 62.8	\$48.98 70.0	\$5.61
Total Annual Cost	\$42,238.63	\$37,900.98	\$4,337.65 concerns over

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

YARD WELL

Location: 51251 140TH ST W

HP: 150

Cust #: 0-007-7591

018-2031-52 Serv. Acct. #:

345M-6685 Meter:

Pump Ref.#:

10590

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 5, 2010. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump:

PEERL

No: NO PLATE

US Motor:

No: 1291749

Results -

Discharge Pressure, PSI	52.2
Standing Water Level, Feet	278.8
Drawdown, Feet	13.7
Discharge Head, Feet	120.6
Pumping Water Level, Feet	292.5
Total Head, Feet	413.1
Capacity, GPM	936
GPM per Foot Drawdown	68.3
Acre Feet Pumped in 24 Hours	4.137
	118.0
kW Input to Motor	158.2
HP Input to Motor	98.1
Motor Load (%)	1,764
Measured Speed of Pump, RPM	941
Customer Meter, GPM	685
kWh per Acre Foot	
Overall Plant Efficiency (%)	61.7

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

YARD WELL PUMPING COST ANALYSIS, Plant: HP: 150 Location: 51251 140TH ST W 018-2031-52 Serv. Acct. #:

Cust #: 0-007-7591 10590 Pump Ref.#: 345M-6685

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 5, 2010, billing history for the past 12 months, and your current rate of TOU-PA-B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 61.7% to 70.0%.
- 2. This can save you up to 47,970 kWh and \$4,998.01 annually.
- These kWh savings translate to a 21-ton decrease in CO₂ emissions.

These kWh savings translate to the total kWh kW Input kWh per Acre Foot	Existing 404,844 118.0 685	Plant Efficiency Improved 356,874 104.0 604	<u>Savings</u> 47,970 14.0 81
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot	591.3 \$0.10 \$71.33 61.7	\$62.88 70.0	\$8.45
Overall Plant Efficiency (%)		\$37,182.69	\$4,998.01
Total Annual Cost	\$42,180.70	ul to you, and that your	concerns over

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 9, 2011

2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: YARD WELL

HP: 150

Location: 51251 140TH ST W Cust #: 0-007-7591

018-2031-52 Serv. Acct. #:

345M-6685 Meter:

10590 Pump Ref.#:

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 7, 2011. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump:	PEERL	NO PLATE
Motor:	US	1291749

Results -



September 9, 2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: YARD WELL

HP: 150 Location: 51251 140TH ST W

018-2031-52 Serv. Acct. #: Cust #: 0-007-7591

Pump Ref.#: 10590 Meter: 345M-6685

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 7, 2011, billing history for the past 12 months, and your current rate of TOU-PA-B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 61.7% to 70.0%.
- 2. This can save you up to 53,951 kWh and \$5,778.15 annually.
- 3. These kWh savings translate to a 23-ton decrease in CO₂ emissions.

THOSE KITH SELVED	Existin <u>a</u>	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot	456,276 122.1 625 730.1	402,325 107.7 551	53,951 14.4 74
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.11 \$66.94 61.7	\$59.02 70.0	\$7.91
Total Annual Cost	\$48,867.16	\$43,089.01	\$5,778.15

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 14, 2012



JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: YARD WELL

Location: 51251 140TH ST W Serv. Acct. #: HP: 150

Cust #: 0-007-7591

018-2031-52

345M-6685 Meter:

Pump Ref.#:

10590

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 10, 2012. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Pump: Motor:	Equipment PEERL US	No: No:	NO PLATE 1291749
Standing W Drawdown, Discharge H Pumping W Total Head Capacity, G GPM per F Acre Feet I kW Input to Motor Load Measured Customer	Pressure, PSI ater Level, Feet Feet Head, Feet Vater Level, Feet Feet FOPM Oot Drawdown Pumped in 24 Hours o Motor		37.1 249.9 16.2 85.7 266.1 351.8 1,150 71.0 5.083 124.9 167.5 103.8 1,752 1,099 590 61.0



September 14, 2012

JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS,

Plant: YARD WELL

Location: 51251 140TH ST W

HP: 150

Cust #: 0-007-7591

018-2031-52 Serv. Acct. #:

345M-6685 Meter:

10590 Pump Ref.#:

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 10, 2012, billing history for the past 12 months, and your current rate of TOU-PA-B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 61.0% to 70.0%.
- 2. This can save you up to 67,300 kWh and \$6,553.67 annually.
- 3. These kWh savings translate to a 29-ton decrease in CO₂ emissions. Diant Efficiency

These Kyvii savings translates	F. inting	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot	Existing 523,260 124.9 590	455,960 108.8 514	67,300 16.1 76
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	887.1 \$0.10 \$57.44 61.0	\$50.05 70.0	\$7.39
	\$50,955.06	\$44,401.39 oful to you, and that your	\$6,553.67 concerns over

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 21, 2001

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - BARN WELL

51320 150TH ST W

SERV ACCT #: 018-2033-06 CUST #: 0-007-7591

DATE OF TEST: September 19, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

NO: NO PLATE PUMP: PEERL

150 HP NO: S1190103PB MOTOR: NEWMN

METER: P831W-34

HYDRAULIC TEST REFERENCE NUMBER: 10587

TEST RESULTS

TEST RESULTS Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%)	51.3 267.3 21.5 118.5 288.8 407.3 945.0 44.0 4.177 125.7 168.6 102.8
kW Input to Motor	168.6
Motor Load (%) Measured Speed of Pump, RPM	102.8 1782 722
kWh per Acre Ft. Overall Plant Efficiency (%)	57.7

The pump was running 4 lines during this test.

Manager



September 21, 2001

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 150 - PLANT: BARN WELL

CUST #: 0-007-7591 SERV ACCT #: 018-2033-06

HYDRAULIC TEST REFERENCE NUMBER: 10587

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 19, 2001 and billing history for the past 12 months

EXISTING PLANT EFFICIENCY TOU-PA-SOP

Current Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft.	303864 125.7 722 420.6 \$0.07 \$53.97
Avg. Cost per Acre Ft.	57.7
Overall Plant Eff. (%)	57.7
TOTAL ANNUAL COST	\$22,701.68

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (661)726-5662.

Manager



October 4, 2002

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - BARN WELL

51320 150TH ST W

SERV ACCT #: 018-2023-06 CUST #: 0-007-7591

DATE OF TEST: October 1, 2002

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

NO: NO PLATE PUMP: PEERL

150 HP NO: S1190103 MOTOR: NEWM

METER: P831W-34

HYDRAULIC TEST REFERENCE NUMBER: 10587

TEST RESULTS

TEST RESULTS Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM kWh per Acre Ft. Overall Plant Efficiency (%)	40.0 278.0 20.4 92.4 298.4 390.8 1,023.0 50.1 4.522 126.3 169.4 103.3 1,781 670 59.6
Overarr France and	4

The pump was running 5 lines during this test.

Manager



October 4, 2002

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 150 - PLANT: BARN WELL

CUST #: 0-007-7591 SERV ACCT #: 018-2023-06

HYDRAULIC TEST REFERENCE NUMBER: 10587

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2002 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B Current Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	582,204 126.3 670 868.3 \$0.09 \$62.00 59.6
TOTAL ANNUAL COST	\$53,831.75

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUF at \$61)726-5662.

DAN LA JOHNSON

Manager



July 20, 2003

2003

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - BARN WELL

51320 150TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 018-2023-06

DATE OF TEST: July 14, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

NO: NO PLATE PEERL PUMP:

150 HP NO: S1190103 MOTOR: NEWM

METER: P729M-46

HYDRAULIC TEST REFERENCE NUMBER: 10587

TEST RESULTS Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM - kWh per Acre Ft. Overall Plant Efficiency (%)	TEST 1 41.8 281.0 17.9 96.6 298.9 395.5 1,141.0 63.7 5.043 124.1 166.4 101.5 1,780 591 68.5	TEST 2 54.3 281.0 15.8 125.4 296.8 422.2 1,035.0 65.5 4.575 121.0 162.3 99.0
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------

Test 1 is the normal operation of this pump at the time of the above results were obtained by throttling the discharge. The other test(s).

DAN L JOHNSON

Manager



July 20, 2003

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 150 - PLANT: BARN WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2023-06

HYDRAULIC TEST REFERENCE NUMBER: 10587

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed July 14, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-7B

Current Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	540,000 124.1 591 914.2 \$0.10 \$60.08 68.5
TOTAL ANNUAL COST	\$54,920.54

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (661) 726-5662.

DAN L JOHNSON

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

2004

JOHN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - BARN WELL

51320 150TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 018-2023-06

DATE OF TEST: August 25, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EOUIPMENT

PEERL PUMP:

NO: NO PLATE NO: S1190103

150 HP

MOTOR: NEWM METER: P729M-46

HYDRAULIC TEST REFERENCE NUMBER: 10587

TEST RESULTS Discharge Pressure, PSI Standing Water Level, Ft. Drawdown, Ft. Discharge Head, Ft. Pumping Water Level, Ft. Total Head, Ft. Capacity, GPM GPM per Ft. Drawdown Acre Ft. Pumped in 24 Hrs. ** W Input to Motor HP Input to Motor Motor Load (%)	TEST 1 33.5 290.2 18.3 77.4 308.5 385.9 1,076.0 58.8 4.756 125.1 167.8 102.3 1,781	TEST 2 41.9 290.2 17.3 96.8 307.5 404.3 994.0 57.5 4.393 123.0 164.9 100.6	TEST 3 50.2 290.2 16.0 116.0 306.2 422.2 921.0 57.6 4.071 119.9 160.8 98.1
Measured Speed of Pump, RPM 为 kWh per Acre Ft. Overall Plant Efficiency (%)	631 62.5	672 61.5	707 61.1

Test 1 is the normal operation of this pump at the time of the above The other #esults were obtained by throttling the discharge. test(s).

Manager

Hydraulic Services

JOHNSON -



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: JOHN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

> SUBJECT: PUMPING COST ANALYSIS - HP: 150 - PLANT: BARN WELL CUST #: 0-007-7591 - SERV ACCT #: 018-2023-06 HYDRAULIC TEST REFERENCE NUMBER: 10587

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 25, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 62.5% to 70.0%. These improvements can save you up to 72,485 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EVICATING PIAN	NT EFFICIENCY	IMPROVED PLANT	EFFICIENCY
EXIDIIMO 1221	TOU-PA-7B Current Rate	TOU-PA-7B Current Rate	Savings
Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year	676,860 125.1 631 1,072.0	604,375 111.7 564 1,072.0	72,485 13.4 68
Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	\$0.08 \$47.91 62.5	\$42.78 70.0 	\$5.13
TOTAL ANNUAL COST	\$51,360.14	\$45,859.98	\$5,500.15

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at 805 654-7312.

Manager Manager Hydraulic Services



2005

September 9, 2005

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - BARN WELL

51320 150TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 018-2023-06

DATE OF TEST: September 7, 2005

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

NO: NO PLATE PEERL PUMP:

150 HP NO: S1190103 MOTOR: NEWM

METER: 345M-6350

HYDRAULIC TEST REFERENCE NUMBER: 10587

Test 1 is the normal operation of this pump at the time of the above The other fresults were obtained by throttling the discharge. test(s).

JOHNSON ---

Manaώr '



September 9, 2005

JEAN MARITORENA ATTN: JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: PUMPING COST ANALYSIS

HP: 150 - PLANT: BARN WELL

CUST #: 0-007-7591 - SERV ACCT #: 018-2023-06

HYDRAULIC TEST REFERENCE NUMBER: 10587

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 7, 2005 and billing history for the past 12 months.

EXISTING	PLANT	EFFIC:	ENCY
		TOU-PA	
	Cı	ırrent	Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft. Overall Plant Eff. (%)	517,260 123.6 580 891.6 \$0.08 \$44.08 69.0
TOTAL ANNUAL COST	\$39,296.24

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at (805)654-7312.

> JOHNSON -Manader



September 15, 2006

2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: BARN WELL

Location: 51320 150TH ST W HP: 150

Cust. #: 0-007-7591

Serv. Acct. #: 018-2023-06 OK

Meter: 345M-6350

Pump Ref #: 10587

In accordance with your request, a test was made on your turbine well pump on September 11, 2006. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.


EQUIPMENT

Pump Mfg.: PEERL No.: NO PLATE Notor Mfg.: NEWM No.: S1190103

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

DAN L. JOHNSON

Manager



Save energy, Save money... Your test results show that you can!

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261 PUMPING COST ANALYSIS, Plant: BARN WELL

Location: 51320 150TH ST W HP: 150

Cust. #: 0-007-7591 Meter: 345M-6350

Serv. Acct. #: 018-2023-06

Pump Ref #: 10587

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our technical specialists performed a free pump-efficiency test on one or more pumps at your facility on September 11, 2006. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

	Plant E		
Total kWh kW Input kWh per Acre Foot Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot	Existing 488,196 125.3 604 807.8 \$0.08 \$47.54	<u>Improved</u> 454,735 116.7 563 \$44.28	<u>Savings</u> 33,461 8.6 41 \$3.26
Overall Plant Efficiency (%) Total Annual Cost	\$38,406.38	70.0 \$35,774.02	\$2,632.36 \$2,676.87
Cash Incentive			Ψ,σ.

Case studies show that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 65.2% to 70.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-7B, we estimate that you may save up to 33,461 kWh annually, resulting in energy cost savings of \$2,632.36.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you would receive an incentive of \$0.08 per kWh saved, courtesy of SCE's Agricultural Energy Efficiency Program. Based on your estimated kWh savings, you would be eligible for a potential cash incentive of \$2,676.87, capped at 50% of your project cost. (See contract for details.)

You may also be eligible for pump motor incentives. For more information about your test results, options, and incentive opportunities, contact RICK KOCH at (805)654-7312.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

Program funded by California utility ratepayers, and administered by Southern California Edison under the auspices of the California Public Utilities Commission.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: BARN WELL

Location: 51320 150TH ST W HP: 150

Cust. #: 0-007-7591

Serv. Acct. #: 018-2023-06

Meter: 345M-6350

Pump Mfg.: PEERL

Pump Ref #: 10587

No.: NO PLATE

No.: S1190103

In accordance with your request, a test was made on your turbine well pump on September 12, 2007. If you have any questions regarding the results which follow, please contact

RICK KOCH at (805)654-7312.

EQUIPMENT

Motor Mfg.: NEWM	No.: S1190103		
RESULTS Discharge Pressure, PSI Standing Water Level, Feet Drawdown, Feet Discharge Head, Feet Pumping Water Level, Feet Total Head, Feet Capacity, GPM GPM per Foot Drawdown Acre Feet Pumped in 24 Hours kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM	Test 1 39.0 293.1 16.6 90.1 309.7 399.8 1,040.0 62.7 4.597 123.9 166.1 101.4 1,781	Test 2 57.0 293.1 13.7 131.7 306.8 438.5 850.0 62.0 3.757 115.9 155.4 94.8	Test 3 71.5 293.1 10.5 165.2 303.6 468.8 660.0 62.9 2.917 104.7 140.4 85.6
kWh per Acre Foot: Overall Plant Efficiency (%)	647 63 .2	741 60.6	862 55.6
Customer Meter, GPM	1,114		

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

DAN L. JOHNSON Manager Hydraulic Services

Customer Meter, GPM

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: BARN WELL

Location: 51320 150TH ST W HP: 150

Cust. #: 0-007-7591 Serv. Acct. #: 018-2023-06

Meter: 345M-6350 Pump Ref #: 10587

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 12, 2007, billing history for the past 12 months, and your current rate of TOU-PA-7B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

1. Overall Plant Efficiency can be improved from 63.2% to 70.0%.

2. This can save you up to 58,460 kWh and \$5,223.44 annually.

	Plant E	fficiency	
Total kWh kW Input kWh per Acre Foot Acre Feet per Year	Existing 601,332 123.9 647 929.4	<u>Improved</u> 542,872 111.9 584	<u>Savings</u> 58,460 12.0 63
Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.09 \$57.81 63.2	\$52.19 70.0	\$5.62
Total Annual Cost	\$53,729.01	\$48,505.58	\$5,223.44

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 19, 2008

2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant

BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

018-2023-06 Serv. Acct. #:

10587

Pump Ref.#: 345M-6350 Meter:

In accordance with your request, a test was made on your turbine well pump on September 15, 2008. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Pump: Motor:	Equipment PEERL NEWM	No: No:	NO PLATE S1190103	
Results Discharge Pressure, PSI Standing Water Level, Feet Drawdown, Feet Discharge Head, Feet Pumping Water Level, Feet Total Head, Feet Capacity, GPM GPM per Foot Drawdown Acre Feet Pumped in 24 Hour kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, R kWh per Acre Foot Overall Plant Efficiency (%) Customer Meter, GPM	124.3 166.7 103.3	3 0 0 0 4	Test 2 54.5 296.2 14.0 125.9 310.2 436.1 862 61.6 3.810 115.7 155.2 96.2 729 61.2	Test 3 68.5 296.2 10.8 158.2 307.0 465.2 668 61.9 2.953 105.4 141.3 87.6

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.



September 19, 2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

018-2023-06 Serv. Acct. #:

345M-6350 Meter:

Pump Ref.#:

10587

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 15, 2008, billing history for the past 12 months, and your current rate of TOU-PA-7B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 63.4% to 70.0%.
- 2. This can save you up to 54,505 kWh and \$4,718.47 annually.

2. This can save you up to any	Existing	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot	576,816 124.3 620 930.5	522,311 112.6 561	54,505 11.7 59
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.09 \$53.66 63.4	\$48.59 70.0	\$5.07
Total Annual Cost	\$49,934.96	\$45,216.49	\$4,718.47

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

018-2023-06

10587

Serv. Acct. #: Pump Ref.#: 345M-6350 Meter:

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 9, 2009. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

	Pump: Motor:	Equipment PEERL NEWM	No: No:	NO PLATE S1190103	
Resu	ılts	-	Tes	<u>t 1</u>	Test 2
Standing W Drawdown Discharge Pumping W Total Head Capacity, G GPM per F Acre Feet kW Input t HP Input t Motor Loa Measured Customer	Head, Feet Vater Level, I, Feet GPM Foot Drawdo Pumped in 2 o Motor o Motor	Feet wn 24 Hours ump, RPM	293 11 9 31 40 5 6 4.3 11 16 5 1,	9.0 8.7 5.7 0.1 4.4 4.5 982 9.2.5 340 19.8 60.7 99.6 780 042 663 62.4	55.8 298.7 12.8 128.9 311.5 440.4 817 63.8 3.611 112.6 151.0 93.6

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

BARN WELL

Location: 51320 150TH ST W Serv. Acct. #: HP: 150

Cust #: 0-007-7591

018-2023-06

345M-6350 Meter:

Pump Ref.#:

10587

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 9, 2009, billing history for the past 12 months, and your current rate of TOU-PA-7B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 62.4% to 70.0%.
- 2. This can save you up to 59,727 kWh and \$4,981.86 annually.
- 3. These kWh savings translate to a 26-ton decrease in CO₂ emissions.

These kvvii savings translation	Existing	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot	552,888 119.8 663	493,161 106.9 591	59,727 12.9 72
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	834.5 \$0.08 \$55.26 62.4	\$49.29 70.0	\$5.97
Total Annual Cost	\$46,116.39	\$41,134.52	\$4,981.86 concerns over

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

BARN WELL

Location: 51320 150TH ST W Serv. Acct. #: HP: 150

Cust #: 0-007-7591

018-2023-06

345M-6350 Meter:

Pump Ref.#:

10587

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 5, 2010. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump: Motor: PEERL NEWMN No: NO PLATE

No: S1190103

Results -

Di James Drocesure PSI	47.6
Discharge Pressure, PSI Standing Water Level, Feet	290.0
Standing Water Love, 1	15.4
Drawdown, Feet	110.0
Discharge Head, Feet	305.4
Pumping Water Level, Feet	415.4
Total Head, Feet	941
Capacity, GPM	61.1
GPM per Foot Drawdown	4.159
Acre Feet Pumped in 24 Hours	119.8
kW Input to Motor	160.7
HP Input to Motor	99.6
Motor Load (%)	1,783
Measured Speed of Pump, RPM	1,037
Customer Meter, GPM	691
kWh per Acre Foot	61.4
Overall Plant Efficiency (%)	01.4

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

018-2023-06 Serv. Acct. #:

Meter:

10587 Pump Ref.#: 345M-6350

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 5, 2010, billing history for the past 12 months, and your current rate of TOU-PA-B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 61.4% to 70.0%.
- 2. This can save you up to 50,894 kWh and \$5,207.43 annually.
- 3. These kWh savings translate to a 22-ton decrease in CO₂ emissions.

. These kyvii saviiigs translate tr	Existing	Plant Efficiency Improved	Savings
Total kWh kW Input kWh per Acre Foot	416,352 119.8 691 602.2	365,458 105.2 607	50,894 14.6 85
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.10 \$70.74 61.4	\$62.10 70.0	\$8.65
Total Annual Cost	\$42,601.14	\$37,393.70	\$5,207.43 concerns over

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

September 9, 2011

2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

018-2023-06 Serv. Acct. #:

Meter: 345M-6350

10587 Pump Ref.#:

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 7, 2011. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Pump: Motor:	Equipment PEERL NEWMN	No: No:		
Results Discharge Pressure, Ps Standing Water Level, Drawdown, Feet Discharge Head, Feet Pumping Water Level, Total Head, Feet Capacity, GPM GPM per Foot Drawdo Acre Feet Pumped in S kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of P Customer Meter, GPM	SI Feet Feet own 24 Hours	Tes 329 11 8 30 38 1,4 6 4.		Test 2 55.0 290.0 13.3 127.1 303.3 430.4 858 64.5 3.792 115.8 155.3 96.3
kWh per Acre Foot Overall Plant Efficie	ncy (%)		62.4	60.1

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.



September 9, 2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS,

Plant: BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

018-2023-06 Serv. Acct. #:

345M-6350 Meter:

10587 Pump Ref.#:

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 7, 2011, billing history for the past 12 months, and your current rate of TOU-PA-B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 62.4% to 70.0%.
- 2. This can save you up to 54,113 kWh and \$5,514.14 annually.
- 3. These kWh savings translate to a 24-ton decrease in CO₂ emissions.

Existing 497,736 123.2 636 782.6 \$0.10 \$64.81	Plant Efficiency Improved 443,623 109.8 567 \$57.76	<u>Savings</u> 54,113 13.4 69 \$7.05
\$50,719,30	\$45,205.16	\$5,514.14
	497,736 123.2 636 782.6 \$0.10 \$64.81 62.4	Existing Improved 497,736

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 14, 2012

2012

JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

Serv. Acct. #:

018-2023-06

Meter:

345M-6350

Pump Ref.#:

10587

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 10, 2012. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Pump: Motor:	Equipment PEERL NEWMN	No: No:	NO PLATE S1190103	
Results Discharge Pressure, F Standing Water Level, Drawdown, Feet Discharge Head, Feet Pumping Water Level Total Head, Feet Capacity, GPM GPM per Foot Drawd Acre Feet Pumped in kW Input to Motor HP Input to Motor HP Input to Motor Motor Load (%) Measured Speed of F Customer Meter, GP kWh per Acre Foot Overall Plant Efficience	Feet , Feet own 24 Hours Pump, RPM M	82 285 367 1,1 6 4.9 12 17 10 1,7	 5.5 3.3 7.3 2.0 5.6	Test 2 44.5 268.3 16.0 102.8 284.3 387.1 1,048 65.5 4.632 124.5 167.0 103.5

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.



September 14, 2012

JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: BARN WELL

Location: 51320 150TH ST W

HP: 150

Cust #: 0-007-7591

Serv. Acct. #:

018-2023-06

Meter: 345M-6350 Pump Ref.#:

10587

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 10, 2012, billing history for the past 12 months, and your current rate of TOU-PA-B.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 60.2% to 70.0%.
- 2. This can save you up to 69,173 kWh and \$6,383.33 annually.
- These kWh savings translate to a 30-ton decrease in CO₂ emissions.

	Existing	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot Acre Feet per Year	496,416 128.0 624 795.5 \$0.09	427,243 110.2 537	69,173 17.8 87
Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$57.58 60.2	\$49.56 70.0	\$8.02
Total Annual Cost	\$45,809.27	\$39,425.94	\$6,383.33

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



House Well

An EDISON INTERNATIONAL® Company

CONFIDENTIAL/PROPRIETARY INFORMATION

November 1, 2004

Jose Maritorena, Inc. 300 E Panama Rd. Bakersfield, CA 93307 2004

SUBJECT:

HYDRAULIC TEST RESULTS - HOUSE WELL

ACCT: (Not applicable - diesel engine)

434 448 155th St West

DATE OF TEST: 10/25/04

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact Rick Koch at (661)726-5662.

EQUIPMENT

PUMP: L&B

NO: NO PLATE

MOTOR: CUMMINS

NO: 14045883

TEST RESULTS

	TEST 1
Discharge Pressure, PSI	54.5
Standing Water Level, Ft	298.7
Discharge Head, Ft.	125.9
Capacity, GPM	962
Acre Ft. Pumped in 24 Hrs.	4.252
Fuel Consumption, GPH	8.5
Input, Thermal HP	467.5
Customer's Engine Tachome	eter, RPM 1775
Measured Speed of Pump, R	PM 1775

During testing, the engine speed was set to represent a typical electric motor RPM. We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column. Fuel consumption rates are based on the customer's engine computer display gauge and Thermal Horsepower was calculated using 140000 btu/gallon for diesel #2.

DAN JOHNSON

Hydraulic/Industrial Test Supervisor



CONFIDENTIAL/PROPRIETARY INFORMATION

September 9, 2005

2005

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - HOUSE WELL

434 155TH ST W

CUST #: 0-007-7591 - SERV ACCT #: 026-3450-99

DATE OF TEST: September 8, 2005

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

PUMP: L&B NO: 16814

MOTOR: US NO: 670757 250 HP

METER: V349N-478

HYDRAULIC TEST REFERENCE NUMBER: 25855

TEST RESULTS

Discharge Pressure, PSI	40.5
Standing Water Level, Ft.	309.1
Drawdown, Ft.	
Discharge Head, Ft.	93.6
Pumping Water Level, Ft.	
Total Head, Ft.	
Capacity, GPM	1,229.0
GPM per Ft. Drawdown	
Acre Ft. Pumped in 24 Hrs.	5.432
kW Input to Motor	144.0
HP Input to Motor	193.1
Motor Load (%)	71.4
Measured Speed of Pump, RPM	1,788
kWh per Acre Ft.	636
Overall Plant Efficiency (%)	
Customer Meter, GPM	1,119.0

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column. This pump is operating in an efficient manner, however records indicate little or no usage during the last twelve months.

Manager

Hydraulic Services

/ JOHNSON



September 15, 2006

2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: HOUSE WELL

Location: 434 155TH ST W HP: 250

Serv. Acct. #: 026-5797-39 OK Cust. #: 0-007-7591

Pump Ref #: 25855 Meter: V349N-478

In accordance with your request, a test was made on your turbine well pump on September 13, 2006. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

No.: 16814 Pump Mfg.: L&B No.: 670757 Motor Mfg.: US

RESULTS

RESULTS	39.5
Discharge Pressure, PSI	• • • • •
Standing Water Level, Feet	324.3
Drawdown, Feet	91.2
Discharge Head, Feet	011
Pumping Water Level, Feet	
Total Head, Feet	1,213.0
Capacity, GPM	1,210.0
GPM per Foot Drawdown	5.361
Acre Feet Pumped in 24 Hours	141.1
kW Input to Motor	
HP Input to Motor	189.2
Motor Load (%)	70.0
Measured Speed of Pump, RPM	1,787
Weasured Speed of Lamp, Tall	632
kWh per Acre Foot: Overall Plant Efficiency (%) Customer Meter, GPM	1,087.0

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column.

DAN LAOHNSON Manager

Hydraulic Services



September 15, 2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: HOUSE WELL

Location: 434 155TH ST W HP: 250

Serv. Acct. #: 026-5797-39 Cust. #: 0-007-7591

Pump Ref #: 25855 Meter: V349N-478

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 13, 2006, billing history for the past 12 months, and your current rate of TOU-PA-B.

Total Annual Cost	\$39,974.65
Average Cost per Acre Foot	\$69.20
Average Cost per kWh	\$0.11
Acre Feet per Year	577.7
kWh per Acre Foot	632
kW Input	141.1
Total kWh	364,932
	<u>Existing</u>

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

DAN LAOPNSON Manager

Hydraulic Services

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: HOUSE WELL

Location: 434 155TH STW HP: 250

Cust. #: 0-007-7591

Serv. Acct. #: 026-5797-39

Meter: V349N-478

Pump Ref #: 25855

In accordance with your request, a test was made on your turbine well pump on September 13, 2007. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

	EGOH INTELL
Pump Mfg.: L&B Motor Mfg.: US	No.: 16814 No.: 670757

RESULTS	
	33.0
Discharge Pressure, PSI	314.8
Standing Water Level, Feet	
Drawdown, Feet	76.2
Discharge Head, Feet	
Pumping Water Level, Feet	
Total Head, Feet	4 274 0
Capacity, GPM	1,271.0
GPM per Foot Drawdown	= 040
Acre Feet Pumped in 24 Hours	5.618
kW Input to Motor	144.1
HP Input to Motor	193.2
Motor Load (%)	71.5
Measured Speed of Pump, RPM	1,786
Weasured Speed of Famp, Farm	616
kWh per Acre Foot:	
Overall Plant Efficiency (%)	1,131
Customer Meter, GPM	1,101

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column.



September 14, 2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: HOUSE WELL

Location: 434 155TH ST W HP: 250

Cust. #: 0-007-7591 Serv. Acct. #: 026-5797-39

Meter: V349N-478 Pump Ref #: 25855

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 13, 2007, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	<u>Existing</u>
Total kWh	366,780
kW Input	144.1
kWh per Acre Foot	616
Acre Feet per Year	595.7
Average Cost per kWh	\$0.11
Average Cost per Acre Foot	\$64.77
Total Annual Cost	\$38,585.26

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 19, 2008

2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

HOUSE WELL

Location: 434 155TH ST W

HP: 250

Cust #: 0-007-7591

026-5797-39

Meter: V349N-478

Serv. Acct. #: Pump Ref.#:

25855

In accordance with your request, a test was made on your turbine well pump on September 16, 2008. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

	Equipment		
Pump:	L&B	No:	16814
Motor:	US	No:	670757
	_		
Resul	ts		
Discharge Pr	ressure, PSI		43.0
	iter Level, Feet		320.6
Drawdown, I	Feet		
Discharge H			99.3
Pumping Wa	ater Level, Feet		
Total Head,	Feet		
Capacity, GF			1,196
•	ot Drawdown		
Acre Feet Po	umped in 24 Hours		5.286
kW Input to	Motor		141.1
HP Input to I	Votor		189.2
Motor Load	(%)		71.3
	peed of Pump, RPM		1,785
kWh per Act			641
	t Efficiency (%)		
Customer M	eter, GPM		1,065

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column.



September 19, 2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

HOUSE WELL

Location: 434 155TH ST W Serv. Acct. #: HP: 250

Cust #: 0-007-7591

026-5797-39

V349N-478 Meter:

Pump Ref.#:

25855

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 16, 2008, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	Existing
	435,204
Total kWh	141.1
kW Input	641
kWh per Acre Foot	679.2
Acre Feet per Year	\$0.10
Average Cost per kWh Average Cost per Acre Foot	\$62.83
Total Annual Cost	\$42,676.10

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

HOUSE WELL

Location: 434 155TH ST W Serv. Acct. #: HP: 250

Cust #: 0-007-7591

026-5797-39

25855

Pump Ref.#: V349N-478 Meter:

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 9, 2009. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

E	q	u	Ĭ	p	ľ	n	е	n	t	•

No: 16814 L&B Pump: No: 670757 US Motor:

Results -

Discharge Pressure, PSI	42.3
Standing Water Level, Feet	329.3
Drawdown, Feet Discharge Head, Feet Pumping Water Level, Feet	97.7
Total Head, Feet Capacity, GPM	1,213
GPM per Foot Drawdown Acre Feet Pumped in 24 Hours kW Input to Motor HP Input to Motor Motor Load (%)	5.361 139.7 187.3 70.6 1,788
Measured Speed of Pump, RPM Customer Meter, GPM kWh per Acre Foot Overall Plant Efficiency (%)	1,760 1,031 625

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column.



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

HOUSE WELL

Location: 434 155TH ST W Serv. Acct. #: HP: 250

Cust #: 0-007-7591

026-5797-39

V349N-478 Meter:

Pump Ref.#:

25855

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 9, 2009, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	<u>Existing</u>
	467,808
Total kWh	139.7
kW Input	625
kWh per Acre Foot	747.9
Acre Feet per Year	\$0.09
Average Cost per kWh Average Cost per Acre Foot	\$57.67
Total Annual Cost	\$43,131.90

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 8, 2010

2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

HOUSE WELL

Location: 434 155TH ST W

HP: 250

Cust #: 0-007-7591

026-5797-39 Serv. Acct. #:

Pump Ref.#: 25855 Meter: V349N-478

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 6, 2010. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

No: 16814 L&B Pump: No: 670757 US Motor:

Results -

Discharge Pressure, PSI	50.3
Standing Water Level, Feet	304.5
Drawdown, Feet	
Discharge Head, Feet	116.2
Pumping Water Level, Feet	
Total Head, Feet	
Capacity, GPM	1,155
GPM per Foot Drawdown	= 405
Acre Feet Pumped in 24 Hours	5.105
kW Input to Motor	138.2
HP Input to Motor	185.3
Motor Load (%)	69.8
Measured Speed of Pump, RPM	1,787
Customer Meter, GPM	1,043
kWh per Acre Foot	650
Overall Plant Efficiency (%)	

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

HOUSE WELL

Location: 434 155TH ST W Serv. Acct. #: HP: 250

Cust #: 0-007-7591

026-5797-39

V349N-478 Meter:

Pump Ref.#:

25855

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 6, 2010, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	<u>Existing</u>
	412,260
Total kWh	138.2
kW Input	650
kWh per Acre Foot	634.4
Acre Feet per Year	\$0.10
Average Cost per kWh Average Cost per Acre Foot	\$63.10
Total Annual Cost	\$40,030.45

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 9, 2011



ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: HOUSE-WELL

Location: 434 155TH ST W

HP: 250

Cust #: 0-007-7591

Serv. Acct. #:

026-5797-39

Meter: V349N-478

Pump Ref.#:

25855

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 7, 2011. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump:

L&B

No: 16814

Motor:

US

No: 670757

Results

Discharge Pressure, PSI	39.3
Standing Water Level, Feet	306.2
Drawdown, Feet	
Discharge Head, Feet	90.8
Pumping Water Level, Feet	
Total Head, Feet	
Capacity, GPM	1,254
GPM per Foot Drawdown	
Acre Feet Pumped in 24 Hours	5.543
kW Input to Motor	144.2
HP Input to Motor	193.4
Motor Load (%)	72.9
Measured Speed of Pump, RPM	1,788
Customer Meter, GPM	1,136
kWh per Acre Foot	625
Overall Plant Efficiency (%)	

We were unable to measure the water levels with our sounder line and the air line is inoperative or missing. Therefore, we are unable to determine the total pumping head and overall plant efficiency. The standing level was measured down through the pump column.



September 9, 2011

2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: HOUSE WELL

HP: 250

Location: 434 155TH ST W

Cust #: 0-007-7591

Serv. Acct. #:

026-5797-39

Meter: V349N-478

Pump Ref.#:

25855

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 7, 2011, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

Total Annual Cost	\$30,909.79
Average Cost per Acre Foot	\$63.41
Average Cost per kWh	\$0.10
Acre Feet per Year	
kWh per Acre Foot	487.5
kW Input	625
	144.2
Total kWh	304,440
	<u>Existing</u>

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 14, 2012



JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant HOUSE WELL

Location: 434 155TH ST W

HP: 250

Cust #: 0-007-7591

Serv. Acct. #: 03

026-5797-39

Meter: V349N-478

Pump Ref.#:

25855

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 11, 2012. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump: Motor: L&B US No: 16814

No: 670757

Results -

Discharge Pressure, PSI	48.5
Standing Water Level, Feet	301.0
Drawdown, Feet	46.6
Discharge Head, Feet	112.0
Pumping Water Level, Feet	347.6
Total Head, Feet	459.6
Capacity, GPM	1,196
GPM per Foot Drawdown	25.7
Acre Feet Pumped in 24 Hours	5.286
kW Input to Motor	142.4
HP Input to Motor	191.0
Motor Load (%)	72.0
Measured Speed of Pump, RPM	1,788
Customer Meter, GPM	1,051
kWh per Acre Foot	647
Overall Plant Efficiency (%)	72.7



September 14, 2012

JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: HOUSE WELL

Location: 434 155TH ST W HP: 250

Cust #: 0-007-7591 Serv. Acct. #: 026-5797-39

Meter: V349N-478 Pump Ref.#: 25855

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 11, 2012, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

Total kWh kW Input kWh per Acre Foot Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	Existing 516,240 142.4 647 798.4 \$0.08 \$53.79 72.7
Total Annual Cost	\$42,940.84

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Ave A well

CONFIDENTIAL/PROPRIETARY INFORMATION

November 1, 2004

Jose Maritorena, Inc. 300 E Panama Rd. Bakersfield, CA 93307

SUBJECT:

HYDRAULIC TEST RESULTS - AVENUE A WELL

ACCT: (Not applicable – diesel engine)
N/S AVENUE A W/O 150TH WEST

DATE OF TEST: 10/25/04

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact Rick Koch at (661)726-5662.

EQUIPMENT

PUMP: L&B

NO: NO PLATE

MOTOR: CUMMINS

NO: 14045901

TEST RESULTS

	TEST 1	TEST 2
Discharge Pressure, PSI	66.5	45.5
Standing Water Level, Ft	290.5	290.5
Drawdown, Ft	18.3	20.7
Discharge Head, Ft.	153.6	105.1
Pumping Water Level, Ft.	308.8	311.2
Total Head, Ft.	462.4	416.3
Capacity, GPM	1084	1194
GPM per Ft Drawdown	59.2	57.7
Acre Ft. Pumped in 24 Hrs.	4.791	5.277
Fuel Consumption, GPH	7.9	8.0
Input, Thermal HP	434.5	440.0
Water HP	126.6	125.5
Customer's Engine Tachometer, RPM	1625	1625
Measured Speed of Pump, RPM	1787	1787
Overall Plant Efficiency (%)	29.1	28.5

During testing, the engine speed was set to represent a typical electric motor RPM. Test 1 was pumping to the center pivot with a higher than normal discharge pressure. For Test 2 another line was opened to simulate a normal operating pressure. Fuel consumption rates are based on the customer's engine computer display gauge and Thermal HP was calculated using 140000 btu/gallon for diesel #2.

DAN JOHNSON

Hydraulic/Industrial Test Supervisor



CONFIDENTIAL/PROPRIETARY INFORMATION

September 9, 2005

2005

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

SUBJECT: HYDRAULIC TEST RESULTS - A WELL

15183 W AVENUE A

CUST #: 0-007-7591 - SERV ACCT #: 026-4284-96

DATE OF TEST: September 7, 2005

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

PUMP: L&B NO: NO PLATE

MOTOR: US NO: C603072-739 200 HP

METER: 349-13899

HYDRAULIC TEST REFERENCE NUMBER: 25854

TEST RESULTS

Discharge Pressure, PSI	38.7
Standing Water Level, Ft.	298.6
Drawdown, Ft.	20.8
Discharge Head, Ft.	89.4
Pumping Water Level, Ft.	319.4
Total Head, Ft.	408.8
Capacity, GPM	1,3290
GPM per Ft. Drawdown	63.9
Acre Ft. Pumped in 24 Hrs.	5.874
kW Input to Motor	149.4
HP Input to Motor	200.3
Motor Load (%)	92.2
Measured Speed of Pump, RPM	1,781
kWh per Acre Ft.	611
Overall Plant Efficiency (%)	68.5
Customer Meter, GPM	1,268.0

This pump is operating in an efficient manner, however records indicate little or no usage during the last twelve months.

Managér

Hydraulic Services

JOHNSON'



September 15, 2006

2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: A WELL

Location: 15183 W AVENUE A HP: 200

Cust. #: 0-007-7591 Serv. Acct. #: 026-4284-96
Meter: 349M-9505 Pump Ref #: 25854

In accordance with your request, a test was made on your turbine well pump on September 13, 2006. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

Pump Mfg.: L&B No.: NO PLATE No.: C603072-739

RESULTS

11202.0	
Discharge Pressure, PSI	40.0
Standing Water Level, Feet	300.2
Drawdown, Feet	20.7
Discharge Head, Feet	92.4
Pumping Water Level, Feet	320.9
Total Head, Feet	413.3
Capacity, GPM	1,312.0
GPM per Foot Drawdown	63.4
Acre Feet Pumped in 24 Hours	5.799
kW Input to Motor	148.6
HP Input to Motor	199.3
	91.7
Motor Load (%)	1,780
Measured Speed of Pump, RPM	615
kWh per Acre Foot:	68.7
Overall Plant Efficiency (%)	
Customer Meter, GPM	1,246.0

DAN L. JOHNSON

Manager

Hydraulic Services



September 15, 2006

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: A WELL

Location: 15183 W AVENUE A HP: 200

Cust. #: 0-007-7591

Serv. Acct. #: 026-4284-96 OK

Existing

Meter: 349M-9505

Pump Ref #: 25854

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 13, 2006, billing history for the past 12 months, and your current rate of TOU-PA-B.

	Existing
Total kWh	455,904
kW Input	148.6
kWh per Acre Foot	615
Acre Feet per Year	741.2
Average Cost per kWh	\$0.10
Average Cost per Acre Foot	\$61.56
Overall Plant Efficiency (%)	68.7
Total Annual Cost	\$45,626.87

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

DAN LAOMNSON

Manager

Hydraulic Services

SOUTHERN CALIFORNIA EDISON An EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: A WELL

Location: 15183 W AVENUE A HP: 200

Cust. #: 0-007-7591

Serv. Acct. #: 026-4284-96

Meter: 349M-9505

Pump Ref #: 25854

In accordance with your request, a test was made on your turbine well pump on September 13, 2007. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

EQUIPMENT

Pump Mfg.: L&B Motor Mfg.: US No.: NO PLATE No.: C603072-739

RESULTS

Discharge Pressure, PSI	43.5
Standing Water Level, Feet	302.6
Drawdown, Feet	19.9
Discharge Head, Feet	100.5
Pumping Water Level, Feet	322.5
Total Head, Feet	423.0
Capacity, GPM	1,255.0
GPM per Foot Drawdown	63.1
Acre Feet Pumped in 24 Hours	5.547
kW Input to Motor	148.3
HP Input to Motor	198.9
Motor Load (%)	91.5
Measured Speed of Pump, RPM	1,781
kWh per Acre Foot:	642
Overall Plant Efficiency (%)	67.4
Customer Meter, GPM	1,207

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

Confidential / Proprietary Information

September 14, 2007

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: A WELL

Location: 15183 W AVENUE A HP: 200

Cust. #: 0-007-7591 Serv. Acct. #: 026-4284-96

Meter: 349M-9505 Pump Ref #: 25854

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 13, 2007, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	Existing
Total kWh	608,052
kW Input	148.3
kWh per Acre Foot	642
Acre Feet per Year	947.5
Average Cost per kWh	\$0.09
Average Cost per Acre Foot	\$57.03
Overall Plant Efficiency (%)	67.4
Total Annual Cost	\$54,037.58

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 19, 2008



ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

A WELL

Location: 15183 W AVENUE A

HP: 200

026-4284-96

Cust #: 0-007-7591

Serv. Acct. #:

25854

Pump Ref.#: 349M-9505 Meter:

In accordance with your request, a test was made on your turbine well pump on September 15, 2008. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Pump: Motor:	Equipment L&B US	No: No:	NO PLATE C603072-739
Standing Wood Drawdown, Discharge Head, Capacity, German G	ressure, PSI ater Level, Feet Feet lead, Feet ater Level, Feet Feet PM bot Drawdown lumped in 24 Hours Motor Motor (%) Speed of Pump, RPM lore Foot ht Efficiency (%)		51.5 303.1 20.7 119.0 323.8 442.8 1,231 59.5 5.441 146.8 196.9 92.0 1,784 648 69.9 1,149



September 19, 2008

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

 PUMPING COST ANALYSIS, Plant:
 A WELL

 Location: 15183 W AVENUE A
 HP: 200

 Cust #: 0-007-7591 Serv. Acct. #: 026-4284-96
 026-4284-96

 Meter: 349M-9505 Pump Ref.#: 25854

The following analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 15, 2008, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	<u>Existing</u>
Total kWh	522,876
	146.8
kW input	648
kWh per Acre Foot	807.4
Acre Feet per Year	\$0.09
Average Cost per kWh	\$56.57
Average Cost per Acre Foot	69.9
Overall Plant Efficiency (%)	
Total Annual Cost	\$45,667.99

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 11, 2009

2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

A WELL

Location: 15183 W AVENUE A

HP: 200

Cust #: 0-007-7591

.007-7591 Serv. Acct. #:

026-4284-96

Meter: 349

349M-9505

Pump Ref.#:

25854

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 9, 2009. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

			NO DIATE
Pump:	L&B	No:	NO PLATE
r ump.		A1	0000072 720
Motor:	US	NO:	C603072-739

Results

Discharge Pressure, PSI	46.0
Standing Water Level, Feet	308.8
Drawdown, Feet	28.2
Discharge Head, Feet	106.3
Pumping Water Level, Feet	337.0
Total Head, Feet	443.3
Capacity, GPM	1,243
GPM per Foot Drawdown	44.1
Acre Feet Pumped in 24 Hours	5.494
kW Input to Motor	145.4
HP Input to Motor	195.0
Motor Load (%)	91.2
Measured Speed of Pump, RPM	1,782
Customer Meter, GPM	1,205
kWh per Acre Foot	635
Overall Plant Efficiency (%)	71.4
Overall Flatic Linciency (70)	



September 11, 2009

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant:

Location: 15183 W AVENUE A

Cust #: 0-007-7591 Serv. Acct. #:

HP: 200 026-4284-96

Cust #: 0-007-7591 Meter: 349M-9505

Pump Ref.#:

25854

A WELL

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 9, 2009, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	<u>Existing</u>
Total kWh	540,156
	145.4
kW Input kWh per Acre Foot	635
Acre Feet per Year	850.3
Average Cost per kWh	\$0.09
Average Cost per Acre Foot	\$55.99
Overall Plant Efficiency (%)	71.4
Total Annual Cost	\$47,603.95

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



October 8, 2010

2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant:

A WELL

Location: 15183 W AVENUE A

HP: 200

Cust #: 0-007-7591

026-4284-96

Serv. Acct. #:

349M-9505 Meter:

Pump Ref.#:

25854

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 6, 2010. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump:	L&B	No:	NO PLATE
Motor:	US	No:	C603072-739

Results -

Measured Speed of Pump, RPM 1	55.7 .937 40.9 88.9
Acre Feet Pumped in 24 Hours kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM 1	
Acre Feet Pumped in 24 Hours kW Input to Motor HP Input to Motor Motor Load (%) Measured Speed of Pump, RPM 1	35.7
kW Input to Motor 1 HP Input to Motor 1 Motor Load (%) Measured Speed of Pump, RPM 1	937
HP Input to Motor 1 Motor Load (%) Measured Speed of Pump, RPM 1	40.9
Motor Load (%) Measured Speed of Pump, RPM 1	38.9
Measured Speed of Pump, RPM 1	88.3
Customer Motor CDM	
Customer Meter, GPM 1	784
kWh per Acre Foot	,784 ,008
Overall Plant Efficiency (%)	•



October 8, 2010

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: A Location: 15183 W AVENUE A

A WELL

Cust #: 0-007-7591

HP: 200 026-4284-96

Meter: 349M-9505

Serv. Acct. #: 0: Pump Ref.#: 2

25854

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 6, 2010, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

	<u>Existing</u>
Total kWh	449,148
kW Input	140.9
kWh per Acre Foot	685
Acre Feet per Year	655.6
Average Cost per kWh	\$0.09
Average Cost per Acre Foot	\$63.89
Overall Plant Efficiency (%)	71.6
Total Annual Cost	\$41,887.54

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

September 9, 2011

2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: A WELL

Location: 15183 W AVENUE A

HP: 200

Cust #: 0-007-7591

Serv. Acct. #:

026-4284-96

Meter: 349M-9505

Pump Ref.#:

25854

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 7, 2011. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump:	L&B	No:	NO PLATE
Motor:	US	No:	C603072-739

Results

Discharge Pressure, PSI	39.2
Standing Water Level, Feet	301.6
Drawdown, Feet	20.2
Discharge Head, Feet	90.6
Pumping Water Level, Feet	321.8
Total Head, Feet	412.4
Capacity, GPM	1,312
GPM per Foot Drawdown	65.0
Acre Feet Pumped in 24 Hours	5.799
kW Input to Motor	147.0
HP Input to Motor	197.1
Motor Load (%)	92.2
Measured Speed of Pump, RPM	1,779
Customer Meter, GPM	1,233
kWh per Acre Foot	608
Overall Plant Efficiency (%)	69.3

RUSS JOHNSON Manager Hydraulic Services

10180 Telegraph Road Ventura. CA 93004

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

September 9, 2011

ATTN: JEAN MARITORENA JOSE MARITORENA, INC 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: A WELL

Location: 15183 W AVENUE A

HP: 200

Cust #: 0-007-7591

Serv. Acct. #:

026-4284-96

Meter: 349M-9505

Pump Ref.#:

25854

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 7, 2011, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 69.3% to 72.0%.
- 2. This can save you up to 22,765 kWh and \$1,685.03 annually.
- 3. These kWh savings translate to a 9.9-ton decrease in CO₂ emissions.

	<u>Existing</u>	Plant Efficiency Improved	<u>Savings</u>
Total kWh kW Input kWh per Acre Foot	609,864 147.0 608 1,002.3	587,099 141.5 586	22,765 5.5 23
Acre Feet per Year Average Cost per kWh Average Cost per Acre Foot Overall Plant Efficiency (%)	\$0.07 \$45.04 69.3	\$43.36 72.0	\$1.68
Total Annual Cost	\$45,142.13	\$43,457.10	\$1,685.03

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



September 14, 2012

2012

JEAN MARITORENA JOSE MARITORENA, INC. 300 E PANAMA RD BAKERSFIELD, CA 93307-6261

HYDRAULIC TEST RESULTS, Plant: A WELL

Location: 15183 W AVENUE A

HP: 200

Cust #: 0-007-7591

Serv. Acct. #:

026-4284-96

Meter:

349M-9505

Pump Ref.#:

25854

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 10, 2012. If you have any questions regarding the results which follow, please contact RICK KOCH at (805)654-7312.

Equipment

Pump: Motor: L&B US No: NO PLATE

No: C603072-739

Results -

Discharge Pressure, PSI	52.6
Standing Water Level, Feet	283.7
Drawdown, Feet	18.0
Discharge Head, Feet	121.5
Pumping Water Level, Feet	301.7
Total Head, Feet	423.2
Capacity, GPM	1,223
GPM per Foot Drawdown	67.9
Acre Feet Pumped in 24 Hours	5.406
kW Input to Motor	144.3
HP Input to Motor	193.5
Motor Load (%)	90.5
Measured Speed of Pump, RPM	1,781
Customer Meter, GPM	1,159
kWh per Acre Foot	641
Overall Plant Efficiency (%)	67.5



September 14, 2012

2012-3

JEAN MARITORENA JOSE MARITORENA, INC. 300 È PANAMA RD BAKERSFIELD, CA 93307-6261

PUMPING COST ANALYSIS, Plant: A WELL

Location: 15183 W AVENUE A

HP: 200

Cust #: 0-007-7591

Serv. Acct. #: 0

026-4284-96

Meter: 349M-9505

Pump Ref.#:

25854

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 10, 2012, billing history for the past 12 months, and your current rate of TOU-PA-B-I.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 67.5% to 72.0%.
- 2. This can save you up to 32,011 kWh and \$2,423.27 annually.
- 3. These kWh savings translate to a 14-ton decrease in CO₂ emissions.

		Plant Efficiency	
<i>y</i>	Existing	Improved	<u>Savings</u>
Total kWh	517,152	485,141	32,011
kW Input	144.3	135.4	8.9
kWh per Acre Foot	641	601	40
Acre Feet per Year	807.1		
Average Cost per kWh	\$0.08		
Average Cost per Acre Foot	\$48.51	\$45.50	\$3.00
Overall Plant Efficiency (%)	67.5	72.0	
Total Annual Cost	\$39,148.41	\$36,725.14	\$2,423.27

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.