

EXHIBIT “E4” part 1

TO

EXHIBIT “1”

**TO STIPULATION RE: GROUNDWATER PUMPING AND WATER USE BY
BOLTHOUSE PROPERTIES, LLC**

Well:	
Meter:	
Legal:	
Location:	Duck 29-3

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: <u>D.A.P.M.</u>	H.P.: <u>450</u>	Volts:	R.P.M.: <u>1786</u>	Serial #: <u>6109014</u>
Frame:	Type:	Pump:	Type Oil Lube:	

Date:	11-27-06								
Standing Water	333'								
Draw Down	31								
Pumping Level	364'								
Lift Above Discharge	35								
Total Lift	399								
G.P.M.	2030								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	786	24.6	15 ^{lbs}	(2000cc/l)		1250			
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									

[illegible]

19

Well:	
Meter:	
Legal:	
Location:	Hammann 29-1

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: DARAM H.P.: 400 Volts: R.P.M.: 1750 Serial #: C105053
 Frame: Type: Pump: Type Oil Lube:

Date:	11-27-04								
Standing Water	322'								
Draw Down	43								
Pumping Level	365'								
Lift Above Discharge	60								
Total Lift	425								
G.P.M.	2071								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1750	25.8	26 ^{lbs}	(2200 gal.)	10 ² OP	250	well.		
KW Input									
KW Hours Per AC/Ft.									
BFF									
Cost Per AC/Ft.									

Well: _____

Meter: _____

Legal: _____

Location *min-22-2W*

9

Pump Data Installation Date: _____

Pump Setting: _____

Airline: _____

CT&S Size: _____

Bowls: _____

Well Depth: _____

Blank: _____

Perforations: _____

Motor: *Duram* H.P.: *300* Volts: _____ R.P.M.: *1789* Serial #: *B901032*

Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	<i>11-20-06</i>								
Standing Water:	<i>270'</i>								
Draw Down	<i>33</i>								
Pumping Level	<i>303'</i>								
Lift Above Discharge	<i>127</i>								
Total Lift	<i>430</i>								
G.P.M.	<i>2100</i>								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	<i>1789</i>	<i>21.6</i>	<i>5518</i>	<i>(2100) gpl</i>	<i>10"</i>	<i>2150 well</i>			
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									

Well:	
Meter:	
Legal:	
Location:	Wm 22-23

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: D. Penn H.P.: 300 Volts: _____ R.P.M.: 800 Serial #: B609034
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	11-21-06							
Standing Water	271'							
Draw Down	38							
Pumping Level	309'							
Lift Above Discharge	46							
Total Lift	355							
G.P.M.	1064							
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1800	12.9	20 Lbs	(1500 gal)		10"	240 wall	
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

Well: _____

Meter: _____

Legal: _____

Location: *Men 22-4*

Pump Data Installation Date: _____

Pump Setting: _____

Airline: _____

CT&S Size: _____

Bowls: _____

Well Depth: _____

Blank: _____

Perforations: _____

Motor: *DePau* H.P.: *200* Volts: _____ R.P.M.: *1790* Serial #: *C40111*

Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	<i>11-21-06</i>								
Standing Water	<i>288'</i>								
Draw Down	<i>47</i>								
Pumping Level	<i>336'</i>								
Lift Above Discharge	<i>116</i>								
Total Lift	<i>450.5</i>								
G.P.M.	<i>1692</i>								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	<i>1790</i>	<i>20.5</i>	<i>50 lbs</i>		<i>10" 250 wall</i>				
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									

10

Well:	
Meter:	
Legal:	
Location:	Man 22-3

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: D.P. Pump H.P.: 300 Volts: R.P.M.: 1750 Serial #: 201046
 Frame: Type: Pump: Type Oil Lube:

Date:	11-20-06								
Standing Water	283'								
Draw Down	63								
Pumping Level	346'								
Lift Above Discharge	134								
Total Lift	480								
G.P.M.	982								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1750	1027	678265	1300 gal	10" 250 wall				
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									

Well:	
Meter:	
Legal:	
Location:	Man 21-3-E

7

Well:	
Meter:	
Legal:	
Location:	Man 21-3 W

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: D e Rom H.P.: 400 Volts: R.P.M.: 1806 Serial #: B710008
 Frame: Type: Pump: Type Oil Lube:

Date:	11-20-06								
Standing Water	312'								
Draw Down	33								
Pumping Level	346'								
Lift Above Discharge	10.6								
Total Lift	451								
G.P.M.	2000								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1806	1-6/16	4-6 lbs	(2000 gal)					
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: DePan H.P.: 1/350 Volts: R.P.M.: 1780 Serial #: C304165
Frame: Type: Pump: Type Oil Lube:

Date:	11-27-06							
Standing Water	?							
Draw Down								
Pumping Level	? conf set							
Lift Above Discharge								
Total Lift	1500							
G.P.M.								
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1780	12.7	44 lbs	(1600 gpd)		250 wall		
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: De Pan H.P.: 460 Volts: _____ R.P.M.: 1773 Serial #: C111081
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	11-28-06							
Standing Water								
Draw Down	can							
Pumping Level	not set							
Lift Above Discharge		92						
Total Lift								
G.P.M.		1324						
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1773	16.1	40 ^{lbs}	(1700gpm)			12" IPS	250 wad.
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

29

Well:	
Meter:	
Legal:	
Location:	Pondie 283

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: De Ron H.P.: 200 Volts: R.P.M.: 1783 Serial #: 8912065
 Frame: Type: Pump: Type Oil Lube:

Date:	11-28-06								
Standing Water	327'								
Draw Down	14								
Pumping Level	341'								
Lift Above Discharge	8'								
Total Lift	429								
G.P.M.	964								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1783	38 ^{lbs}	11.7	(1200 ⁷)	10"	.250	all		
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									

30

Well: _____
Meter: _____
Legal: _____
Location: Parker 30-3

Pump Data Installation Date: _____
Pump Setting: _____
Airline: _____
CT&S Size: _____
Bowls: _____
Well Depth: _____
Blank: _____
Perforations: _____

Motor: Defcon H.P.: 200 Volts: _____ R.P.M.: _____ Serial #: 13712099
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	<u>11-22-06</u>								
Standing Water	<u>329'</u>								
Draw Down									
Pumping Level	<u>?</u>								
Lift Above Discharge	<u>4612</u>								
Total Lift									
G.P.M.	<u>652</u>								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	<u>1600</u>	<u>2.9</u>	<u>20465</u>	<u>(850)</u>	<u>10"</u>	<u>240</u>			
KW Input									
KW Hours Per AC/Ft.									
BFF									
Cost Per AC/Ft.									

Well:	
Meter:	
Legal:	
Location:	Rowan-2 -6

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: DERAN	H.P.: 300	Volts:	R.P.M.:	Serial #: C 208080
Frame:	Type:	Pump:	Type Oil Lube:	

Date:	1-3-07							
Standing Water	240'							
Draw Down	60							
Pumping Level	300'							
Lift Above Discharge	138							
Total Lift	438							
G.P.M.	4073							
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1500	13	6025				10" 250 wall	
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

Well:	
Meter:	
Legal:	
Location:	Rowan 2-33

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: Amarillo H.P.: 2.50 Volts: _____ R.P.M.: _____ Serial #: 5250202445
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	1-3-07							
Standing Water	202'							
Draw Down	34							
Pumping Level.	236'							
Lift Above Discharge	129							
Total Lift	365							
G.P.M.	450							
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1550	5.5	562 lbs	(500) 1/2 P/min	10"	250 wall		
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

48

Well:	
Meter:	
Legal:	
Location:	Rowen 2-1

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: DR-RAH H.P.: 300 Volts: R.P.M.: Serial #: C060-A1880011
Frame: Type: Pump: Type Oil Lube:

Date:	1-2-07								
Standing Water	418' 28 Lbs								
Draw Down	44								
Pumping Level	462 10 Lbs								
Lift Above Discharge	102'								
Total Lift									
G.P.M.	1133								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1750	2.12	27 Lbs	(1000) RPM	8"	.200 mesh			
KW Input									
KW Hours Per AC/Ft.									
BFP									
Cost Per AC/Ft.									

Airline Reading is not Good.

Well:	
Meter:	
Legal:	
Location:	S4P36-1

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: DERAN H.P.: 300 Volts: _____ R.P.M.: _____ Serial #: C109011
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	1-3-07							
Standing Water	27 4lbs							
Draw Down	0							
Pumping Level	0 1 lbs							
Lift Above Discharge	25							
Total Lift								
G.P.M.	726							
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1700	8.9	11 LBS	(800) RPM				
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

Airline Plugged

Well:	
Meter:	
Legal:	
Location:	Bushnell 10-4-E

Pump Data Installation Date:	
Pump Setting:	
Airline:	420
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: Johnson H.P.: 350 Volts: _____ R.P.M.: 1775 Serial #: 166047
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	11-29-06							
Standing Water	47 Lbs	311						
Draw Down		107						
Pumping Level	18 Lbs	378						
Lift Above Discharge		85						
Total Lift		463						
G.P.M.		1015						
GPM/FT		11.2						
AC Ft. In. 24 Hrs.								
HP Input RPM	1775	37 Lbs	12.3	(1100 RPM)	10" IPS	250 wall		
KW Input								
KW Hours Per AC/Ft.								
EPF								
Cost Per AC/Ft.								

Well:	
Meter:	
Legal:	
Location:	Pond 20-7 - S-E

Pump Data Installation Date:	
Pump Setting:	
Airline:	462
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: Johnson H.P.: 350 Volts: _____ R.P.M.: 1760 Serial #: 166048
 Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	11-28-06							
Standing Water	48 lbs	351						
Draw Down		23						
Pumping Level	38 lbs	374						
Lift Above Discharge		88						
Total Lift		462						
G.P.M.		1950						
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1750	23.7	38 lbs	(1600 GPM)		.250		
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

Well:	
Meter:	
Legal:	
Location: <i>Anderson - South</i>	

Pump Data Installation Date:	
Pump Setting:	
Airline : 420	
CT&S Size:	
Bowls:	
Well Depth:	
Blank:	
Perforations:	

Motor: Johnson H.P.: 350 Volts: _____ R.P.M.: _____ Serial #: 169343
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	12-29-06							
Standing Water	75 Lbs	247						
Draw Down		34						
Pumping Level	60 Lbs	281						
Lift Above Discharge		69						
Total Lift		350						
G.P.M.		2327						
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1786	2822	30 PSI (2300) RPM	10"	250 wall			
KW Input								
KW Hours Per AC/Ft.								
BFF								
Cost Per AC/Ft.								

35

Blank:

Perforations:

R.P.M.:

Serial #: 166011

10' 250 WALL

Well:	
Meter:	
Legal:	
Location:	Big field EAST

Pump Data Installation Date:	
Pump Setting :	
Airline :	400
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: <u>Johnson</u>	H.P.: <u>500</u>	Volts: _____	R.P.M.: _____	Serial #: <u>166088</u>
Frame: _____	Type: _____	Pump: _____	Type Oil Lube: _____	

Date:	1-2-07							
Standing Water	56 lbs	270						
Draw Down		30						
Pumping Level	43 lbs	300						
Lift Above Discharge		78						
Total Lift		378						
G.P.M.		1593						
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1750	19.3	34 lbs			10"	2.50	in all
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

Well:	
Meter:	
Legal:	
Location:	Big Field South

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: Johnson H.P.: 500 Volts: _____ R.P.M.: 1775 Serial #: 166010
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	12-5-06							
Standing Water	2410							
Draw Down	1							
Pumping Level	2410							
Lift Above Discharge	129.							
Total Lift								
G.P.M.	2410							
GPM/FT	1.0							
AC Ft. In. 24 Hrs.								
HP Input RPM	1775	29.3	56 ^{lb}	(2500) gpd	10"	250 well		
KW Input								
KW Hours Per AC/Ft.								
BFP								
Cost Per AC/Ft.								

Motor: DEKAY H.P.: 300 Volts: _____ R.P.M.: _____ Serial #: 13904040
Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	1-2-07							
Standing Water	113'							
Draw Down	122							
Pumping Level	235'							
Lift Above Discharge	57							
Total Lift	292							
G.P.M.	1064							
GPM/FT								
AC Ft. In. 24 Hrs.								
HP Input RPM	1750	12.9	25 LBS (1000)	15 PM	10"	2250 rpm		
KW Input								
KW Hours Per AC/Ft.								
EFF								
Cost Per AC/Ft.								

41

Well:	
Meter:	
Legal:	
Location:	Tanner - South

Pump Data Installation Date:
Pump Setting:
Airline: 300
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor:	H.P.: 500	Volts:	R.P.M.:	Serial #: 169244
Frame:	Type:	Pump:	Type Oil Lube:	

Date:	12-29-06								
Standing Water	80 Lbs	135							
Draw Down		14							
Pumping Level	74 Lbs	149							
Lift Above Discharge		27							
Total Lift		176							
G.P.M.	2030	2030							
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1750	24.7	12 Lbs	(2100) 30 P.M.	10"	250 wall.			
KW Input									
KW Hours Per AC/Ft.									
BFF									
Cost Per AC/Ft.									

44

Well:	
Meter:	
Legal:	
Location:	SAP 362- 37

362

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: DE-RAH H.P.: 300 Volts: R.P.M.: Serial #: 6209042
Frame: Type: Pump: Type Oil Lube:

Date:	1-3-07								
Standing Water	30 Lbs								
Draw Down									
Pumping Level	0 Lbs								
Lift Above Discharge		32							
Total Lift									
G.P.M.		1370							
GPM/FT									
AC Ft. In. 24 Hrs.	1750	16.6	14.2 Lbs			10" 250 W all			
HP Input RPM									
KW Input									
KW Hours Per AC/Ft.									
BFF									
Cost Per AC/Ft.									

Airline not working

Well:	
Meter:	
Legal:	
Location:	542 35-4-71

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: De Pann H.P.: 300 Volts: R.P.M.: Serial #: C209149
Frame: Type: Pump: Type Oil Lube:

Date:	1-3-07								
Standing Water	188'								
Draw Down	64								
Pumping Level	252								
Lift Above Discharge	116								
Total Lift	368								
G.P.M.	1000								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1650	9.0	50 lbs	(1000) g/m	10"	250-mall			
KW Input									
KW Hours Per AC/Ft.									
BFF									
Cost Per AC/Ft.									

[illegible]

Well:	
Meter:	
Legal:	
Location:	area 14-33

Pump Data Installation Date:	
Pump Setting :	
Airline :	
CT&S Size:	
Bowls:	
Well Depth:	
	Blanks:
	Perforations:

1-24-08

Moto: De Ron H.P. 300 Volts: _____ R.P.M.: _____ Serial #: B3810081
 Fram: _____ Type: _____ Pump: _____ Type Oil Lube: _____

[illegible]

Pump Data Installation Date:	
Pump Setting :	
Airline :	483
CT&S Size:	
Bowls:	
Well Depth:	
	Blank:
	Perforations:

Motor: Diason H.P.: 450 Volts: _____ R.P.M.: _____ Serial #: C111072
 Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	11-28-07							
Standing Water	452 lbs	379						
Draw Down		18						
Pumping Level	37 Lbs	397						
Lift Above Discharge		94.71						
Total Lift		491						
G.P.M.		1708						
GPM/FT			1708 G.P.M.					
AC Ft. In. 24 Hrs.								
HP Input RPM	1750	20.7	41 Lbs			10" IPS	2.50	wall
KW Input								
KW Hours Per AC/Ft.								
BFP								
Cost Per AC/Ft.								

Well:	
Motor:	
Legal:	
Location:	Arval 21-2

1-24-08

Pump Data Installation Date:	
Pump Setting:	
Alfina:	
CT&S Size:	
Rows:	
Well Depth:	
Blank:	
Perforations:	

Motor: De Rom H.P. 450 HP Volts: R.P.M.: Serial #: C111080
 Fram. Type: Pump: Type Oil Lube:

Date:									
Standing Water	307'								
Draw Down	35'								
Pumping Level	342'								
Lift Above Discharge	23.1								
Total Lift	365.1								
G.P.M.	2475								
GPM/FT.									
AC Ft. In. 24 Hrs.									
HP Input RPM	1800	3007	1026						
KW Input									
KW Hours Per AC/Ft.									
HPF									
Cost Per AC/Ft.									

2475
 10" IPS 250 wall

Well:	
Meter:	
Legal:	
Location:	Dock 29-3

Pump Data Installation Date:
Pump Setting :
Airline :
CT&S Size:
Bowls:
Well Depth:
Blank:
Perforations:

Motor: Duran H.P.: 450 Volts: _____ R.P.M.: _____ Serial #: C1090124
 Frame: _____ Type: _____ Pump: _____ Type Oil Lube: _____

Date:	11-26-07								
Standing Water	339								
Draw Down	31								
Pumping Level	370								
Lift Above Discharge	39.27								
Total Lift	409.27								
G.P.M.	2154								
GPM/FT									
AC Ft. In. 24 Hrs.									
HP Input RPM	1800	26.1	1765	2154 ^{88 ft}	10" EPS	1250 W			
KW Input									
KW Hours Per AC/Ft.									
EFF									
Cost Per AC/Ft.									
