| 1 2 3 4 5 6 | HANNA AND MORTON LLP EDWARD S. RENWICK (State Bar No. 29 444 South Flower Street, Suite 1500 Los Angeles, California 90071-2916 Telephone: (213) 628-7131 Facsimile: (213) 623-3379 Attorneys for Cross-Defendant WAGAS LAND COMPANY LLC | 325) | |
|----------------------------|---|--------------------------|---|
| 7 8 | SUPERIOR COURT OF | THE STATE O | F CALIFORNIA |
| 9 | COUNTY O | F LOS ANGEL | LES |
| 10 | | | |
| 11 | ANTELOPE VALLEY GROUNDWATER CASES | Judicial Cou No. 4408 | ncil Coordination Proceeding |
| 12 | Included Consolidated Actions: | | Case No. 1-05-CV-049053 he Hon. Jack Komar |
| 13 14 | Los Angeles County Waterworks District No. 40 v. Diamond Farming Co., Superior | J | .ND COMPANY LLC'S |
| 15 | Court of California, County of Los Angeles Case No. BC325201 | RESPONSE FOR PHASE | TO DISCOVERY ORDER E 4 TRIAL |
| 16 | Los Angeles County Waterworks District No. 40 v. Diamond Farming Co., Superior | Trial Date: Time: | February 11, 2013 9:00 a.m. |
| 17 | Court of California, County of Kern Case No. S-1500-CV254348 | Dept: | LASC, Dept. 1 |
| 18 19 | 'Wm. Bolthouse Farms, Inc. v. City of | | |
| 20 | Lancaster; Diamond Farming Co. v. City of Lancaster; Diamond Farming Co. v. Palmdale Water Dist., Superior Court of | | |
| 21 | California, County of Riverside, Consolidated Actions, Case Nos. | | |
| 22 | RIC353840, RIC344436, RIC344668. | | |
| 23 | Rebecca Lee Willis v. Los Angeles County Waterworks District No. 40, Superior | | |
| 24 | Court of California, County of Los Angeles Case No. BC364553 | | |
| 25 | Richard A. Wood v. Los Angeles County Waterworks, District No. 40, Superior | | |
| 26 | Court of California, County of Los Angeles, Case No. BC391869 | | |
| 27 | | | |

(I) The crop type, if any, grown on the parcel during each of the calendar years 2000, 2001, 2002, 2003, 2004, 2011, and 2012.

<u>Response</u>: Wild life habitat which included pond weed, sunflowers, wild grasses, wild shrubs, Japanese Millet, natural cover and natural feed of all types.

(J) If the responding party contends the parcel has groundwater rights based upon something other than groundwater production or use, please state the amount of that claim for each of the calendar years 2000, 2001, 2002, 2003, 2004, 2011, and 2012, and its legal and factual basis therefor.

Response: Not applicable.

(K) State the amount of water rights claimed as the reasonable and beneficial use for each such parcel.

Response: 1106 Acre Feet which is the average annual production of water pumped from the three wells in the years 2000 through 2004.

(K)[sic] At the responding party's election any other facts that the responding party contends will assist the Court in determining the amount of groundwater produced from each parcel of land owned or controlled by the responding party in any or all calendar years 2000, 2001, 2002, 2003, 2004, 2011 and 2012.

Response: The Wagas Land Company, aka Wagas Ranch, aka Wagas Gun Club was incorporated as a California corporation and acquired the above described land in 1925. Thereafter the corporation was dissolved and the property was owned and operated by a partnership in which Albert B. Mckee Jr. was a partner. The partnership continued to operate the property as a hunting club known as Wagas Ranch aka Wagas Gun Club. Thereafter the property was owned by Albert B. McKee Jr. who continued to operate the property as a hunting club known as Wagas Ranch aka Wagas Gun Club. Thereafter Mr. McKee took in a group of partners and the property was operated as a partnership for a number of years until the partnership was

| 1 2 | II. FOR ALL PARTIES CLAIMING A NON-OVERLYING RIGHT, INCLUDING APPROPRIATIVE, PRESCRIPTIVE OR OTHERWISE. |
|----------|---|
| 3 | 1. Not applicable. |
| 4 | III. FOR ALL PARTIES CLAIMING RETURN FLOW CREDITS |
| 5 | 1. Not applicable. |
| 6 | |
| 7 | V. FOR ALL RESPONDING PARTIES |
| 8 | 1. For each of the items above, please identify the person(s) most qualified to testify |
| 9 | on its behalf to the facts alleged and materials produced. |
| 10 | Response: Edward Wopschall who has acted as the managing member since |
| 11 | approximately 2000. |
| 12 | |
| 13 | 2. The responding party's responses must be accompanied by an executed |
| 14 15 | verification by an individual authorized to do so. |
| 16 | Response: Mr. Wopschall is authorized to verify this response and has done so. |
| 17 | |
| 18 | Dated: December 21, 2012 HANNA AND MORTON LLP EDWARD S. RENWICK |
| 19 | EDWARD 3. REITWICK |
| 20 | By: Mad Snevill |
| 21 | Edward S. Renwick |
| 22 | Attorneys for Cross-Defendant WAGAS Land Company LLC |
| 23 | |
| 24 | |
| 25 | |
| 26 | |
| 27 | |
| 28 | |

VERIFICATION I am a managing member of WAGAS LAND COMPANY LLC, a California limited liability company, and am authorized to make this verification on its behalf. I have read the foregoing WAGAS LAND COMPANY LLC'S RESPONSE TO DISCOVERY ORDER FOR PHASE 4 54IQL. I am informed and believe that the matters stated therein are true and correct, and on that ground certify or declare under penalty of perjury under the laws of the State of California that the same are true and correct. Executed this Zorn day of December, 2012, at IRWINDALE, CA... Zawad A. Wopschall Edward A. Wopschall

VERIFICATION

WAGAS LAND COMPANY LLC WATER USAGE: 2000-2004 AND 2011-2012 (Revised 12-19-12)

(AS DETERMINED BY EDISON COMPANY PUMP TESTS)

| | | | South Well | |
|---------|-------------|-------------|--------------|--------|
| | | | (60 HP) | |
| | | | Referred to | |
| | | | by Edison as | |
| | North Well | East Well | "West Well" | Total |
| Year | (30 HP) AFY | (50 HP) AFY | AFY | AFY |
| 2000 | 220.3 | 556.7 | 605.9 | 1382.9 |
| 2001 | 88.3 | 426.7 | 521.7 | 1036.7 |
| 2002 | 44.5 | 433.6 | 575.8 | 1053.9 |
| 2003 | 34.6 | 455.7 | 548.6 | 1038.9 |
| 2004 | 32.8 | 466 | 518.6 | 1017.4 |
| Average | | | | 1106.0 |
| Median | | | | 1038.9 |
| Highest | | | | 1382.9 |
| 2011 | 11.5 | 472.1 | 467.9 | 951.5 |
| 2012 | 10.3 | 469.8 | 536.7 | 1016.8 |
| | | | | |

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust #: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#:

2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on December 22, 2011, billing history for the past 12 months, and your current rate of TOU-PA-A.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 36.1% to 61.0%.
- 2. This can save you up to 2,350 kWh and \$1,667.34 annually.
- 3. These kWh savings translate to a 1.0-ton decrease in CO₂ emissions.

| | Plant Efficiency | | |
|------------------------------|------------------|-----------------|----------------|
| | <u>Existing</u> | <u>Improved</u> | <u>Savings</u> |
| Total kWh | 5,760 | 3,410 | 2,350 |
| kW Input | 26.0 | 15.4 | 10.6 |
| kWh per Acre Foot | 501 | 296 | 204 |
| Acre Feet per Year | 11.5 | | |
| Average Cost per kWh | \$0.71 | | |
| Average Cost per Acre Foot | \$355.23 | \$210.29 | \$144.94 |
| Overall Plant Efficiency (%) | 36.1 | 61.0 | |
| Total Annual Cost | \$4,086.37 | \$2,419.04 | \$1,667.34 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Save Energy, Save Money. . . Your test results show that you can!

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A HP: 30

Cust #: 0-006-1729 Serv. Acct. #: 003-4220-09 Meter: 3412M-7140 Pump Ref. #: 2580

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on December 22, 2011. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

| | Existing | <u>Improved</u> | <u>Savings</u> | Cash Incentive |
|------------------------------|------------|-----------------|----------------|----------------|
| Total kWh | 5,760 | 3,410 | 2,350 | \$211.52 |
| kW Input | 26.0 | 15.4 | 10.6 | |
| kW on-peak activity factor * | | | 6.9 | \$689.56 |
| Acre Feet per Year | 11.5 | | | |
| kWh per Acre Foot | 501 | 296 | 204 | |
| Average Cost per Acre Foot | \$355.23 | \$210.29 | \$144.94 | |
| Overall Plant Efficiency (%) | 36.1 | 61.0 | | |
| Annual Total | \$4,086.37 | \$2,419.04 | \$1,667.34 | \$901.08 |

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 10.6 kW, and the savings used for incentive calculations is 65% of 10.6, or 6.9 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 36.1% to 61.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-A, we estimate that you may save up to 2,350 kWh annually (which translates to a 1.0-ton decrease in CO₂ emissions). This may result in energy cost savings of \$1,667.34.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a Potential Cash Incentive of \$901.08, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

SOUTHERN CALIFORNIA EDISON® An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP:50

Cust #: 0-000-2633

Serv. Acct. #: 014-8034-41

Meter: 3412M-6681

Pump Ref.#:

2578

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on December 22, 2011, billing history for the past 12 months, and your current rate of TOU-PA-SOP-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 55.0% to 65.0%.
- 2. This can save you up to 24,753 kWh and \$2,419.63 annually.
- 3. These kWh savings translate to a 11-ton decrease in CO₂ emissions.

| | Plant Efficiency | | |
|------------------------------|------------------|-----------------|----------------|
| | Existing | <u>Improved</u> | <u>Savings</u> |
| Total kWh | 160,392 | 135,639 | 24,753 |
| kW Input | 42.6 | 36.0 | 6.6 |
| kWh per Acre Foot | 340 | 287 | 52 |
| Acre Feet per Year | 472.1 | | |
| Average Cost per kWh | \$0.10 | | |
| Average Cost per Acre Foot | \$33.21 | \$28.08 | \$5.13 |
| Overall Plant Efficiency (%) | 5 5.0 | 65.0 | |
| Total Annual Cost | \$15,678.32 | \$13,258.68 | \$2,419.63 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Save Energy, Save Money. . . Your test results show that you can!

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: EAST WELL #2Location: E/S 30TH W S/O AVE AHP: 50Cust #: 0-000-2633Serv. Acct. #: 014-8034-41

Meter: 3412M-6681 Pump Ref.#: 2578

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on December 22, 2011. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

| | Existing | <u>Improved</u> | Savings | Cash Incentive |
|------------------------------|-------------|-----------------|------------|----------------|
| Total kWh | 160,392 | 135,639 | 24,753 | \$2,227.80 |
| kW Input | 42.6 | 36.0 | 6.6 | |
| kW on-peak activity factor * | | | 4.3 | \$427.34 |
| Acre Feet per Year | 472.1 | | | |
| kWh per Acre Foot | 340 | 287 | 52 | |
| Average Cost per Acre Foot | \$33.21 | \$28.08 | \$5.13 | |
| Overall Plant Efficiency (%) | 55.0 | 65.0 | | |
| Annual Total | \$15,678.32 | \$13,258.68 | \$2,419.63 | \$2,655.14 |

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 6.6 kW, and the savings used for incentive calculations is 65% of 6.6, or 4.3 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 55.0% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-SOP-1, we estimate that you may save up to 24,753 kWh annually (which translates to a 11-ton decrease in CO₂ emissions). This may result in energy cost savings of \$2.419.63.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$2,655.14</u>, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact KRISTINA L LUNA at (909)873-7964 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

SOUTHERN CALIFORNIA Ar. EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A

HP:60

Cust #: 0-006-1729

003-6970-34 Serv. Acct. #:

Meter: 3416M-7011

Pump Ref.#:

2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on December 22, 2011, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 53.8% to 65.0%.
- 2. This can save you up to 28,826 kWh and \$3,035.39 annually.
- 3. These kWh savings translate to a 13-ton decrease in CO2 emissions.

| | | Plant Efficiency | |
|------------------------------|-----------------|------------------|------------|
| | <u>Existing</u> | <u>Improved</u> | Savings |
| Total kWh | 166,788 | 137,962 | 28,826 |
| kW Input | 59.4 | 49.1 | 10.3 |
| kWh per Acre Foot | 356 | 295 | 62 |
| Acre Feet per Year | 467.9 | | |
| Average Cost per kWh | \$0.11 | | |
| Average Cost per Acre Foot | \$37.53 | \$31.05 | \$6.49 |
| Overall Plant Efficiency (%) | 53.8 | 65.0 | |
| Total Annual Cost | \$17,562.78 | \$14,527.39 | \$3,035.39 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Save Energy, Save Money. . . Your test results show that you can!

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A HP: 60

Cust #: 0-006-1729 Serv. Acct. #: 003-6970-34

Meter: 3416M-7011 Pump Ref.#: 2579

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on December 22, 2011. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

| | Existing | <u>Improved</u> | <u>Savings</u> | Cash Incentive |
|------------------------------|--------------|-----------------|----------------|----------------|
| Total kWh | 166,788 | 137,962 | 28,826 | \$2,594.35 |
| kW Input | 59.4 | 49.1 | 10.3 | |
| kW on-peak activity factor * | | | 6.7 | \$667.30 |
| Acre Feet per Year | 467.9 | | | |
| kWh per Acre Foot | 356 | 295 | 62 | |
| Average Cost per Acre Foot | \$37.53 | \$31.05 | \$6.49 | |
| Overall Plant Efficiency (%) | 53 .8 | 65.0 | | |
| Annual Total | \$17,562.78 | \$14,527.39 | \$3,035.39 | \$3,261.65 |

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 10.3 kW, and the savings used for incentive calculations is 65% of 10.3, or 6.7 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 53.8% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-P-S-1-AP, we estimate that you may save up to 28,826 kWh annually (which translates to a 13-ton decrease in CO₂ emissions). This may result in energy cost savings of \$3,035.39.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$3.261.65</u>, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization before implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust #: 0-006-1729

003-4220-09 Serv. Acct. #:

Meter:

254000-016403 Pump Ref.#: 2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 22, 2012, billing history for the past 12 months, and your current rate of PA-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 37.3% to 61.0%.
- 2. This can save you up to 2,041 kWh and \$969.98 annually.
- 3. These kWh savings translate to a 0.9-ton decrease in CO₂ emissions.

| Total Annual Cost | \$2,498.23 | \$1,528.25 | \$969.98 |
|------------------------------|------------|------------------|----------|
| Overall Plant Efficiency (%) | 37.3 | 61.0 | |
| Average Cost per Acre Foot | \$241.51 | \$147.74 | \$93.77 |
| Average Cost per kWh | \$0.48 | | |
| Acre Feet per Year | 10.3 | | |
| kWh per Acre Foot | 508 | 311 | 197 |
| kW Input | 24.7 | 15.1 | 9.6 |
| Total kWh | 5,256 | 3,215 | 2,041 |
| | Existing | Improved | Savings |
| | | Plant Efficiency | _ |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Save Energy, Save Money... Your test results show that you can!

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A HP: 30
Cust #: 0-006-1729 Serv. Acct. #: 003-4220-09

Meter: 254000-016403 Pump Ref.#: 2580

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on October 22, 2012. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

| Annual Total | \$2,498.23 | \$1,528.25 | \$969.98 | \$807.03 |
|------------------------------|------------|-----------------|---------------------------------------|----------------|
| Overall Plant Efficiency (%) | 37.3 | 61.0 | | |
| Average Cost per Acre Foot | \$241.51 | \$147.74 | \$93.77 | |
| kWh per Acre Foot | 508 | 311 | 197 | |
| Acre Feet per Year | 10.3 | | | |
| kW on-peak activity factor * | | | 6.2 | \$623.36 |
| kW Input | 24.7 | 15.1 | 9.6 | |
| Total kWh | 5,256 | 3,215 | 2,041 | \$183.67 |
| | Existing | <u>Improved</u> | Savings | Cash Incentive |
| | | | · · · · · · · · · · · · · · · · · · · | • |

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 9.6 kW, and the savings used for incentive calculations is 65% of 9.6, or 6.2 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 37.3% to 61.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of PA-1, we estimate that you may save up to 2,041 kWh annually (which translates to a 0.9-ton decrease in CO₂ emissions). This may result in energy cost savings of \$969.98.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive
 an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency
 Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$807.03</u>, capped
 at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

SOUTHERN CALIFORNIA EDISON® An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: EAST WELL #2
Location: E/S 30TH W S/O AVE A HP: 50
Cust #: 0-000-2633 Serv. Acct. #: 014-8034-41

Meter: 3412M-6681 Pump Ref.#: 2578

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 22, 2012, billing history for the past 12 months, and your current rate of TOU-PA-SOP-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 54.9% to 65.0%.
- 2. This can save you up to 26,123 kWh and \$2,418.17 annually.
- 3 These kWh savings translate to a 11-ton decrease in CO₂ emissions.

| | | Plant Efficiency | |
|------------------------------|-----------------|------------------|----------------|
| | <u>Existing</u> | <u>Improved</u> | <u>Savings</u> |
| Total kWh | 167,388 | 141,265 | 26,123 |
| kW Input | 43.1 | 36.4 | 6.7 |
| kWh per Acre Foot | 356 | 301 | 56 |
| Acre Feet per Year | 469.8 | | |
| Average Cost per kWh | \$0.09 | | |
| Average Cost per Acre Foot | \$32.98 | \$27.83 | \$5.15 |
| Overall Plant Efficiency (%) | 54.9 | 65.0 | |
| Total Annual Cost | \$15,495.11 | \$13,076.94 | \$2,418.17 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Save Energy, Save Money. . . Your test results show that you can!

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Cust #: 0-000-2633

Serv. Acct. #:

014-8034-41

Meter:

3412M-6681

Pump Ref.#:

2578

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on October 22, 2012. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

| | Projected Incentive, Energy, and Cost Savings | | | |
|------------------------------|---|-----------------|------------|----------------|
| | Existing | <u>Improved</u> | Savings | Cash Incentive |
| Total kWh | 167,388 | 141,265 | 26,123 | \$2,351.03 |
| kW Input | 43.1 | 36.4 | 6.7 | |
| kW on-peak activity factor * | | | 4.4 | \$437.20 |
| Acre Feet per Year | 469.8 | | | |
| kWh per Acre Foot | 356 | 301 | 56 | |
| Average Cost per Acre Foot | \$32.98 | \$27.83 | \$5.15 | |
| Overall Plant Efficiency (%) | 54.9 | 65.0 | | |
| Annual Total | \$15,495.11 | \$13,076.94 | \$2,418.17 | \$2,788.24 |

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 6.7 kW, and the savings used for incentive calculations is 65% of 6.7, or 4.4 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Effliciency: Your OPE can be improved from 54.9% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-SOP-1, we estimate that you may save up to 26,123 kWh annually (which translates to a 11-ton decrease in CO₂ emissions). This may result in energy cost savings of \$2,418.17.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$2.788.24</u>. capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact Veronica Diaz at (626)812-7670 to complete a project application. All applicants must receive a written approval authorization before implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

SOUTHERN CALIFORNIA EDISON® An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A

HP: 60

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#:

2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 22, 2012, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 56.2% to 65.0%.
- 2. This can save you up to 27,867 kWh and \$2,564.34 annually.
- 3. These kWh savings translate to a 12-ton decrease in CO₂ emissions.

| | | Plant Efficiency | |
|------------------------------|-------------|------------------|----------------|
| | Existing | <u>Improved</u> | <u>Savings</u> |
| Total kWh | 204,780 | 176,913 | 27,867 |
| kW Input | 60,7 | 52.4 | 8.3 |
| kWh per Acre Foot | 382 | 330 | 52 |
| Acre Feet per Year | 536.7 | | |
| Average Cost per kWh | \$0.09 | | |
| Average Cost per Acre Foot | \$35.11 | \$30.33 | \$4.78 |
| Overall Plant Efficiency (%) | 56.2 | 65.0 | |
| Total Annual Cost | \$18,843.86 | \$16,279.52 | \$2,564,34 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.



Save Energy, Save Money... Your test results show that you can!

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A

HP: 60 : 003-6970-34

Cust #: 0-006-1729 Meter: 3416M-7011 Serv. Acct. #: Pump Ref.#:

2579

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on October 22, 2012. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

| | <u>Existing</u> | <u>Improved</u> | <u>Savings</u> | Cash Incentive |
|------------------------------|-----------------|-----------------|----------------|----------------|
| Total kWh | 204,780 | 176,913 | 27,867 | \$2,508.05 |
| kW Input | 60.7 | 52.4 | 8.3 | |
| kW on-peak activity factor * | | | 5.4 | \$536.92 |
| Acre Feet per Year | 536.7 | | | |
| kWh per Acre Foot | 382 | 330 | 52 | |
| Average Cost per Acre Foot | \$35.11 | \$30.33 | \$4.78 | |
| Overall Plant Efficiency (%) | 56.2 | 65.0 | | |
| Annual Total | \$18,843.86 | \$16,279.52 | \$2,564.34 | \$3,044.96 |

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 8.3 kW, and the savings used for incentive calculations is 65% of 8.3, or 5.4 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 56.2% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-P-S-1-AP, we estimate that you may save up to 27,867 kWh annually (which translates to a 12-ton decrease in CO₂ emissions). This may result in energy cost savings of \$2,564.34.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a Potential Cash Incentive of \$3,044.96, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization before implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

WAGAS LAND COMPANY LLC WATER USAGE: 2000-2004 (Revised 2-18-12)

(AS DETERMINED BY EDISON COMPANY PUMP TESTS)
Years 2000-2004

| | | | South Well (60 HP) Referred to by Edison as | |
|---------|-------------|-------------|--|--------|
| | North Well | East Well | "West Well" | Total |
| Year | (30 HP) AFY | (50 HP) AFY | AFY | AFY |
| 2000 | 220.3 | 556.7 | 605.9 | 1382.9 |
| 2001 | 88.3 | 426.7 | 521.7 | 1036.7 |
| 2002 | 44.5 | 433.6 | 575.8 | 1053.9 |
| 2003 | 34.6 | 455.7 | 548.6 | 1038.9 |
| 2004 | 32.8 | 466 | 518.6 | 1017.4 |
| Average | | | | 1106.0 |
| Median | | | | 1038.9 |
| Highest | | | | 1382.9 |

SOUTHERN CALIFORNIA EDISON INTERNATIONAL COmpany

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant'NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust #: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 11, 2000. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

| Equipment | | | | | | |
|------------------------------|-------|-----|-------------|-------|--|--|
| Pump: | AUROR | No: | 'V8472099 | | | |
| Motor: | US | No: | 'R718303919 | | | |
| Discharge Pressure, PSI | 1.7 | | 15.1 | 26.5 | | |
| Standing Water Level, Feet | 143.7 | | 143.7 | 143.7 | | |
| Drawdown, Feet | 41.3 | | 35.0 | 28.9 | | |
| Discharge Head, Feet | 3.9 | | 34.9 | 61.2 | | |
| Pumping Water Level, Feet | 185.0 | | 178.7 | 172.6 | | |
| Total Head, Feet | 188.9 | | 213.6 | 233.8 | | |
| Capacity, GPM | 379 | | 319 | 263 | | |
| GPM per Foot Drawdown | 9.2 | | 9.1 | 9.1 | | |
| Acre Feet Pumped in 24 Hours | 1.675 | | 1.410 | 1.162 | | |
| kW Input to Motor | 24.5 | | 23.8 | 22.2 | | |
| HP Input to Motor | 32.9 | | 31.9 | 29.8 | | |
| Motor Load (%) | 96.9 | | 94.2 | 87.8 | | |
| Measured Speed of Pump, RPM | 1,774 | | | | | |
| kWh per Acre Foot | 351 | | 405 | 458 | | |
| Overall Plant Efficiency (%) | 55.0 | | 53.9 | 52.2 | | |

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: 'NORTH WELL #1

Location: 35TH ST W N/S AVE A

Cust #: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 11, 2000, billing history for the past 12 months, and your current rate of TOU-PA-A.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 55.0% to 65.0%.
- 2. This can save you up to 11,866 kWh and \$1,233.92 annually.
- 3. These kWh savings translate to a 5.2-ton decrease in CO₂ emissions.

| | | Plant Efficiency | |
|------------------------------|------------|------------------|----------------|
| | Existing | Improved | <u>Savings</u> |
| Total kWh | 77,340 | 65,474 | 11,866 |
| kW input | 24.5 | 20.7 | 3.8 |
| kWh per Acre Foot | 351 | 297 | 54 |
| Acre Feet per Year | 220.3 | | |
| Average Cost per kWh | \$0.10 | | |
| Average Cost per Acre Foot | \$36.51 | \$30.91 | \$5.60 |
| Overall Plant Efficiency (%) | 55.0 | 65.0 | • |
| Total Annual Cost | \$8,042.74 | \$6,808.82 | \$1,233.92 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.

Confidential/Proprietary Information

February 14, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant:

'EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Meter:

Cust #: 0-000-2633 3412M-6681 Serv. Acct. #: 014-8034-41

Pump Ref.#: 2578

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 11, 2000. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

| L- | ~ | 1 | m | _ | - | ٠ |
|----|----|--------|--------|-----|---|----|
| _ | ŁJ | ** | 15 E I | 162 | | ı. |

| Pump: | L&B | No: | 'D18009 |
|----------------|-------------------|-----|-----------|
| Motor: | US | No: | 'H1019392 |
| Discharge Pr | ressure, PSI | | 1.3 |
| Standing Wa | iter Level, Feet | | 145.8 |
| Drawdown, F | eet | | 36.4 |
| Discharge H | ead, Feet | | 3.0 |
| Pumping Wa | ter Level, Feet | | 182.2 |
| Total Head, I | Feet | | 185.2 |
| Capacity, GF | M | | 709 |
| GPM per Foo | ot Drawdown | | 19.5 |
| Acre Feet Pu | ımped in 24 Hours | | 3.134 |
| kW input to it | Motor | | 43.0 |
| HP Input to N | Motor | | 57.7 |
| Motor Load (| %) | | 103.8 |
| Measured Sp | seed of Pump, RPM | | 1,774 |
| kWh per Acı | e Foot | | 329 |
| Overall Plan | t Efficiency (%) | | 57.5 |
| | | | |

Confidential/Proprietary Information

February 14, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant:

'EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Cust #: 0-000-2633 Serv. Acct. #:

014-8034-41

Meter: 3412M-6681 Pump Ref.#:

2578

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 11, 2000, billing history for the past 12 months, and your current rate of TOU-PA-SOP-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 57.5% to 70.0%.
- 2. This can save you up to 32,736 kWh and \$2,262.30 annually.
- 3. These kWh savings translate to a 14-ton decrease in CO₂ emissions.

| | | Plant Efficiency | |
|------------------------------|-------------|------------------|----------------|
| | Existing | <u>Improved</u> | <u>Savings</u> |
| Total kWh | 183,372 | 150,636 | 32,736 |
| kW Input | 43.0 | 35.3 | 7.7 |
| kWh per Acre Foot | 329 | 271 | 59 |
| Acre Feet per Year | 556.7 | | |
| Average Cost per kWh | \$0.07 | | |
| Average Cost per Acre Foot | \$22.76 | \$18.70 | \$4.06 |
| Overall Plant Efficiency (%) | 57.5 | 70.0 | |
| Total Annual Cost | \$12,672.47 | \$10,410.18 | \$2,262.30 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUÉ at (661)726-5662.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant: WEST WELL #3

Location: 3310 W AVENUE A

HP: 60

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#: 2579

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 12, 2000. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

| | Equipme | ent | | |
|------------------------------|-----------|------|------------|-------|
| Pump: | L&B | | '21847 | |
| Motor: | US | No: | '1025182 | |
| Discharge Pressure, | PSI | | .8 | 14.1 |
| Standing Water Leve | l, Feet | 158 | .9 | 158.9 |
| Drawdown, Feet | | 35 | .2 | 30.7 |
| Discharge Head, Fee | et | 1 | .8 | 32.6 |
| Pumping Water Leve | el, Feet | 194 | .1 | 189.6 |
| Total Head, Feet | | 195 | .9 | 222.2 |
| Capacity, GPM | | 97 | 78 | 827 |
| GPM per Foot Drawd | iown | 27 | .8 | 26.9 |
| Acre Feet Pumped in | 24 Hours | 4.32 | 23 | 3.655 |
| kW Input to Motor | • | 61 | .2 | 60.5 |
| HP Input to Motor | | 82 | .1 | 81.1 |
| Motor Load (%) | - | 123 | .1 | 121.7 |
| Measured Speed of I | Pump, RPM | 1,77 | ' 5 | |
| kWh per Acre Foot | | 34 | 10 | 397 |
| Overall Plant Efficie | ency (%) | 59. | .0 | 57.2 |

Test 1 is the normal operation of this pump at the time of the above test(s). The other results. were obtained by throttling the discharge.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: 'WEST WELL #3

Location: 3310 W AVENUE A

HP:60

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#: 2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 12, 2000, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 59.0% to 70.0%.
- 2. This can save you up to 32,498 kWh and \$2,000.86 annually.
- 3. These kWh savings translate to a 14-ton decrease in CO2 emissions.

| | Plant Efficiency | | |
|------------------------------|------------------|-----------------|------------|
| | <u>Existing</u> | <u>Improved</u> | Savings |
| Total kWh | 205,908 | 173,410 | 32,498 |
| kW Input | 61.2 | 51.5 | 9,7 |
| kWh per Acre Foot | 340 ⋅ | 286 | 54 |
| Acre Feet per Year | 605.9 | | |
| Average Cost per kWh | \$0.06 | | |
| Average Cost per Acre Foot | \$20.92 | \$17.62 | \$3.30 |
| Overall Plant Efficiency (%) | 59.0 | 70.0 | |
| Total Annual Cost | \$12,677.34 | \$10,676.48 | \$2,000.86 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - NORTH WELL #1

35TH ST W N/S AVE A

CUST #: 0-006-1729 SERV ACCT #: 003-4220-09

DATE OF TEST: October 1, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: AUROR

MOTOR: US

NO: V8472099

NO: R718303919

30 HP

METER: 732M-54

HYDRAULIC TEST REFERENCE NUMBER: 2580

| TEST RESULTS | TEST 1 | TEST 2 | TEST 3 |
|------------------------------|---------------|--------|--------|
| Discharge Pressure, PSI | 1.0 | 15.9 | 26.3 |
| Standing Water Level, Ft. | 150.4 | 150.4 | 150.4 |
| Drawdown, Ft. | 39.1 | 32.2 | 26.1 |
| Discharge Head, Ft. | 2.3 | 36.7 | 60.8 |
| Pumping Water Level, Ft. | 189.5 | 182.6 | 176.5 |
| Total Head, Ft. | 191.8 | 219.3 | 237.3 |
| Capacity, GPM | 366.0 | 294.0 | 235.0 |
| GPM per Ft. Drawdown | 9.4 | 9.1 | 9.0 |
| Acre Ft. Pumped in 24 Hrs. | 1.618 | 1.299 | 1.039 |
| kW Input to Motor | 24.3 | 23.1 | 21.5 |
| HP Input to Motor | 32.6 | 31.0 | 28.8 |
| Motor Load (%) | 96.1 | 91.4 | 85.1 |
| Measured Speed of Pump, RPM | 17 <u>7</u> 0 | | |
| kWh per Acre Ft. | (361) | 427 | 497 |
| Overall Plant Efficiency (%) | 54.4 | 52.6 | 48.8 |

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by threttling the discharge. 300 Southern

Manager

Hydraulic Services

42060 10th St. W. Lancaster, CA 93534



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY

PA-1

Current Rate

| Total kWh | 31836 |
|------------------------|------------|
| kW Input | 24.3 |
| kWh per Acre Ft. | 361 |
| Acre Ft. per Year | 88.3 |
| Avg. Cost per kWh | \$0.11 |
| Avg. Cost per Acre Ft. | \$39.30 |
| Overall Plant Eff. (%) | 54.4 |
| | |
| TOTAL ANNUAL COST | \$3,469.61 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY ARDVE at (661) 726-5662.

DAN SOHNSON

Manager

Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved to 65.0%.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY PA-1 | IMPROVED PLANT PA-1 | EFFICIENCY |
|------------------------|--------------------------|------------------------|------------|
| | Current Rate | Current Rate | Savings |
| Total kWh | 31836 | 26644 | 5192 |
| kW Input | 24.3 | 20.3 | 4.0 |
| kWh per Acre Ft. | 361 | 302 | 59 |
| Acre Ft. per Year | 88.3 | 88.3 | |
| Avg. Cost per kWh | \$0.11 | | |
| Avg. Cost per Acre Ft. | \$39.30 | \$32.89 | \$6.41 |
| Overall Plant Eff. (%) | 54.4 | 65.0 | , |
| TOTAL ANNUAL COST | \$3,469.61 | \$2,903.80 | \$565.81 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARDUK at

DAN JÖHNSON Manager

Hydraulic Services

42060 10th St. W. Lancaster, CA 93534



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 SERV ACCT #: 014-8034-41

DATE OF TEST: October 1, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EOUIPMENT

PUMP: L & B NO: D18009

NO: H1019392

50 HP

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

MOTOR: US

| Discharge Pressure, PSI | 1.1 | |
|------------------------------|-------|----------------------|
| Standing Water Level, Ft. | 144.7 | |
| Drawdown, Ft. | 36.9 | |
| Discharge Head, Ft. | 2.5 | |
| Pumping Water Level, Ft. | 181.6 | |
| Total Head, Ft. | 184.1 | |
| Capacity, GPM | 700.0 | 19gal parot draudour |
| GPM per Ft. Drawdown | 19.0 | 0 1 |
| Acre Ft. Pumped in 24 Hrs. | 3.094 | |
| kW Input to Motor | 42.7 | |
| HP Input to Motor | 57.3 | |
| Motor Load (%) | 103.1 | |
| Measured Speed of Pump, RPM | 1773 | |
| kWh per Acre Ft. | (331) | |
| Overall Plant Efficiency (%) | 56.80 | |

Manager

14. Calper 1 16 France Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP

Current Rate

| Total kWh | 141372 |
|------------------------|------------|
| kW Input | 42.7 |
| kWh per Acre Ft. | 331 |
| Acre Ft. per Year | 426.7 |
| Avg. Cost per kWh | \$0.07 |
| Avg. Cost per Acre Ft. | \$21.82 |
| Overall Plant Eff. (%) | 56.8 |
| ******* | |
| TOTAL ANNUAL COST | \$9,311.04 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at 4661) 726-5662.

DAN JOHNSON Manager

Hydraulic Services

138 Days

42060 10th St. W. Lancaster, CA 93534



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved to 70.0%.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY TOU-PA-SOP | IMPROVED PLANT TOU-PA-SOP | EFFICIENCY |
|------------------------|--------------------------------|------------------------------|------------|
| | Current Rate | Current Rate | Savings |
| Total kWh | 141372 | 114780 | 26592 |
| kW Input | 42.7 | 34.7 | 8.0 |
| kWh per Acre Ft. | 331 | 269 | 62 |
| Acre Ft. per Year | 426.7 | 426.7 | |
| Avg. Cost per kWh | \$0.07 | | |
| Avg. Cost per Acre Ft. | | \$17.71 | \$4.10 |
| Overall Plant Eff. (%) | 56.8 | 70.0 | |
| | | | |
| TOTAL ANNUAL COST | \$9,311.04 | \$7,559.63 (| \$1,751.42 |
| | | | |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (661)726-5662.

DAN JOHNSON

Manager



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - WEST WELL #3

35TH W 1/4 S/O AVE A

CUST #: 0-006-1729 SERV ACCT #: 003-6970-34

DATE OF TEST: October 2, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B

NO: 21847 NO: 1025182

60 HP

MOTOR: US

METER: 0728K-1297

HYDRAULIC TEST REFERENCE NUMBER: 2579

TEST RESULTS

| Discharge Pressure, PSI | 0.8 |
|------------------------------|-------|
| Standing Water Level, Ft. | 168.3 |
| Drawdown, Ft. | 31.8 |
| Discharge Head, Ft. | 1.8 |
| Pumping Water Level, Ft. | 200.1 |
| Total Head, Ft. | 201.9 |
| Capacity, GPM | 938.0 |
| GPM per Ft. Drawdown | 29.5 |
| Acre Ft. Pumped in 24 Hrs. | 4.146 |
| kW Input to Motor | 61.1 |
| HP Input to Motor | 81.9 |
| Motor Load (%) | 122.9 |
| Measured Speed of Pump, RPM | 1786 |
| kWh per Acre Ft. | 354 |
| Overall Plant Efficiency (%) | 58.4 |

DAN JOHNSON

Manager

Hydraulic Services

15,75 per 145 prem

42060 10th St. W. Lancaster, CA 93534



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 2, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY
TOU-PA-SOP
Current Rate

Total kWh 184572 kW Input 61.1 kWh per Acre Ft. 354 Acre Ft. per Year 521.7 Avg. Cost per kWh \$0.07 Avg. Cost per Acre Ft. \$23.02 Overall Plant Eff. (%) 58.4

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (661)726-5662.

Manager

\$12,010.28

Hydraulic Services

125

415 521.7 10630 10830 207.7

TOTAL ANNUAL COST

42060 10th St. W. Lancaster, CA 93534



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 2, 2001 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved to 70.0%.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY TOU-PA-SOP | IMPROVED PLANT TOU-PA-SOP | EFFICIENCY |
|------------------------|--------------------------------|------------------------------|------------|
| | Current Rate | Current Rate | Savings |
| Total kWh | 184572 | 153901 | 30671 |
| kW Input | 61.1 | 50.9 | 10.2 |
| kWh per Acre Ft. | 354 | 295 | 59 |
| Acre Ft. per Year | 521.7 | 521.7 | |
| Avg. Cost per kWh | \$0.07 | | |
| Avg. Cost per Acre Ft. | | \$19.19 | \$3.83 |
| Overall Plant Eff. (%) | 58.4 | 70.0 | 4-1-1 |
| | | | |
| TOTAL ANNUAL COST | \$12,010.28 | \$10,014.50 | \$1,995.79 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PAHDUE at (661) 726-5662.

DAN JOHNSON

Manager

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant/NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust#: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140 Pump Ref.#: 2580

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 25, 2002. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

| | Equipment | | | |
|------------------------------|-----------|-----|-------------|-------|
| Pump: | AUROR | No: | 'V8472099 | |
| Motor: | US | No: | 'R718303919 | |
| Discharge Pressure, PSI | 1.0 | | 11.5 | 19.4 |
| Standing Water Level, Feet | 152.7 | | 152.7 | 152.7 |
| Drawdown, Feet | 34.0 | | 29.5 | 25.5 |
| Discharge Head, Feet | 2,3 | | 26.6 | 44.8 |
| Pumping Water Level, Feet | 186.7 | | 182.2 | 178.2 |
| Total Head, Feet | 189.0 | | 208.8 | 223.0 |
| Capacity, GPM | 325 | | 294 | 227 |
| GPM per Foot Drawdown | 9.6 | | 10.0 | 8.9 |
| Acre Feet Pumped in 24 Hours | 1.437 | | 1.299 | 1.003 |
| kW Input to Motor | 24.8 | | 24.0 | 23.1 |
| HP Input to Motor | 33.3 | | 32.2 | 31.0 |
| Motor Load (%) | 98.1 | | 94.9 | 91.4 |
| Measured Speed of Pump, RPM | 1,760 | | , | |
| kWh per Acre Foot | 414 | | 443 | .553 |
| Overall Plant Efficiency (%) | 46.6 | | 48.2 | 41.3 |

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

DAN L. JOHNSON Manager Hydraulic Services

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: 'NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust#: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 25, 2002, billing history for the past 12 months, and your current rate of TOU-PA-A.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- Overall plant efficiency can be improved from 46.6% to 65.0%.
- 2. This can save you up to 5,206 kWh and \$635.14 annually.
- 3. These kWh savings translate to a 2.3-ton decrease in CO2 emissions.

| | Existing | Plant Efficiency improved | <u>Şavings</u> |
|------------------------------|------------|------------------------------|----------------|
| Total kWh | 18,432 | 13,226 | 5,206 |
| kW Input | 24.8 | 17.8 | 7.0 |
| kWh per Acre Foot | 414 | 297 | 117 |
| Acre Feet per Year | 44,5 | a* | |
| Average Cost per kWh | \$0.12 | • | |
| Average Cost per Acre Foot | \$50.56 | \$36.28 | \$14.28 |
| Overall Plant Efficiency (%) | 46.6 | 65.0 | · |
| Total Annual Cost | \$2,248.74 | \$1,613.60 | \$635.14 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.

DAN L. JOHNSON Manager Hydraulic Services



September 30, 2002

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 SERV ACCT #: 014-8034-41

DATE OF TEST: September 25, 2002

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B

MOTOR: US

NO: D18009

NO: H1019392

50 HP

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

| Discharge Pressure, PSI | 1.5 |
|------------------------------|-------|
| Standing Water Level, Ft. | 131.6 |
| Drawdown, Ft. | 40.1 |
| Discharge Head, Ft. | 3.5 |
| Pumping Water Level, Ft. | 171.7 |
| Total Head, Ft. | 175.2 |
| Capacity, GPM | 719.0 |
| GPM per Ft. Drawdown | 17.9 |
| Acre Ft. Pumped in 24 Hrs. | 3.178 |
| kW Input to Motor | 42.5 |
| HP Input to Motor | 57.0 |
| Motor Load (%) | 102.6 |
| Measured Speed of Pump, RPM | 1,773 |
| kWh per Acre Ft. | 321 |
| Overall Plant Efficiency (%) | 55.8 |

DAN L. JOHNSON

Manager



September 30, 2002

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 25, 2002 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved to 70.0%.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY TOU-PA-SOP | IMPROVED PLANT TOU-PA-SOP | EFFICIENCY |
|------------------------|--------------------------------|------------------------------|------------|
| | Current Rate | Current Rate | Savings |
| Total kWh | 139,200 | 110,992 | 28,208 |
| kW Input | 42.5 | 33.9 | 8.6 |
| kWh per Acre Ft. | 321 | 256 | 65 |
| Acre Ft. per Year | 433.6 | 433.6 | |
| Avg. Cost per kWh | \$0.09 | | |
| Avg. Cost per Acre Ft. | . \$28.18 | \$22,47 | \$5.71 |
| Overall Plant Eff. (%) | 55.8 | 70.0 | · |
| TOTAL ANNUAL COST | \$12,219.53 | \$9,743.31 | \$2,476.22 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARTUF at (661)726-5662.

DAN L. JOHNSON

Manager

Hydraulic Services

42060 10th St. W. Lancaster, CA 93534-7002



September 30, 2002

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 25, 2002 and billing history for the past 12 months.

| EXISTING | PLANT | EFFIC | LENCY |
|----------|-------|--------|-------|
| | | TOU-PA | A-SOP |
| | Cı | ırrent | Rate |

| Total kWh | 139,200 |
|------------------------|-------------|
| kW Input | 42.5 |
| kWh per Acre Ft. | 321 |
| Acre Ft. per Year | 433.6 |
| Avg. Cost per kWh | \$0.09 |
| Avg. Cost per Acre Ft. | \$28.18 |
| Overall Plant Eff. (%) | 55.8 |
| | |
| TOTAL ANNUAL COST | \$12,219.53 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARTUE at (681)726-5662.

DAN L. JOHNSON

Manager

Confidential/Proprletary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant'WEST WELL #3

Location: 3310 W AVENUE A

HP:60

Cust#: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011 Pump Ref.#: 2579

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 26, 2002. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662,

| | Equipment | | |
|-------------|-------------------|-----|----------|
| Pump: | L&B | No: | '21847 |
| Motor: | US | No: | '1025182 |
| m, , , , | 501 | | |
| • | ressure, PSI | | .2 |
| • | ater Level, Feet | | 144.1 |
| Drawdown, | Feet | | 41.7 |
| Discharge H | lead, Feet | | .5 |
| Pumping W | ater Level, Feet | | 185.8 |
| Total Head, | Feet | | 186.3 |
| Capacity, G | PM | | 1,018 |
| GPM per Fo | ot Drawdown | | 24.4 |
| Acre Feet P | umped in 24 Hours | | 4.500 |
| kW Input to | Motor | | 60.7 |
| HP Input to | | | 81.4 |
| Motor Load | (%) | | 122.1 |
| Measured S | peed of Pump, RPM | | 1,776 |
| kWh per Ac | re Foot | | 324 |
| Overall Pla | nt Efficiency (%) | | 58.8 |

DAN L. JOHNSON Manager Hydraulic Services

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: 'WEST WELL #3

Location: 3310 W AVENUE A

HP: 60

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#: 2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 26, 2002, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP,

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 58.8% to 70.0%.
- 2. This can save you up to 29,735 kWh and \$2,954,26 annually.
- 3. These kWh savings translate to a 13-ton decrease in CO2 emissions.

| • | | Plant Efficiency | |
|------------------------------|-------------------|------------------|----------------|
| | <u>Existing</u> | Improved | <u>Savings</u> |
| Total kWh | 186,456 | 156,721 | 29,735 |
| kW Input | 60.7 | 51.0 | 9.7 |
| kWh per Acre Foot | 324 | 272 | 52 |
| Acre Feet per Year | 5 75.8 | | |
| Average Cost per kWh | \$0.10 | | |
| Average Cost per Acre Foot | \$32.17 | \$27.04 | \$5.13 |
| Overall Plant Efficiency (%) | 58.8 | 70.0 | |
| Total Annual Cost | \$18,524.78 | \$15,570.51 | \$2,954.26 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.

DAN L. JOHNSON Manager Hydraulic Services



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - NORTH WELL #1

35TH ST W N/S AVE A

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

DATE OF TEST: August 27, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EOUIPMENT

PUMP: AUROR

NO: V8472099

MOTOR: US

NO: R718303919

30 HP

METER: 732M-54

HYDRAULIC TEST REFERENCE NUMBER: 2580

| TEST RESULTS | TEST 1 | TEST 2 | TEST 3 |
|------------------------------|--------|--------|--------|
| Discharge Pressure, PSI | 1.1 | 11.6 | 19.8 |
| Standing Water Level, Ft. | 155.9 | 155.9 | 155.9 |
| Drawdown, Ft. | 33.2 | 28.5 | 24.4 |
| Discharge Head, Ft. | 2.5 | 26.8 | 45.7 |
| Pumping Water Level, Ft. | 189.1 | 184.4 | 180.3 |
| Total Head, Ft. | 191.6 | 211.2 | 226.0 |
| Capacity, GPM | 357.0 | 313.0 | 277.0 |
| GPM per Ft. Drawdown | 10.8 | 11.0 | 11.4 |
| Acre Ft. Pumped in 24 Hrs. | 1.578 | 1.383 | 1.224 |
| kW Input to Motor | 24.6 | 23.6 | 23.0 |
| HP Input to Motor | 33.0 | 31.6 | 30.8 |
| Motor Load (%) | 97.3 | 93.4 | 91.0 |
| Measured Speed of Pump, RPM | 1,759 | | |
| kWh per Acre Ft. | 374 | 409 | 451 |
| Overall Plant Efficiency (%) | 52.4 | 52.7 | 51.3 |

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

DAN I JOHNSON Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY PA-1

Current Rate

| Total kWh | 12,948 |
|------------------------|------------|
| kW Input | 24.6 |
| kWh per Acre Ft. | 374 |
| Acre Ft. per Year | 34.6 |
| Avg. Cost per kWh | \$0.15 |
| Avg. Cost per Acre Ft. | \$54.39 |
| Overall Plant Eff. (%) | 52.4 |
| | |
| TOTAL ANNUAL COST | \$1,881.78 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at 76611726-5662.

Dr. Comme

DAN L. JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved from 52.4% to 65.0%. These improvements can save you up to 2,518 kWh annually.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY PA-1 | IMPROVED PLANT PA-1 | |
|---|---|-------------------------------|--------------------|
| | Current Rate | Current Rate | Savings |
| Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh | 12,948 24.6 374 34.6 \$0.15 | 10,430 19.8 301 34.6 | 2,518 4.8 73 |
| Avg. Cost per Acre Ft. Overall Plant Eff. (%) | \$54.39 | \$43.81 65.0 | \$10.58 |
| TOTAL ANNUAL COST | \$1,881.78 | \$1,515.86 | \$365.92 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact CARY PARDUE at (661)76-5662.

DAN I JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

DATE OF TEST: August 27, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B

MOTOR: US

NO: D18009

NO: H1019392

50 HP

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

| Discharge Pressure, PSI | 2.0 |
|------------------------------|-------|
| Standing Water Level, Ft. | 133.4 |
| Drawdown, Ft. | 38.6 |
| Discharge Head, Ft. | 4.6 |
| Pumping Water Level, Ft. | 172.0 |
| Total Head, Ft. | 176.6 |
| Capacity, GPM | 714.0 |
| GPM per Ft. Drawdown | 18.5 |
| Acre Ft. Pumped in 24 Hrs. | 3.156 |
| kW Input to Motor | 42.4 |
| HP Input to Motor | 56.9 |
| Motor Load (%) | 102.3 |
| Measured Speed of Pump, RPM | 1,772 |
| kWh per Acre Ft. | 323 |
| Overall Plant Efficiency (%) | 56.0 |

DAN LA JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP Current Rate

| Total kWh | 146,976 |
|------------------------|-------------|
| kW Input | 42.4 |
| kWh per Acre Ft. | 323 |
| Acre Ft. per Year | 455.7 |
| Avg. Cost per kWh | \$0.09 |
| Avg. Cost per Acre Ft. | \$29.16 |
| Overall Plant Eff. (%) | 56.0 |
| | |
| TOTAL ANNUAL COST | \$13,288.96 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at 7(661)726-5662.

DAN L. JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved from 56.0% to 70.0%. These improvements can save you up to 29,392 kWh annually.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY TOU-PA-SOP | IMPROVED PLANT TOU-PA-SOP | EFFICIENCY |
|-----------------------|-----------------------------|---------------------------|------------|
| | Current Rate | Current Rate | Savings |
| Total kWh | 146,976 | 117,584 | 29,392 |
| kW Input | 42.4 | 33.9 | 8.5 |
| kWh per Acre Ft. | 323 | 258 | 64 |
| Acre Ft. per Year | 455.7 | 455.7 | |
| Avg. Cost per kWh | \$0.09 | | |
| Avg. Cost per Acre Ft | \$29.16 | \$23.33 | \$5.83 |
| Overall Plant Eff. (% |) 56.0 | 70.0 | , |
| | | | |
| TOTAL ANNUAL COST | \$13,288.96 | \$10,631.44 | \$2,657.52 |
| | | | |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (661)726-5662.

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - WEST WELL #3

35TH W 1/4 S/O AVE A

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

DATE OF TEST: August 28, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: 21847

MOTOR: US NO: 1025182

60 HP

METER: 0728K-1297

HYDRAULIC TEST REFERENCE NUMBER: 2579

TEST RESULTS

| Discharge Pressure, PSI | 0.9 |
|------------------------------|-------|
| Standing Water Level, Ft. | 148.3 |
| Drawdown, Ft. | 40.7 |
| Discharge Head, Ft. | 2.1 |
| Pumping Water Level, Ft. | 189.0 |
| Total Head, Ft. | 191.1 |
| Capacity, GPM | 962.0 |
| GPM per Ft. Drawdown | 23.6 |
| Acre Ft. Pumped in 24 Hrs. | 4.252 |
| kW Input to Motor | 60.7 |
| HP Input to Motor | 81.4 |
| Motor Load (%) | 122.1 |
| Measured Speed of Pump, RPM | 1,775 |
| kWh per Acre Ft. | 343 |
| Overall Plant Efficiency (%) | 57.0 |

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 28, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP Current Rate

| Total kWh | 187,980 |
|------------------------|-------------|
| kW Input | 60.7 |
| kWh per Acre Ft. | 343 |
| Acre Ft. per Year | 548.6 |
| Avg. Cost per kWh | \$0.09 |
| Avg. Cost per Acre Ft. | \$31.45 |
| Overall Plant Eff. (%) | 57.0 |
| | |
| TOTAL ANNUAL COST | \$17,254.86 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (661)726-5662.

DAN L JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 60 - PLANT: WEST WELL #3
CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 28, 2003 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 57.0% to 70.0%. These improvements can save you up to 34,823 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY TOU-PA-SOP Current Rate | IMPROVED PLANT TOU-PA-SOP Current Rate | EFFICIENCY Savings |
|---|--|--|-----------------------|
| Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh | 187,980 60.7 343 548.6 \$0.09 | 153,157 49.5 279 548.6 | 34,823 11.2 63 |
| Avg. Cost per Acre Ft. Overall Plant Eff. (%) | \$31.45 | \$25.63 70.0 | \$5.83 |
| TOTAL ANNUAL COST | \$17,254.86 | \$14,058.42 | \$3,196.44 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (601) 726-5662.

DAN I JOHNSON

Manager

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - NORTH WELL #1

35TH ST W N/S AVE A

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

DATE OF TEST: August 24, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (661)726-5662.

EOUIPMENT

PUMP: AUROR MOTOR: US

NO: V8472099

NO: R718303919

METER: 732M-54

HYDRAULIC TEST REFERENCE NUMBER: 2580

| TEST RESULTS | TEST 1 | TEST 2 | TEST 3 |
|------------------------------|--------|--------|--------|
| Discharge Pressure, PSI | 7.0 | 12.9 | 22.6 |
| Standing Water Level, Ft. | 147.6 | 147.6 | 147.6 |
| Drawdown, Ft. | 34.6 | 29.8 | 25.1 |
| Discharge Head, Ft. | 16.2 | 29.8 | 52.2 |
| Pumping Water Level, Ft. | 182.2 | 177.4 | 172.7 |
| Total Head, Ft. | 198.4 | 207.2 | 224.9 |
| Capacity, GPM | 328.0 | 295.0 | 270.0 |
| GPM per Ft. Drawdown | 9.5 | 9.9 | 10.8 |
| Acre Ft. Pumped in 24 Hrs. | 1.450 | 1.304 | 1.193 |
| kW Input to Motor | 25.0 | 24.4 | 23.3 |
| HP Input to Motor | 33.5 | 32.7 | 31.2 |
| Motor Load (%) | 98.9 | 96.5 | 92.2 |
| Measured Speed of Pump, RPM | 1,760 | | |
| kWh per Acre Ft. | 414 | 449 | 469 |
| Overall Plant Efficiency (%) | 49.0 | 47.2 | 49.1 |

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

Manager

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® CUREDAY

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 24, 2004 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY

PA-1

Current Rate

| Total kWh | 13,572 |
|------------------------|------------|
| kW Input | 25.0 |
| kWh per Acre Ft. | 414 |
| Acre Ft. per Year | 32.8 |
| Avg. Cost per kWh | \$0.11 |
| Avg. Cost per Acre Ft. | \$46.53 |
| Overall Plant Eff. (%) | 49.0 |
| | |
| TOTAL ANNUAL COST | \$1,525.61 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at 7661)726-5662.

DAN L JOHNSON

Manager

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 24, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 49.0% to 65.0%. These improvements can save you up to 3,337 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY PA-1 | IMPROVED PLANT PA-1 | |
|---|--------------------------|------------------------|------------|
| | Current Rate | Current Rate | Savings |
| Total kWh kW Input | 13,572 25.0 | 10,235 18.9 | 3,337 |
| kWh per Acre Ft. | 414 | 312 | 6.1 102 |
| Acre Ft. per Year Avg. Cost per kWh | 32.8 \$0.11 | 32.8 | |
| Avg. Cost per Acre Ft. Overall Plant Eff. (%) | | \$35.09 65.0 | \$11.44 |
| TOTAL ANNUAL COST | \$1,525.61 | \$1,150.49 | \$375.12 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at 16627726/2662.

Manager

Hydraulic Services

THISON

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® COMPANY

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

DATE OF TEST: August 23, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (661)726-5662.

EQUIPMENT

PUMP: L & B

NO: D18009

MOTOR: US

NO: H1019392

50 HP

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

| Discharge Pressure, PSI | 0.9 |
|------------------------------|-------|
| Standing Water Level, Ft. | 127.8 |
| Drawdown, Ft. | 40.0 |
| Discharge Head, Ft. | 2.1 |
| Pumping Water Level, Ft. | 167.8 |
| Total Head, Ft. | 169.9 |
| Capacity, GPM | 676.0 |
| GPM per Ft. Drawdown | 16.9 |
| Acre Ft. Pumped in 24 Hrs. | 2.988 |
| kW Input to Motor | 42.0 |
| HP Input to Motor | 56.3 |
| Motor Load (%) | 101.4 |
| Measured Speed of Pump, RPM | 1,773 |
| kWh per Acre Ft. | 337 |
| Overall Plant Efficiency (%) | 51.5 |

Manager

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 23, 2004 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP1 Current Rate

| Total kWh | 157,248 |
|------------------------|-------------|
| kW Input | 42.0 |
| kWh per Acre Ft. | 337 |
| Acre Ft. per Year | 466.0 |
| Avg. Cost per kWh | \$0.07 |
| Avg. Cost per Acre Ft. | \$22.84 |
| Overall Plant Eff. (%) | 51.5 |
| | |
| TOTAL ANNUAL COST | \$10,645.69 |

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at \$\int_{661}\quad \quad 26-5662.

DAN L. JOHNSON

Manager

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 23, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 51.5% to 70.0%. These improvements can save you up to 41,569 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| EXISTING | PLANT EFFICIENCY TOU-PA-SOP | IMPROVED PLANT TOU-PA-SOP | EFFICIENCY |
|---|--------------------------------|------------------------------|--------------------|
| | Current Rate | Current Rate | Savings |
| Total kWh kW Input | 157,248 | 115,679 | 41,569 |
| kWh per Acre Ft. | 42.0 337 | 30.9 248 | 11. 1 89 |
| Acre Ft. per Year Avg. Cost per kWh | 466.0 \$0.07 | 466.0 | |
| Avg. Cost per Acre Ft. Overall Plant Eff. (%) | | \$16.80 70.0 | \$6.04 |
| TOTAL ANNUAL COST | \$10,645.69 | \$7,831.46 | \$2,814.23 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at (6617)26-3662.

Manager

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - WEST WELL #3

3310 W AVENUE A

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

DATE OF TEST: August 24, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (661)726-5662.

EQUIPMENT

PUMP: L & B

MOTOR: US

NO: 21847

NO: 1025182

60 HP

METER: 0728K-1297

HYDRAULIC TEST REFERENCE NUMBER: 2579

| TEST RESULTS | TEST 1 | TEST 2 |
|------------------------------|--------|--------|
| Discharge Pressure, PSI | 0.9 | 44.0 |
| Standing Water Level, Ft. | 141.8 | 141.8 |
| Drawdown, Ft. | 39.6 | 22.1 |
| Discharge Head, Ft. | 2.1 | 101.6 |
| Pumping Water Level, Ft. | 181.4 | 163.9 |
| Total Head, Ft. | 183.5 | 265.5 |
| Capacity, GPM | 878.0 | 322.0 |
| GPM per Ft. Drawdown | 22.2 | 14.6 |
| Acre Ft. Pumped in 24 Hrs. | 3.881 | 1.423 |
| kW Input to Motor | 60.7 | 52.0 |
| HP Input to Motor | 81.4 | 69.7 |
| Motor Load (%) | 122.1 | 104.6 |
| Measured Speed of Pump, RPM | 1,777 | |
| kWh per Acre Ft. | 375 | 877 |
| Overall Plant Efficiency (%) | 50.0 | 31.0 |

The above test results indicate various operating conditions of this pump. Test #1 the pump was running slightly throttled. Test #2 the pump was filling the domestic reservoir.

Manager

Hydraulic Services

CANSON

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® COMPANY

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 24, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved from 50.0% to 70.0%. These improvements can save you up to 55,684 kWh annually.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

| PLANT EFFICIENCY TOU-PA-SOP | IMPROVED PLANT TOU-PA-SOP | EFFICIENCY |
|--------------------------------|--|--|
| Current Rate | Current Rate | Savings |
| 194,724 | 139,040 | 55,684 |
| 60.7 | 43.3 | 17.4 |
| 3 7 5 | 268 | 107 |
| 518.6 | 518.6 | |
| \$0.07 | | |
| \$25.44 | \$18.16 | \$7.27 |
| 50.0 | 70.0 | · |
| | | |
| \$13,192.55 | \$9,419.95 | \$3,772.60 |
| | TOU-PA-SOP Current Rate 194,724 60.7 375 518.6 \$0.07 \$25.44 50.0 | TOU-PA-SOP TOU-PA-SOP Current Rate 194,724 139,040 60.7 43.3 375 268 518.6 518.6 \$0.07 \$25.44 \$18.16 50.0 70.0 |

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at 1661) 726-5662.

Manager

Hydraulic Services

JOHNSON