DECLARATION

DECLARATION

I, Edward A. Wopschall, declare:

1. I am a managing member for Wagas Land Company LLC, a party to this action. In lieu of deposition testimony for the Phase 4 trial, I am providing this declaration. This declaration applies only to the categories I have filled in. The items left blank or crossed out do not apply to me. I have personal knowledge of each fact herein and would testify competently thereto under oath.

Property Ownership and Parcel Size

2. Wagas Land Company LLC owns property that overlies the Antelope Valley Area of Adjudication as decided by this Court. The land is in both Kern County and in Los Angeles

County and is identified by the following APN/APNs: The parcels consist of approximately 630 acres of contiguous land fronting on Avenue A near 30th Street West. Approximately ½ the land is located in Kern County and ½ is located in Los Angeles County. The Assessors' parcel numbers are:

Los Angeles County 3115-1-17.

Los Angeles County 3115-1-18.

Los Angeles County 3115-03-1.

Los Angeles County 3115-03-2.

Kern County 473-021-04.

[If additional room is needed, please identify the APN/APNs in Exhibit A.] A true and correct copy of Exhibit A is attached hereto and incorporated herein.

- 3. Wagas Land Company LLC claims groundwater rights only as to the properties listed in Paragraph 2 and Exhibit A.
- 4. For each APN/APNs identified above, the total acreage by parcel is as follows: I don't know the exact acreage of each of the APNs but the parcels are all contiguous and total approximately 630 acres, ½ of which is in Kern County and ½ is in Los Angeles County. [Hf additional room is needed, please identify the APN/APNs and parcel size in Exhibit B.] A true and correct copy of Exhibit B is attached hereto and incorporated herein.

Leases

5. For each A	PN/APNs identified above Waga	as Land Company LLC and its
predecessor entities have	owned the property during the fo	llowing timer period: since 1925.
Wagas Land Company Ll	C took title in September 2005.	Prior thereto for many years title was
held by Wagas Land Com	pany, a partnership aka Wagas R	anch aka Wagas Gun Club. Prior
thereto title was held by v	rarious entities consisting of at lea	ast one corporation, one sole
proprietorship and one pa	rtnership each of which used the	name Wagas Land Company, Wagas
Gun Club and or Wagas F	Ranch.	

- 6. The following are all individuals/entities appearing on the title for the above identified APN/APNS from Jan 1, 2000 to the present: Wagas Land Company, a general partnership and Wagas Land Company LLC.
- 7. For each individual/entity identified in paragraph 6 that individual/entity appeared on the title during the following time: Wagas Land Company LLC took title in September 2005. Prior thereto Wagas Land Company, a general partnership held title.

8.	(declarant or party affiliated with declarant) leases property that
<u> </u>	own and that overlies the Antelope Valley Area of Adjudication as
decid	ed by this court and identified by the following APNS:
9.	The total acreage by parcel is:
10.	The property is currently leased to:
11.	The property was leased on the following dates:
12.	The lease provides that may claim groundwater rights from the use of
	- 2 -

LAW OFFICES OF BEST BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, CALIFORNIA 92502

water on the leased property. Attached to this declaration is a true and correct copy of the lease.
[If additional room is needed, please list APN/APNs, acreage by APN, Lessee by APN and dates
for each Lessee by APN for each parcel in Exhibit C.] A true and correct copy of Exhibit C is
attached hereto and incorporated herein.
13 leases property from which overlies the
Antelope Valley Area of Adjudication as decided by this court and is identified by the following
APNS:
14. The total acreage by parcel is:
15. The Lease provides that may claim groundwater rights from use of
water on leased property. Attached to this declaration is a true and correct copy of the lease.
[If additional room is needed, please attach APN/APNs, Name of the Lessor and acreage by APN
for each parcel list in Exhibit D to this declaration.] A rue and correct copy of Exhibit D is
attached hereto and incorporated herein.
16claims groundwater rights only as to the leasehold interests listed
in Paragraph 15 and Exhibit D.
17 claims groundwater rights only as to the properties listed in
Paragraph 2 and Exhibit A and as to the leasehold interests listed in Paragraph 8 and Exhibit C.
18. To the best of my knowledge, onlyclaims groundwater rights as to the
leased parcel(s) identified in paragraph 15 and Exhibit D.
Water Meter Records
19 measures the groundwater production on the above referenced
properties by water meters. Exhibit E contains the records for these water meters for the
following years:
- 3 -

A true and correct copy of Exhibit E is attached hereto and incorporated herein.

20. Exhibit F sets forth the total yearly production amounts by metered water well on the above referenced properties for the years 2000-2004, 2011, and 2012. A true and correct copy of Exhibit F is attached hereto and incorporated herein.

State Water Project Purchases

21.	purchases State Water Project water from a State Water Contractor
C 1	
for use by	on the properties referenced above. Exhibit G contains true
and correct copies of the ir	voices for delivery of State Water Project Water to the properties
•	
referenced above.	

22. Exhibit H sets forth the total yearly State Water Project water deliveries to the properties referenced above for the years 2000-2004, 2011, and 2012. A true and correct copy of Exhibit H is attached hereto and incorporated herein.

Pump Tests/ Electric Records

- 23. In order to calculate groundwater pumped and used on the properties referenced above, Wagas Land Company LLC and Wagas Land Company a general partnership relied on Edison Company pump tests and electric records. Exhibit I contains true and correct copies of the pump test records and electrical records for wells on the properties referenced above. The electric records attached to this declaration as Exhibit I do not include electric use on the properties referenced above for anything other than pumping groundwater.
- 24. Exhibit J_lalso sets forth the amount of total yearly groundwater that Wagas Land Company LLC estimates was pumped and used on the properties referenced above for the years 2000-2004, 2011, and 2012 based on the attached pump test records and electrical records for the wells on the properties referenced above. A true and correct copy of Exhibit J_l is attached hereto and incorporated herein.
- 25. Pump tests were performed on the following dates: the dates shown on the Edison pump

LAW OFFICES OF	BEST BEST & KRIEGER LLP	3750 UNIVERSITY AVENUE, SUITE 400	P.O. BOX 1028	RIVERSIDE, CALIFORNIA 92502	
----------------	-------------------------	-----------------------------------	---------------	-----------------------------	--

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

test records contained in Exhibit I. Edison Company pump tests were also performed for years prior to the years referenced above. We have those records back to and including 1985.

- 26. Wagas Land Company LLC is not producing pump test records for the following dates years prior to 2000 because the Court Order did not direct us to do so.
- 27. I am not aware of any other that Edison Company also conducted pump tests on the properties referenced above prior to 1985 but Edison Company has not preserved those records and neither have we.having been performed on the properties referenced above.

Pump Tests/Diesel Records

- In order to calculate groundwater pumped and used on the properties referenced above, relied on pump tests and diesel fuel records. Exhibit K contains true and correct copies of the records pertaining to pump tests and diesel fuel purchases for the properties referenced above. The diesel fuel records attached to this declaration as Exhibit K do not include diesel fuel used on the properties referenced above for anything other than pumping groundwater.
- 29. Exhibit L sets forth the amounts of total yearly groundwater pumped and used on the properties referenced above for the years 2000-2004, 2011, and 2012. A true and correct copy of Exhibit L is attached hereto and incorporated herein.
- Pump tests were performed on the following dates: 30.

31. is not producing pump test records for the following dates because:

32. I am not aware of any other pump tests having been performed on the properties referenced above.

Crop Duties and Irrigated Acres

33. In order to calculate water use on the properties referenced above, relies on the amount of acres in irrigation on the properties referenced above multiplied by the

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28


water was used for the following:


foregoing is true and correct. Executed this <u>26</u> day of January 2013, at <u>LANCASTER</u>, CA.


California.


EXHIBIT "A"

LAW OFFICES OF BEST BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, CALIFORNIA 92502 EXHIBIT "B"









LAW OFFICES OF BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, CALIFORNIA 92502 EXHIBIT "F"

<u>Year</u>	Well	Yearly Production
,		
/	- 13 -	
	DECLARATION	




EXHIBIT "H"

- 15 -

LAW OFFICES OF BEST BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, CALIFORNIA 92502 EXHIBIT "I"

- 16 -

WAGAS LAND COMPANY LLC WATER USAGE: 2000-2004 AND 2011-2012 (Revised 12-19-12)

(AS DETERMINED BY EDISON COMPANY PUMP TESTS)

			South Well	
			(60 HP)	
			Referred to	
			by Edison as	
	North Well	East Well	"West Well"	Total
Year	(30 HP) AFY	(50 HP) AFY	AFY	AFY
2000	220.3	556.7	605.9	1382.9
2001	88.3	426.7	521.7	1036.7
2002	44.5	433.6	575.8	1053.9
2003	34.6	455.7	548.6	1038.9
2004	32.8	466	518.6	1017.4
Average				1106.0
Median				1038.9
Highest				1382.9
2011	11.5	472.1	467.9	951.5
2012	10.3	469.8	536.7	1016.8

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant'NORTH WELL #1

Location: 35TH ST W N/S AVE A

Cust #: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 11, 2000. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

	Equipment	•		
Pump:	AUROR	No:	'V8472099	
Motor:	US	No:	'R718303919	
Discharge Pressure, PSI	1.7		15.1	26.5
Standing Water Level, Feet	143,7		143.7	143.7
Drawdown, Feet	41.3		35.0	28.9
Discharge Head, Feet	3.9		34.9	61.2
Pumping Water Level, Feet	185.0		178.7	172.6
Total Head, Feet	188.9		213.6	233.8
Capacity, GPM	379		319	263
GPM per Foot Drawdown	9.2		9.1	9.1
Acre Feet Pumped in 24 Hours	1.675		1.410	1,162
kW Input to Motor	24.5		23.8	22.2
HP Input to Motor	32.9		31.9	29.8
Motor Load (%)	96.9		94.2	87.8
Measured Speed of Pump, RPM	1,774			
kWh per Acre Foot	351		405	458
Overall Plant Efficiency (%)	55.0		53.9	52.2

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

SOUTHERN CALIFORNIA EDISON INTERNATIONAL COMPANY

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: 'NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust#: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 11, 2000, billing history for the past 12 months, and your current rate of TOU-PA-A.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 55.0% to 65.0%.
- 2. This can save you up to 11,868 kWh and \$1,233.92 annually.
- 3. These kWh savings translate to a 5.2-ton decrease in CO₂ emissions.

	Existing	Plant Efficiency improved	Savings
Total kWh	77,340	65,474	11,866
kW Input	24.5	20.7	3.8
kWh per Acre Foot	351	297	54
Acre Feet per Year	220.3		
Average Cost per kWh	\$0.10		
Average Cost per Acre Foot	\$36.51	\$30.91	\$5.60
Overall Plant Efficiency (%)	55.0	65.0	,
Total Annual Cost	\$8,042.74	\$6,808.82	\$1,233,92

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.

Confidential/Proprietary Information

February 14, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant:

'EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Meter:

Cust #: 0-000-2633 3412M-6681 Serv. Acct. #: Pump Ref.#:

014-8034-41 2578

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 11, 2000. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

Equipment

	m of or fearing or or		
Pump:	L&B	No:	'D18009
Motor:	US	No:	'H1019392
Discharge Pr	essure, PSI		1.3
Standing Wa	ter Level, Feet		145.8
Drawdown, F	eet		36.4
Discharge He	ead, Feet		3.0
Pumping Wa	ter Level, Feet		182.2
Total Head, i	eet		185.2
Capacity, GP	M		709
GPM per For	ot Drawdown		19.5
Acre Feet Pu	mped in 24 Hours		3.134
kW Input to N	Notor		43.0
HP Input to N	fotor		57.7
Motor Load (%)		103.8
Measured Sp	eed of Pump, RPM		1,774
kWh per Acr	e Foot		329
Overali Plani	t Efficiency (%)		57.5

Confidential/Proprietary Information

February 14, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant:

'EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Cust#: 0-000-2633

Serv. Acct. #: 014-8034-41

Meter: 3412M-6681 Pump Ref.#:

2578

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 11, 2000, billing history for the past 12 months, and your current rate of TOU-PA-SOP-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 57.5% to 70.0%.
- 2. This can save you up to 32,736 kWh and \$2,262.30 annually.
- 3. These kWh savings translate to a 14-ton decrease in CO2 emissions.

		Plant Efficiency	
	Existing	<u>improved</u>	Savings
Total kWh	183,372	150,636	32,736
kW Input	43.0	35.3	7.7
kWh per Acre Foot	329	271	59
Acre Feet per Year	556.7		
Average Cost per kWh	\$0.07		
Average Cost per Acre Foot	\$22.76	\$18.70	\$4.06
Overall Plant Efficiency (%)	57.5	70.0	
Total Annual Cost	\$12,672.47	\$10,410.18	\$2,262.30

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUÉ at (661)726-5662.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant:WEST WELL #3

Location: 3310 W AVENUE A

HP:60

Cust #: 0-006-1729

Serv. Acct. #: 003-8970-34

Meter: 3416M-7011

Pump Ref.#: 2579

In accordance with your request, an energy efficiency test was performed on your turbine well pump on October 12, 2000. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

,	Dump	Equipmen		104047	
	Pump:			21847	
	Motor:	US	No:	'1025182	
Discharge	Pressure, PS	SI .		.8	14.1
	Water Level, I		158		158.9
Drawdow			35		30.7
	Head, Feet			.8	32.6
Pumping \	Water Level, F	Feet -	194		189.6
Total Hea	d, Feet		195		222.2
Capacity.			97	78	827
GPM per l	Foot Drawdov	۷n	27	.8	26.9
Acre Feet	Pumped in 24	4 Hours	4.32	23	3.655
kW Input I		•	61	.2	60.5
HP Input i			82	.1	81.1
Motor Loa	d (%)		123	.1	121.7
Measured	Speed of Pur	mp, RPM	1,77	75	
kWh per /	Acre Foot		34	10	397
Overall P	lant Efficienc	y (%)	59	.0	57.2

Test 1 is the normal operation of this pump at the time of the above test(s). The other results. were obtained by throttling the discharge.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: 'WEST WELL #3

Location: 3310 W AVENUE A

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#: 2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 12, 2000, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- Overall plant efficiency can be improved from 59.0% to 70.0%.
- 2. This can save you up to 32,498 kWh and \$2,000.86 annually.
- 3. These kWh savings translate to a 14-ton decrease in CO₂ emissions.

• • • •	Plant Efficiency		
•	Existing	<u>Improved</u>	<u>Savings</u>
Total kWh	205,908	173,410	32,498
kW input	61.2	51.5	9.7
kWh per Acre Foot	340 ·	286	54
Acre Feet per Year	605.9		57
Average Cost per kWh	\$0.06		
Average Cost per Acre Foot	\$20.92	\$17.62	\$3,30
Overall Plant Efficiency (%)	59.0	70.0	
Total Annual Cost	\$12,677.34	\$10,676.48	\$2,000.86

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - NORTH WELL #1

35TH ST W N/S AVE A

CUST #: 0-006-1729 SERV ACCT #: 003-4220-09

DATE OF TEST: October 1, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: AUROR NO: V8472099

MOTOR: US NO: R718303919 30 HP

METER: 732M-54

HYDRAULIC TEST REFERENCE NUMBER: 2580

TEST RESULTS	TEST 1	TEST 2	TEST 3
Discharge Pressure, PSI	1.0	15.9	26.3
Standing Water Level, Ft.	150.4	150.4	150.4
Drawdown, Ft.	39.1	32.2	26.1
Discharge Head, Ft.	2.3	36.7	40.1 60.8
Pumping Water Level, Ft.	189.5	182.6	176.5
Total Head, Ft.	191.8	219.3	237.3
Capacity, GPM	366.0	294.0	235.0
GPM per Ft. Drawdown	9.4	9.1	9.0
Acre Ft. Pumped in 24 Hrs.	1.618	1.299	1.039
kW Input to Motor	24.3	23.1	21.5
HP Input to Motor	32.6	31.0	28.8
Motor Load (%)	96.1	91.4	85.1
Measured Speed of Pump, RPM	1770		00.1
kWh per Acre Ft.	(361)	427	497
Overall Plant Efficiency (%)	54.4	52.6	48.8

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by threttling the discharge.

Manager

Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY PA-1

Current Rate

Total kWh	31836
kW Input	24.3
kWh per Acre Ft.	361-
Acre Ft. per Year	88.3
Avg. Cost per kWh	\$0.11
Avg. Cost per Acre Ft.	\$39.30
Overall Plant Eff. (%)	54.4
TOTAL ANNUAL COST	\$3,469.61

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDYE at / 661) 726-5662.

DAN SOHNSON

Manager

Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved to 65.0%.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY PA-1	IMPROVED PLANT PA-1	EFFICIENCY
	Current Rate	Current Rate	Savings
Total kWh	31836	26644	5192
kW Input	24.3	20.3	4.0
kWh per Acre Ft.	361	. 302	59
Acre Ft. per Year	88.3	88.3	
Avg. Cost per kWh	\$0.11		
Avg. Cost per Acre Ft.		\$32.89	\$6.41
Overall Plant Eff. (%)	54.4	65.0	·
TOTAL ANNUAL COST	\$3,469.61	\$2,903.80	\$565.81

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARDU

DAN JÖHNSON

Manager

Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 SERV ACCT #: 014-8034-41

DATE OF TEST: October 1, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: D18009

MOTOR: US NO: H1019392 50 HP

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

Discharge Pressure, PSI	1.1	
Standing Water Level, Ft.	144.7	
Drawdown, Ft.	36.9	
Discharge Head, Ft.	2.5	
Pumping Water Level, Ft.	181.6	
Total Head, Ft.	184.1	
Capacity, GPM	700.0	19 gal possof doudour
GPM per Ft. Drawdown	19.0	0 1
Acre Ft. Pumped in 24 Hrs.	3.094	
kW Input to Motor	42.7	,
HP Input to Motor	57.3	
Motor Load (%)	103.1	
Measured Speed of Pump, RPM	1773	
kWh per Acre Ft.	331	
Overall Plant Efficiency (%)	56.8	_ ^
	11/	~ 3 <i>F</i> 1

Manager

14 calper 1 to Proving Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY
TOU-PA-SOP
Current Rate

Total kWh	141372
kW Input	42.7
kWh per Acre Ft.	331
Acre Ft. per Year	426.7
Avg. Cost per kWh	\$0.07
Avg. Cost per Acre Ft.	\$21.82
Overall Plant Eff. (%)	56.8
TOTAL ANNUAL COST	\$9,311.04

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (561) 726-5662.

138 Days

DAN JOHNSON Manager

Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 1, 2001 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved to 70.0%.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

	EXISTING		EFFICIENCY TOU-PA-SOF urrent Rate		
Total kWh kW Input kWh per Acre Acre Ft. per Avg. Cost pe	Year		141372 42.7 331 426.7 \$0.07	114780 34.7 269 426.7	8.0
Avg. Cost per Overall Plant			\$21.82 56.8	\$17.71 70.0	
TOTAL ANNUAL	COST	· ·	\$9,311.04	\$7,559.63	\$1,751.42

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARTUE at (661) 726-5662.

DAN JOHNSON

Manager

Hydraulic Services



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - WEST WELL #3

35TH W 1/4 S/O AVE A

CUST #: 0-006-1729 SERV ACCT #: 003-6970-34

DATE OF TEST: October 2, 2001

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B MOTOR: US

NO: 21847

NO: 1025182

60 HP

METER: 0728K-1297

HYDRAULIC TEST REFERENCE NUMBER: 2579

TEST RESULTS

Discharge Pressure, PSI	0.8
Standing Water Level, Ft.	168.3
Drawdown, Ft.	31.8
Discharge Head, Ft.	1.8
Pumping Water Level, Ft.	200.1
Total Head, Ft.	201.9
Capacity, GPM	938.0
GPM per Ft. Drawdown	29.5
Acre Ft. Pumped in 24 Hrs.	4.146
kW Input to Motor	61.1
HP Input to Motor	81.9
Motor Load (%)	122.9
Measured Speed of Pump, RPM	1786
kWh per Acre Ft.	354
Overall Plant Efficiency (%)	58.4

DAN JOHNSON

Manager

Hydraulic Services

15,75 per 145 men



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 2, 2001 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY
TOU-PA-SOP
Current Rate

Total kWh	184572
kW Input	61.1
kWh per Acre Ft.	354
Acre Ft. per Year	521.7
Avg. Cost per kWh	\$0.07
Avg. Cost per Acre Ft.	\$23.02
Overall Plant Eff. (%)	58.4
TOTAL ANNUAL COST	\$12,010.28

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (661) 726-5662.

Manager

Hydraulic Services

125



October 5, 2001

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed October 2, 2001 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved to 70.0%.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY TOU-PA-SOP	IMPROVED PLANT TOU-PA-SOP	
	Current Rate	Current Rate	Savings
Total kWh	184572	153901	30671
kW Input	61.1	50.9	10.2
kWh per Acre Ft.	354	295	59
Acre Ft. per Year	521.7	521.7	
Avg. Cost per kWh	\$0.07		
Avg. Cost per Acre Ft.		\$19.19	\$3.83
Overall Plant Eff. (%)	58.4	70.0	,
TOTAL ANNUAL COST	\$12,010.28	\$10,014.50	\$1,995.79

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (661) 726-5662.

DAN JOHNSON

Manager

Hydraulic Services

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant/NORTH WELL #1

Location: 35TH ST W N/S AVE A HP: 30

Cust#: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 25, 2002. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

	Equipment			
Pump:	AUROR	No:	'V8472099	
Motor:	US	No:	'R718303919	
Discharge Pressure, PSI	1.0		11.5	19.4
Standing Water Level, Feet	152.7		152.7	152.7
Drawdown, Feet	34.0		29.5	25.5
Discharge Head, Feet	2.3		26.6	44.8
Pumping Water Level, Feet	186.7		182.2	178.2
Total Head, Feet	189.0		208.8	223.0
Capacity, GPM	325		294	227
GPM per Foot Drawdown	9.6		10.0	8.9
Acre Feet Pumped in 24 Hours	1.437		1.299	1.003
kW Input to Motor	24.8		24.0	23.1
HP Input to Motor	33.3		32.2	31.0
Motor Load (%)	98.1		94.9	91.4
Measured Speed of Pump, RPM	1,760		•	
kWh per Acre Foot	414		443	.553
Overall Plant Efficiency (%)	46.6		48.2	41.3

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

DAN L. JOHNSON Manager Hydraulic Services

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant 'NORTH WELL #1

Location: 35TH ST W N/S AVE A HP: 30

Cust#: 0-006-1729 Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

Pump Ref.#: 2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 25, 2002, billing history for the past 12 months, and your current rate of TOU-PA-A.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- Overall plant efficiency can be improved from 48.6% to 65.0%.
- This can save you up to 5,206 kWh and \$635.14 annually.
 These kWh savings translate to a 2.3-ton decrease in CO₂ emissions.

	Existing	Plant Efficiency <u>improved</u>	<u>Şavings</u>
Total kWh	18,432	13,226	5,206
kW Input	24.8	17.8	7.0
kWh per Acre Foot .	414	297	117
Acre Feet per Year	44,5		***
Average Cost per kWh	\$0.12	•	
Average Cost per Acre Foot	\$50.56	\$36.28	\$14.28
Overall Plant Efficiency (%)	46.6	65.0	
Total Annual Cost	\$2,248.74	\$1,613.60	\$635,14

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.

DAN L. JOHNSON Manager Hydraulic Services



September 30, 2002

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

DATE OF TEST: September 25, 2002

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: D18009

MOTOR: US NO: H1019392

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

Discharge Pressure, PSI	1.5
Standing Water Level, Ft.	131.6
Drawdown, Ft.	40.1
Discharge Head, Ft.	3.5
Pumping Water Level, Ft.	171.7
Total Head, Ft.	175.2
Capacity, GPM	719.0
GPM per Ft. Drawdown	17.9
Acre Ft. Pumped in 24 Hrs.	3.178
kW Input to Motor	42.5
HP Input to Motor	57.0
Motor Load (%)	102.6
Measured Speed of Pump, RPM	1,773
kWh per Acre Ft.	321
Overall Plant Efficiency (%)	55.8

DAN L. JOHNSON

50 HP

Manager



September 30, 2002

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY

LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 25, 2002 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved to 70.0%.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY TOU-PA-SOP	IMPROVED PLANT TOU-PA-SOP	EFFICIENCY
	Current Rate	Current Rate	Savings
Total kWh	139,200	110,992	28,208
kW Input	42.5	33.9	8.6
kWh per Acre Ft.	321	256	65
Acre Ft. per Year	433.6	433.6	•
Avg. Cost per kWh	\$0.09		
Avg. Cost per Acre Ft.	\$28.18	\$22.47	\$5.71
Overall Plant Eff. (%)	55.8	70.0	, , , ,
TOTAL ANNUAL COST	\$12,219.53	\$9,743.31	\$2,476.22

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any questions, please contact GARY PARTUE **(4)**61)726-5662.

> DAN L JOHNSON

Manager

Hydraulic Services

42060 10th St. W. Lancaster, CA 93534-7002



September 30, 2002

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed September 25, 2002 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY
TOU-PA-SOP
Current Rate

Total kWh	139,200
kW Input	42.5
kWh per Acre Ft.	321
Acre Ft. per Year	433.6
Avg. Cost per kWh	\$0.09
Avg. Cost per Acre Ft.	\$28.18
Overall Plant Eff. (%)	55.8
TOTAL ANNUAL COST	\$12,219.53

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pump efficiency will be continued.

If you have any questions, please contact GARY PARDUE at (681)726-5662

DAN L. GOHNSON

Manager

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL Company

Confidential/Proprietary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

> PUMPING COST ANALYSIS, Plant: 'WEST WELL #3 Location: 3310 W AVENUE A HP: 60

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#: 2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on September 26, 2002, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 58.8% to 70.0%.
- 2. This can save you up to 29,735 kWh and \$2,954.26 annually.
- 3. These kWh savings translate to a 13-ton decrease in CO₂ emissions.

	Plant Efficiency		·
Savings	Improved	Existing	•
29,735	156,721	186,456	Total kWh
9.7	51.0	60.7	kW Input
52	272	324	kWh per Acre Foot
		575.8	Acre Feet per Year
		\$0.10	Average Cost per kWh
\$5.13	\$27.04	\$32,17	Average Cost per Acre Foot
*	70.0	58.8	Overall Plant Efficiency (%)
\$2,954.26	\$15,570.51	\$18,524.78	Total Annual Cost

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum energy efficiency will be continued. If you have any questions regarding this report, please contact GARY PARDUE at (661)726-5662.

DAN L. JOHNSON Manager Hydraulic Services

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL Company

Confidential/Proprletary Information

October 19, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

HYDRAULIC TEST RESULTS, Plant'WEST WELL #3

Location: 3310 W AVENUE A

HP: 60

Cust#: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter: 3416M-7011

Pump Ref.#: 2579

In accordance with your request, an energy efficiency test was performed on your turbine well pump on September 26, 2002. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

	Equipment	ł	
Pump:	L&B		'21847
Motor:	US	No:	'1025182
Discharge F	Pressure, PSI		.2
Standing W	ater Level, Feet		144.1
Drawdown,	Feet		41.7
Discharge H	lead, Feet		.5
Pumping W	ater Level, Feet		185.8
Total Head, Feet			186.3
Capacity, G	PM		1,018
GPM per Foot Drawdown			24,4
Acre Feet Pumped in 24 Hours			4.500
kW Input to Motor			60.7
HP Input to Motor			81.4
Motor Load (%)			122.1
Measured S	peed of Pump, RPA	Л	1,776
kWh per Acre Foot			324
Overall Plan	nt Efficiency (%)		58.8

DAN L. JOHNSON Manager Hydraulic Services



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - NORTH WELL #1

35TH ST W N/S AVE A

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

DATE OF TEST: August 27, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: AUROR NO: V8472099

MOTOR: US NO: R718303919 30 HP

METER: 732M-54

HYDRAULIC TEST REFERENCE NUMBER: 2580

TEST RESULTS	TEST 1	TEST 2	TEST 3
Discharge Pressure, PSI	1.1	11.6	19.8
Standing Water Level, Ft.	155.9	155.9	155.9
Drawdown, Ft.	33.2	28.5	24.4
Discharge Head, Ft.	2.5	26.8	45.7
Pumping Water Level, Ft.	189.1	184.4	180.3
Total Head, Ft.	191.6	211.2	226.0
Capacity, GPM	357.0	313.0	277.0
GPM per Ft. Drawdown	10.8	11.0	11.4
Acre Ft. Pumped in 24 Hrs.	1.578	1.383	1.224
kW Input to Motor	24.6	23.6	23.0
HP Input to Motor	33.0	31.6	30.8
Motor Load (%)	97.3	93.4	91.0
Measured Speed of Pump, RPM	1,759		
kWh per Acre Ft.	374	409	451
Overall Plant Efficiency (%)	52.4	52.7	51.3

Test 1 is the normal aperation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

Manager

Hydraulic Services

L. JOHNSON



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY

PA-1 Current Rate

Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh Avg. Cost per Acre Ft.	12,948 24.6 374 34.6 \$0.15 \$54.39
Overall Plant Eff. (%)	52.4
TOTAL ANNUAL COST	\$1,881.78

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at 1661,726-5662.

- A -

DAN L. ZOMNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved from 52.4% to 65.0%. These improvements can save you up to 2,518 kWh annually.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY PA-1	IMPROVED PLANT PA-1	EFFICIENCY
	Current Rate	Current Rate	Savings
Total kWh kW Input kWh per Acre Ft.	12,948 24.6 374	10,430 19.8 301	2,518 4.8
Acre Ft. per Year Avg. Cost per kWh	34.6 \$0.15	34.6	73
Avg. Cost per Acre Ft. Overall Plant Eff. (%)		\$43.81 65.0	\$10.58
TOTAL ANNUAL COST	\$1,881.78	\$1,515.86	\$365.92

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (66) 7/26-5662.

DAN I JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

DATE OF TEST: August 27, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: D18009

MOTOR: US NO: H1019392 50 HP

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

Discharge Pressure, PSI	2.0
Standing Water Level, Ft.	133.4
Drawdown, Ft.	38.6
Discharge Head, Ft.	4.6
Pumping Water Level, Ft.	172.0
Total Head, Ft.	176.6
Capacity, GPM	714.0
GPM per Ft. Drawdown	18.5
Acre Ft. Pumped in 24 Hrs.	3.156
kW Input to Motor	42.4
HP Input to Motor	56.9
Motor Load (%)	102.3
Measured Speed of Pump, RPM	1,772
kWh per Acre Ft.	323
Overall Plant Efficiency (%)	56.0

DAN L. JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP Current Rate

Total kWh	146,976
kW Input	42.4
kWh per Acre Ft.	323
Acre Ft. per Year	455.7
Avg. Cost per kWh	\$0.09
Avg. Cost per Acre Ft.	\$29.16
Overall Plant Eff. (%)	56.0
TOTAL ANNUAL COST	\$13,288.96

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at/(661)726-5662.

DAN L. JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

> SUBJECT: PUMPING COST ANALYSIS - HP: 50 - PLANT: EAST WELL #2 CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41 HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 27, 2003 and billing history for the past 12 months.

It is recommended and assumed that:

- Overall plant efficiency can be improved from 56.0% to 70.0%.
 These improvements can save you up to 29,392 kWh annually.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY TOU-PA-SOP Current Rate	IMPROVED PLANT TOU-PA-SOP	
	current Rate	Current Rate	Savings
Total kWh	146,976	117,584	29,392
kW Input	42.4	33.9	8.5
kWh per Acre Ft.	323	258	64
Acre Ft. per Year	455.7	455.7	
Avg. Cost per kWh	\$0.09		
Avg. Cost per Acre Ft.		\$23.33	\$5.83
Overall Plant Eff. (%)	56.0	70.0	
TOTAL ANNUAL COST	\$13,288.96	\$10,631.44	\$2,657.52

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (661)726-5662.

Manager

Hydraulic Services

CHISON P

42060 10th St. W. Lancaster, CA 93534-7002



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - WEST WELL #3

35TH W 1/4 S/O AVE A

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

DATE OF TEST: August 28, 2003

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact GARY PARDUE at (661)726-5662.

EQUIPMENT

PUMP: L & B MOTOR: US

NO: 21847

NO: 1025182

60 HP

METER: 0728K-1297

HYDRAULIC TEST REFERENCE NUMBER: 2579

TEST RESULTS

ILDI REDUELE	
Discharge Pressure, PSI	0.9
Standing Water Level, Ft.	148.3
Drawdown, Ft.	40.7
Discharge Head, Ft.	2.1
Pumping Water Level, Ft.	189.0
Total Head, Ft.	191.1
Capacity, GPM	962.0
GPM per Ft. Drawdown	23.6
Acre Ft. Pumped in 24 Hrs.	4.252
kW Input to Motor	60.7
HP Input to Motor	81.4
Motor Load (%)	122.1
Measured Speed of Pump, RPM	1,775
kWh per Acre Ft.	343
Overall Plant Efficiency (%)	57.0

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 28, 2003 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP Current Rate

Total kWh	187,980
kW Input	60.7
kWh per Acre Ft.	343
Acre Ft. per Year	548.6
Avg. Cost per kWh	\$0.09
Avg. Cost per Acre Ft.	\$31.45
Overall Plant Eff. (%)	57.0
	seem, state with seem state their beds place place place state.
TOTAL ANNUAL COST	\$17.254.86

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (661)726-5662.

DAN L JOHNSON

Manager



August 31, 2003

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 28, 2003 and billing history for the past 12 months.

It is recommended and assumed that:

- 1. Overall plant efficiency can be improved from 57.0% to 70.0%. These improvements can save you up to 34,823 kWh annually.
- 2. Water requirements will be the same as for the past year.
- 3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY TOU-PA-SOP	IMPROVED PLANT TOU-PA-SOP	EFFICIENCY
	Current Rate	Current Rate	Savings
Total kWh kW Input	187,980 60.7	153,157 49.5	34,823 11.2
kWh per Acre Ft. Acre Ft. per Year	343 548.6	279 548.6	63
Avg. Cost per kWh Avg. Cost per Acre Ft.	\$0.09	\$25.63	\$5.83
Overall Plant Eff. (%)		70.0	- CO*CO
TOTAL ANNUAL COST	\$17,254.86	\$14,058.42	\$3,196.44

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact GARY PARDUE at (601)726-5662.

DAN I JOHNSON Manager

Hydraulic Services

42060 10th St. W. Lancaster, CA 93534-7002

SOUTHERN CALIFORNIA EDISON WTERNATIONAL® COmpany

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - NORTH WELL #1

35TH ST W N/S AVE A

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

DATE OF TEST: August 24, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (661)726-5662.

EQUIPMENT

PUMP: AUROR NO: V8472099

MOTOR: US NO: R718303919 30 HP

METER: 732M-54

HYDRAULIC TEST REFERENCE NUMBER: 2580

TEST RESULTS	TEST 1	TEST 2	TEST 3
Discharge Pressure, PSI	7.0	12.9	22.6
Standing Water Level, Ft.	147,6	147.6	147.6
Drawdown, Ft.	34.6	29.8	25.1
Discharge Head, Ft.	16.2	29.8	52.2
Pumping Water Level, Ft.	182.2	177.4	172.7
Total Head, Ft.	198.4	207.2	224.9
Capacity, GPM	328.0	295.0	270.0
GPM per Ft. Drawdown	9.5	9.9	10.8
Acre Ft. Pumped in 24 Hrs.	1.450	1.304	1.193
kW Input to Motor	25.0	24.4	23.3
HP Input to Motor	33.5	32.7	31.2
Motor Load (%)	98.9	96.5	92.2
Measured Speed of Pump, RPM	1,760		20.2
kWh per Acre Ft.	414	449	469
Overall Plant Efficiency (%)	49.0	47.2	49.1

Test 1 is the normal operation of this pump at the time of the above test(s). The other results were obtained by throttling the discharge.

Manager

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® CUmpany

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 24, 2004 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY PA-1

Current Rate

Total kWh	13,572
kW Input	25.0
kWh per Acre Ft.	414
Acre Ft. per Year	32.8
Avg. Cost per kWh	\$0.11
Avg. Cost per Acre Ft.	\$46.53
Overall Plant Eff. (%)	49.0
TOTAL ANNUAL COST	\$1,525.61

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at (661) 726-5662.

DAN L JOHNSON

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 30 - PLANT: NORTH WELL #1

CUST #: 0-006-1729 - SERV ACCT #: 003-4220-09

HYDRAULIC TEST REFERENCE NUMBER: 2580

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 24, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

 Overall plant efficiency can be improved from 49.0% to 65.0%. These improvements can save you up to 3,337 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY PA-1	IMPROVED PLANT PA-1	EFFICIENCY
	Current Rate	Current Rate	Savings
Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh	13,572 25.0 414 32.8 \$0.11	10,235 18.9 312 32.8	3,337 6.1 102
Avg. Cost per Acre Ft. Overall Plant Eff. (%)	\$46.53	\$35.09 65.0	\$11.44
TOTAL ANNUAL COST	\$1,525.61	\$1,150.49	\$375.12

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at \$662,726/5662.

Managér

Hydraulic Services

10180 Telegraph Rd. Ventura, CA 93004



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - EAST WELL #2

E/S 30TH W S/O AVE A

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

50 HP

DATE OF TEST: August 23, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: D18009

MOTOR: US NO: H1019392

METER: 732K-1194

HYDRAULIC TEST REFERENCE NUMBER: 2578

TEST RESULTS

1201 1000011	
Discharge Pressure, PSI	0.9
Standing Water Level, Ft.	127.8
Drawdown, Ft.	40.0
Discharge Head, Ft.	2.1
Pumping Water Level, Ft.	167.8
Total Head, Ft.	169.9
Capacity, GPM	676.0
GPM per Ft. Drawdown	16.9
Acre Ft. Pumped in 24 Hrs.	2.988
kW Input to Motor	42.0
HP Input to Motor	56.3
Motor Load (%)	101.4
Measured Speed of Pump, RPM	1,773
kWh per Acre Ft.	337
Overall Plant Efficiency (%)	51.5

Manager

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® COMPANY

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL, WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS

HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 23, 2004 and billing history for the past 12 months.

EXISTING PLANT EFFICIENCY TOU-PA-SOP1 Current Rate

Total kWh	157,248
kW Input	42.0
kWh per Acre Ft.	337
Acre Ft. per Year	466.0
Avg. Cost per kWh	\$0.07
Avg. Cost per Acre Ft.	\$22.84
Overall Plant Eff. (%)	51.5
	~
TOTAL ANNUAL COST	\$10,645.69

The hydraulic test results indicate that this pump is operating in an efficient manner.

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at (661)-726-5662.

DAN L JOHNSON

Manager



SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 50 - PLANT: EAST WELL #2

CUST #: 0-000-2633 - SERV ACCT #: 014-8034-41

HYDRAULIC TEST REFERENCE NUMBER: 2578

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 23, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 51.5% to 70.0%. These improvements can save you up to 41,569 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY TOU-PA-SOP Current Rate	IMPROVED PLANT TOU-PA-SOP Current Rate	EFFICIENCY Savings
Total kWh kW Input kWh per Acre Ft. Acre Ft. per Year Avg. Cost per kWh	157,248 42.0 337 466.0 \$0.07	115,679 30.9 248 466.0	41,569 11.1 89
Avg. Cost per Acre Ft. Overall Plant Eff. (%)	\$22.84	\$16.80 70.0	\$6.04
TOTAL ANNUAL COST	\$10,645.69	\$7,831.46	\$2,814.23

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at/ (5627726/9662.

SOUTHERN CALIFORNIA An EDISON INTERNATIONAL® Company

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: HYDRAULIC TEST RESULTS - WEST WELL #3

3310 W AVENUE A

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

60 HP

DATE OF TEST: August 24, 2004

In accordance with your request, a test was made on your turbine well pump on the date listed above. If you have any questions regarding the results which follow, please contact RICK KOCH at (661)726-5662.

EQUIPMENT

PUMP: L & B NO: 21847

MOTOR: US NO: 1025182

METER: 0728K-1297

HYDRAULIC TEST REFERENCE NUMBER: 2579

TEST RESULTS	TEST 1	TEST 2
Discharge Pressure, PSI	0.9	44.0
Standing Water Level, Ft.	141.8	141.8
Drawdown, Ft.	39.6	22.1
Discharge Head, Ft.	2.1	101.6
Pumping Water Level, Ft.	181.4	163.9
Total Head, Ft.	183.5	265.5
Capacity, GPM	878.0	322.0
GPM per Ft. Drawdown	22.2	14.6
Acre Ft. Pumped in 24 Hrs.	3.881	1.423
kW Input to Motor	60.7	52.0
HP Input to Motor	81.4	69.7
Motor Load (%)	122.1	104.6
Measured Speed of Pump, RPM	1,777	
kWh per Acre Ft.	375	877
Overall Plant Efficiency (%)	50.0	31.0

The above test results indicate various operating conditions of this pump. Test #1 the pump was running slightly throttled. Test #2 the pump was filling the domestic reservoir.

Manager

SOUTHERN CALIFORNIA EDISON INTERNATIONAL® Company

SOUTHERN CALIFORNIA EDISON

CONFIDENTIAL/PROPRIETARY INFORMATION

August 27, 2004

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

SUBJECT: PUMPING COST ANALYSIS - HP: 60 - PLANT: WEST WELL #3

CUST #: 0-006-1729 - SERV ACCT #: 003-6970-34

HYDRAULIC TEST REFERENCE NUMBER: 2579

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the Edison Pump Test performed August 24, 2004 and billing history for the past 12 months.

It is recommended and assumed that:

1. Overall plant efficiency can be improved from 50.0% to 70.0%. These improvements can save you up to 55,684 kWh annually.

2. Water requirements will be the same as for the past year.

3. All operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test.

EXISTING	PLANT EFFICIENCY TOU-PA-SOP	IMPROVED PLANT TOU-PA-SOP	EFFICIENCY
	Current Rate	Current Rate	Savings
		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	
Total kWh	194,724	139,040	55,684
kW Input	60.7	43.3	17.4
kWh per Acre Ft.	375	268	107
Acre Ft. per Year	518.6	518.6	
Avg. Cost per kWh	\$0.07		
Avg. Cost per Acre Ft.		\$18.16	\$7.27
Overall Plant Eff. (%)	50.0	70.0	•
TOTAL ANNUAL COST	\$13,192.55	\$9,419.95	\$3,772.60

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued.

If you have any additional questions regarding this report, please contact RICK KOCH at 1661) 726-5662.

Manager

Hydraulic Services

L/JOHNSON

# SOUTHERN CALIFORNIA EDISON INTERNATIONAL COMPANY

### Confidential/Proprietary Information

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30

Cust#: 0-006-1729

Serv. Acct. #: 003-4220-09

Meter: 3412M-7140

140 Pump Ref.#:

2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on December 22, 2011, billing history for the past 12 months, and your current rate of TOU-PA-A.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 36.1% to 61.0%.
- 2. This can save you up to 2,350 kWh and \$1,667.34 annually.
- 3. These kWh savings translate to a 1.0-ton decrease in CO2 emissions.

	Plant Efficiency			
	<u>Exi<b>s</b>ting</u>	<u>Improved</u>	<u>Savings</u>	
Total kWh	5,760	3,410	2,350	
kW Input	26.0	15.4	10.6	
kWh per Acre Foot	501	296	204	
Acre Feet per Year	11.5			
Average Cost per kWh	\$0.71			
Average Cost per Acre Foot	\$355.23	\$210.29	\$144.94	
Overall Plant Efficiency (%)	36.1	61.0	* / / / / / /	
Total Annual Cost	\$4,086.37	\$2,419.04	\$1,667.34	

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

RUSS JOHNSON Manager Hydraulic Services



# Save Energy, Save Money... Your test results show that you can!

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A

HP: 30 003-4220-09

Cust #: 0-006-1729 Meter: 3412M-7140

Serv. Acct. #: Pump Ref.#:

2580

#### Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on December 22, 2011. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

Annual Total	\$4,086,37	\$2,419.04	\$1,667,34	\$901.08
Overall Plant Efficiency (%)	36.1	61.0		
Average Cost per Acre Foot	\$355.23	\$210.29	\$144.94	
kWh per Acre Foot	501	296	204	
Acre Feet per Year	11.5			
kW on-peak activity factor *			6.9	\$689.56
kW Input	26.0	15.4	10.6	
Total kWh	5,760	3,410	2,350	\$211.52
	Existing	Improved	Savings	Cash Incentive

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 10.6 kW, and the savings used for incentive calculations is 65% of 10.6, or 6.9 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Effliciency: Your OPE can be improved from 36.1% to 61.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-A, we estimate that you may save up to 2,350 kWh annually (which translates to a 1.0-ton decrease in CO₂ emissions). This may result in energy cost savings of \$1,667.34.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$901.08</u>, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

# SOUTHERN CALIFORNIA EDISON INTERNATIONALE COMPANY

#### Confidential/Proprietary Information

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Cust #: 0-000-2633

Serv. Acct. #: 014-8034-41

Meter: 3412M-6681

Pump Ref.#:

2578

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on December 22, 2011, billing history for the past 12 months, and your current rate of TOU-PA-SOP-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 55.0% to 65.0%.
- 2. This can save you up to 24,753 kWh and \$2,419.63 annually.
- 3. These kWh savings translate to a 11-ton decrease in CO₂ emissions.

	Plant Efficiency					
	<u>Existing</u>	<u>Improved</u>	<u>Savings</u>			
Total kWh	160,392	135,639	24,753			
kW Input	42.6	36.0	6.6			
kWh per Acre Foot	340	287	52			
Acre Feet per Year	472.1					
Average Cost per kWh	\$0.10					
Average Cost per Acre Foot	\$33.21	\$28.08	\$5.13			
Overall Plant Efficiency (%)	55.0	65.0				
Total Annual Cost	\$15,678.32	\$13,258.68	\$2,419.63			

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

RUSS JOHNSON Manager Hydraulic Services



# Save Energy, Save Money. . . Your test results show that you can!

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 
 PUMPING COST ANALYSIS, Plant: EAST WELL #2

 Location: E/S 30TH W S/O AVE A
 HP: 50

 Cust #: 0-000-2633
 Serv. Acct. #: 014-8034-41

 Meter: 3412M-6681
 Pump Ref.#: 2578

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on December 22, 2011. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings Existing **improved** Savings Cash Incentive Total kWh 160,392 135.639 24.753 \$2,227.80 kW Input 42.6 36.0 6.6 kW on-peak activity factor * 4.3 \$427.34 Acre Feet per Year 472.1 kWh per Acre Foot 340 287 52 Average Cost per Acre Foot \$33.21 \$28.08 \$5.13 Overall Plant Efficiency (%) 55.0 65.0 Annual Total \$15,678.32 \$13,258.68 \$2,419,63 \$2,655.14

("The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 6.6 kW, and the savings used for incentive calculations is 65% of 6,6, or 4.3 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 55.0% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-SOP-1, we estimate that you may save up to 24,753 kWh annually (which translates to a 11-ton decrease in CO₂ emissions). This may result in energy cost savings of \$2.419.63.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$2,655.14</u>, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact KRISTINA L LUNA at (909)873-7964 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

# SOUTHERN CALIFORNIA EDISON® As EDISON INTERNATIONAL® Company

#### Confidential/Proprietary Information

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

**PUMPING COST ANALYSIS,** Plant: WEST WELL #3 Location: 3310 W AVENUE A HP: 60

Cust #: 0-006-1729 Serv. Acct. #: 003-6970-34

Meter: 3416M-7011 Pump Ref.#: 2579

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on December 22, 2011, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 53.8% to 65.0%.
- 2. This can save you up to 28,826 kWh and \$3,035.39 annually.
- 3. These kWh savings translate to a 13-ton decrease in CO₂ emissions.

	Plant Efficiency			
	<u>Existing</u>	<u>Improved</u>	<u>Savings</u>	
Total kWh	166,788	137,962	28,826	
kW Input	59.4	49.1	10.3	
kWh per Acre Foot	356	295	62	
Acre Feet per Year	467.9			
Average Cost per kWh	\$0.11			
Average Cost per Acre Foot	\$37.53	\$31.05	\$6.49	
Overall Plant Efficiency (%)	53.8	65.0		
Total Annual Cost	\$17,562.78	\$14,527.39	\$3,035.39	

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

RUSS JOHNSON Manager Hydraulic Services



# Save Energy, Save Money... Your test results show that you can!

December 23, 2011

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A HP: 60

Cust #: 0-006-1729 Serv. Acct. #: 003-6970-34 Meter: 3416M-7011 Pump Ref.#: 2579

Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on December 22, 2011. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings
Improved Savings

	<u>Existina</u>	<u>Improved</u>	<u>Savings</u>	Cash Incentive
Total kWh	166,788	137,962	28,826	\$2,594.35
kW Input	59.4	49.1	10.3	
kW on-peak activity factor *			6.7	\$667.30
Acre Feet per Year	467.9			
kWh per Acre Foot	356	295	62	
Average Cost per Acre Foot	\$37.53	\$31.05	\$6.49	
Overall Plant Efficiency (%)	53.8	65.0		
Annual Total	\$17,562.78	\$14,527.39	\$3,035.39	\$3,261.65

("The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 10.3 kW, and the savings used for incentive calculations is 65% of 10.3, or 6.7 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 53.8% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-P-S-1-AP, we
  estimate that you may save up to 28,826 kWh annually (which translates to a 13-ton decrease in CO₂ emissions). This may
  result in energy cost savings of \$3,035,39.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$3.261.65</u>, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

# SOUTHERN CALIFORNIA An EDISON INTERNATIONALS Company

#### Confidential/Proprietary Information

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A HP: 30 Cust #: 0-006-1729 Serv. Acct. #: 003-4220-09

Meter.

254000-016403 Pump Ref.#: 2580

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 22, 2012, billing history for the past 12 months, and your current rate of PA-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 37.3% to 61.0%.
- 2. This can save you up to 2,041 kWh and \$969.98 annually.
- 3. These kWh savings translate to a 0.9-ton decrease in CO2 emissions.

	Plant Efficiency					
	Existing	<u>Improved</u>	Savings			
Total kWh	5,256	3,215	2,041			
kW input	24.7	15.1	9.6			
kWh per Acre Foot	508	311	197			
Acre Feet per Year	10.3					
Average Cost per kWh	\$0.48					
Average Cost per Acre Foot	\$241.51	\$147.74	\$93,77			
Overall Plant Efficiency (%)	37.3	61.0	• -			
Total Annual Cost	\$2,498.23	\$1.528.25	\$969.98			

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

**RUSS JOHNSON** Manager Hydraulic Services



# Save Energy, Save Money. . . Your test results show that you can!

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: NORTH WELL #1

Location: 35TH ST W N/S AVE A HP: 30 Cust #: 0-006-1729 Serv. Acct. #: 003-4220-09

Meter: 254000-016403 Pump Ref.#: 2580

#### Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on October 22, 2012. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

	Existing	<u>Improved</u>	<u>Savings</u>	Cash Incentive
Total kWh	5,256	3,215	2,041	\$183.67
kW Input	24.7	15.1	9.6	
kW on-peak activity factor *			6.2	\$623.36
Acre Feet per Year	10.3			
kWh per Acre Foot	508	311	197	
Average Cost per Acre Foot	\$241.51	\$147.74	\$93.77	
Overall Plant Efficiency (%)	37.3	61.0		
Annual Total	\$2,498.23	\$1,528.25	\$969.98	\$807.03

("The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 9.6 kW, and the savings used for incentive calculations is 65% of 9.6, or 6.2 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 37.3% to 61.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of PA-1, we estimate that you
  may save up to 2,041 kWh annually (which translates to a 0.9-ton decrease in CO₂ emissions). This may result in energy
  cost savings of \$969.98.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive
  an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency
  Program. Based on your estimated kWh and kW, you would be eligible for a <u>Potential Cash Incentive of \$807.03</u>, capped
  at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application. All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

# SOUTHERN CALIFORNIA EDISON INTERNATIONALE COMPANY

#### Confidential/Proprietary Information

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: EAST WELL #2

Location: E/S 30TH W S/O AVE A

HP: 50

Cust #: 0-000-2633

Serv. Acct. #: 014-8034-41

Meter:

3412M-6681

Pump Ref.#:

2578

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 22, 2012, billing history for the past 12 months, and your current rate of TOU-PA-SOP-1.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- 1. Overall plant efficiency can be improved from 54.9% to 65.0%.
- 2. This can save you up to 26,123 kWh and \$2,418.17 annually.
- 3. These kWh savings translate to a 11-ton decrease in CO₂ emissions.

	<u>Existing</u>	<u>Improved</u>	<u>Savings</u>
Total kWh	167,388	141,265	26,123
kW Input	43.1	36,4	6.7
kWh per Acre Foot	356	301	56
Acre Feet per Year	469.8		
Average Cost per kWh	\$0.09		
Average Cost per Acre Foot	\$32. <del>9</del> 8	\$27.83	\$5.15
Overall Plant Efficiency (%)	54.9	65.0	
Total Annual Cost	\$15,495.11	\$13,076.94	\$2,418.17

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

RUSS JOHNSON Manager Hydraulic Services



# Save Energy, Save Money... Your test results show that you can!

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: EAST WELL #2

Location: E/S 30TH W S/O AVE A

014-8034-41

Cust #: 0-000-2633 Meter:

Serv. Acct. #: 3412M-6681 Pump Ref.#:

2578

#### Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on October 22, 2012. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings Existing improved Savings Cash Incentive Total kWh 167,388 141,265 26,123 \$2,351.03 kW Input 43,1 36.4 6.7 kW on-peak activity factor * 4.4 \$437.20 Acre Feet per Year 469.8 kWh per Acre Foot 356 301 56 Average Cost per Acre Foot \$32.98 \$27.83 \$5.15 Overall Plant Efficiency (%) 54.9 65.0 Annual Total \$15,495.11 \$13,076.94 \$2,418.17 \$2,788.24

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 6.7 kW, and the savings used for incentive calculations is 55% of 6.7, or 4.4 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 54.9% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-PA-SOP-1, we estimate that you may save up to 26,123 kWh annually (which translates to a 11-ton decrease in CO2 emissions). This may result in energy cost savings of \$2,418.17.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a Potential Cash Incentive of \$2,788,24. capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact Veronica Diaz at (626)812-7670 to complete a project application. All applicants must receive a written approval authorization before implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison



### Confidential/Proprietary Information

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650

PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A

HP: 60

Cust #: 0-006-1729

Serv. Acct. #: 003-6970-34

Meter:

2579

3416M-7011 Pump Ref.#:

The following energy efficiency analysis is presented as an aid to your cost accounting. This is an estimate based on the conditions present during the Edison pump test performed on October 22, 2012, billing history for the past 12 months, and your current rate of TOU-P-S-1-AP.

Assuming that water requirements will be the same as for the past year, and all operating conditions (annual hours of operation, head above, and water pumping level) will remain the same as they were at the time of the pump test, it is estimated that:

- Overall plant efficiency can be improved from 56.2% to 65.0%.
- 2. This can save you up to 27,867 kWh and \$2,564.34 annually.
- 3. These kWh savings translate to a 12-ton decrease in CO₂ emissions.

	Existing	Plant Efficiency Improved	<u>Savings</u>
Total kWh	204,780	176,913	27,867
kW Input	60.7	52,4	8.3
kWh per Acre Foot	382	330	52
Acre Feet per Year	536.7		
Average Cost per kWh	\$0.09		
Average Cost per Acre Foot	\$35.11	\$30.33	\$4.78
Overall Plant Efficiency (%)	56.2	65.0	7
Total Annual Cost	\$18,843.86	\$16,279.52	\$2,564.34

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions regarding this report, please contact RICK KOCH at (805)654-7312.

**RUSS JOHNSON** Manager Hydraulic Services



# Save Energy, Save Money... Your test results show that you can!

October 26, 2012

ATTN: ED WOPSCHALL WAGAS LAND COMPANY 4906 INDIANOLA WAY LA CANADA, CA 91011-2650 PUMPING COST ANALYSIS, Plant: WEST WELL #3

Location: 3310 W AVENUE A

Cust #: 0-006-1729 Serv. Acct. #: 003-6970-34

Meter: 3416M-7011 Pump Ref.#: 2579

#### Dear SCE Customer:

Helping California businesses save energy and money is a major goal at SCE. As you know, our Technical Specialist performed a free energy efficiency test on one or more pumps at your facility on October 22, 2012. We thank you for the opportunity to provide this service, and appreciate your interest in the performance of your pumps.

The results of the testing, shown in the table below, indicate that the pump listed above has the potential for improved Overall Plant Efficiency (OPE), lower energy costs, and a cash incentive.

Projected Incentive, Energy, and Cost Savings

	Existing	Improved	Savings	Cash Incentive
Total kWh	204,780	176,913	27,867	\$2,508.05
kW Input	60.7	52.4	8.3	•
kW on-peak activity factor *			5.4	\$536.92
Acre Feet per Year	536.7			
kWh per Acre Foot	382	330	<b>52</b>	
Average Cost per Acre Foot	\$35.11	\$30.33	\$4.78	
Overall Plant Efficiency (%)	56.2	65.0		
Annual Total	\$18.843.86	\$16,279,52	\$2,564.34	\$3,044.96

(*The kW on-peak activity factor represents how the kW impacts the SCE system during on-peak periods as determined by SCE's agricultural and water pumping customers' average load profiles. By improving efficiency, your expected kW savings is 8.3 kW, and the savings used for incentive calculations is 65% of 8.3, or 5.4 kW.)

Case studies have shown that repairing, retrofitting, or replacing inefficient pumps can save energy and money, and may even help you avoid serious operational problems. For your business, this could mean the following:

- Improved Plant Efficiency: Your OPE can be improved from 56.2% to 65.0%.
- Lower Energy Costs: Based on the test data, your past energy usage, and your current rate of TOU-P-S-1-AP, we estimate that you may save up to 27,867 kWh annually (which translates to a 12-ton decrease in CO₂ emissions). This may result in energy cost savings of \$2,564.34.
- Cash Incentive: Through the retrofit and installation of more energy-efficient equipment, you have the potential to receive an incentive of \$0.09 per kWh and \$100 per on-peak activity factored kW reduced, courtesy of SCE's Customized Efficiency Program. Based on your estimated kWh and kW, you would be eligible for a Potential Cash Incentive of \$3.044.96, capped at 50% of your project cost. (See contract for details.)

If you are interested in an incentive for this pump, please contact CHRISTIAN TORRES at (626)633-9954 to complete a project application, All applicants must receive a written approval authorization <u>before</u> implementing any project; failure to comply will result in forfeiture of incentive funding.

We encourage you to review your results and take advantage of SCE's energy efficiency expertise and incentives. Visit www.sce.com/rebatesandsavings, or give us a call and let us know how we can be of further service to you.

Sincerely,

Southern California Edison

EXHIBIT "K"

- 18 -

DECLARATION

LAW OFFICES OF BEST BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, GALIFORNIA 92502 EXHIBIT "L"

- 19 -

DECLARATION

LAW OFFICES OF BEST BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, CALIFORNIA 92502 EXHIBIT "M"

- 20 -

#### Appendix D-3: Table 4 **Applied Crop Water Duties and Irrigation Efficiency Values** (DU = 80%)

#### **Antelope Valley Area of Adjudication**

					CONTRACTOR OF THE PROPERTY OF	2007				areas 6
Crop	ET: (in)	P _e ² (in)	ET _{AW} ³ (in)	DU⁴ (%)	AW _c ⁵ (in)	AW _{er} ⁶ (in)	AW _{pr} ⁷ (in)	(in) AW _T ⁸	(ft)	E _{irr} ⁹ (%)
Alfalfa	62.10	ZZ ZZ	60.33	80	75.42	0	2.0	77.42	6.5	81
Carrots	27.47	0.00	27.47	80	34.33	6	6,5	46.83	3.9	85
Grain	22.94	1.42	21.52	80	26,90	0	4.0	30.90	2.6	83
Melons/Squash	23.91	0.00	23.91	80	29.88	0	4.0	33.88	2.8	82
Onions	37.57	0.00	37.57	80	46.96	3	4.0	53.96	4.5	83
Orchard (Deciduous)	47.38	0.00	47.38	80	59.22	0	0.0	59.22	4.9	80
Pasture	66.19	1.77	64.42	80	80.53	0	0.0	80.53	6.7	80
Potatoes	24.02	0.00	24.02	80	30.03	0	4.0	34.03	2.8	82
Silage	27.31	0.00	27.31	80	34.14	0	4.0	38.14	3.2	82
Sugar Beets	40.55	0.00	40.55	80	50.68	. 0	4.0	54.68	4.6	81
Vineyard (Grapes)	35,33	0.00	35.33	. 80	44.16	0	0.0	44.16	3.7	. 80

¹ ET_c = K_c* ET_o where ET_o = average ET for specified periods, based on data from Victorville CIMIS Station, 1994-2003); K_c values from Univ. California Cooperative Extension

² P_o = effective precipitation offsetting ET_c, up to 1/2 of the average precipitation, in Dec. - Feb., inclusive

³ ET_{AW} = evapotranspiration of applied water = ET_c - P_e

⁴ DU = Irrigation distribution uniformity

⁵ AW_c = applied water for crop requirement = ET_{AW} + DU

⁶ AW_c = applied water for crops on control

AW_{pr} = applied water for field preparation and pre-inigation

³ AW_T = applied crop water duty = AW_c + AW_{er} + Aw_{pr}
³ E_{rr} = overall irrigation efficiency for beneficial uses = (ET_{AW} + AW_{er} + AW_{pr}) + AW_T

**4**0

EXHIBIT "N"

28

27

LAW OFFICES OF BEST BEST & KRIEGER LLP 3750 UNIVERSITY AVENUE, SUITE 400 P.O. BOX 1028 RIVERSIDE, CALIFORNIA 92502

EXHIBIT "O"

#### PROOF OF SERVICE

# STATE OF CALIFORNIA, COUNTY OF LOS ANGELES

I am over the age of eighteen and not a party to the within action. I am employed by Hanna and Morton LLP in the County of Los Angeles, State of California. My business address is 444 South Flower Street, Suite 1500, Los Angeles, CA 90071-2916.

On January 29, 2013, I served the following document(s) in the *Antelope Valley Groundwater Adjudication* cases, JCCP No. 4408, described as: **DECLARATION OF EDWARD A. WOPSCHALL IN LIEU OF DEPOSITION TESTIMONY FOR PHASE 4 TRIAL** 

on the interested parties in this action, by posting the document(s) listed above to the Santa Clara County Superior Court e-filing website (http://www.scefiling.org) under the Antelope Valley Groundwater matter pursuant to the Court's Order dated October 27, 2005.

Executed on January 29, 2013, at Los Angeles, California.

**(STATE)** I declare under penalty of perjury under the laws of the State of California that the above is true and correct.

Johnen Cantas Sylvia Cantos